



AIR-COOLED SPLIT-TYPE DUCTED AIR CONDITIONERS

DATA BOOK

Series : PE(H)

	Model	Service ref.
Cooling only	PE-7MYC	PE-7MYC-EU
	PE-8MYC	PE-8MYC-EU
	PE-10MYC	PE-10MYC-EU
	PE-15MYC	PE-15MYC-EU
	PE-20MYC	PE-20MYC-EU
Heat pump	PEH-5MYA	PEH-5MYA-EU
	PEH-7MYA	PEH-7MYA-EU
	PEH-8MYA	PEH-8MYA-EU
	PEH-10MYA	PEH-10MYA-EU
	PEH-15MYA	PEH-15MYA-EU
	PEH-TOWITA	PEH-TOWTA-EU
	PEH-15MYA	PEH-15MYA-EU PEH-20MYA-EU

CONTENTS

SAFETY FOR USE	2
A COMPLETE LINE UP	4
FEATURES	5
DESCRIPTIONS	5
MECHANICAL SPECIFICATIONS	6
TYPICAL INSTALLATION EXAMPLE	6
MODEL-DESIGNATION BREAKDOWN	·7
SPECIFICATIONS	8
ELECTRICAL DATA	11
SELECTION PROCEDURE	14
CAPACITY TABLES	16
OPERATION RANGE	36
FAN PERFORMANCE	37
SOUND DATA	40
OUTLINE DIMENSIONS	41
WIRING DIAGRAMS	48
ELECTRICAL OPERATION FLOW CHARTS	71
REFRIGERANT SCHEMATICS	74
SAFETY & CONTROL DEVICES	75
SPECIAL ORDER	77
PHYSICAL DATA	78
INSTALLATION	87
INSTRUCTIONS FOR USE	103
HOW TO OPERATE	
SPECIFICATION GUIDELINES	112

SAFETY FOR USE

Before conducting installation work, please read this "SAFETY FOR USE" carefully for correct installation.

Since the caution items shown here contain important description relative to safety, please observe them without fail.

Marning

Erroneous handling gives a high possibility to induce serious results such as death or heavy injury.

<u></u> C

Caution

Erroneous handling may induce serious injury depending on the situation.

After reading, please keep it with you together the Instruction Manual, and read it again at the movement of the unit.

Ask your dealer or specialized subcontractor for installation.

Conducting installation work by yourself improperly may cause a fire, electric shock or water leakage.

For installation, conduct the work correctly by following the Installation Manual.

Improper installation may cause a fire, electrical shock or water leakage.

Install the unit on a spot sufficiently durable against the unit weight.

Insufficient durability can cause an injury by the falling down of unit.

All electric work must be performed by licensed technician, according to local regulations and the instructions given in this manual.

The units should be powered by dedicated power lines.

Power lines with insufficient capacity or improper electrical work may result in electric shock or fire.

Use only the specified cables for wiring. The connections must be made secured without tension the terminals.

Improper connection or fastening can cause a fire or electrical shock.

The unit should be installed according to the instructions in order to minimize the risk of damage from earthquakes, typhoons or strong winds.

Improper installation work can cause an injury by the falling down of the unit.

The outdoor unit must be installed on stable, level surface, in a place where there is no accumulation of snow, leaves or rubbish.

The outdoor unit should be installed in a location where air and noise emitted by the unit will not disturb the neighbors. The indoor unit should be securely installed.

If the unit is loosely mounted, it may fall, and cause injury.

The heating of refrigerant is noted.

When the refrigerant touches the fire etc., it was decomposed and a poisonous gas is generated.

Do not use the welding machine etc., in the room close up of the installation of the air conditioner.

Never repair the unit, remodel or transfer it to another site by yourself.

If they are performed improperly, water leakage, electric shock or fire may result. If you need to have the unit repaired or moved, consult your dealer.

Use only the specified refrigerant (R-22) to charge the refrigerant circuit.

Do not mix it with any other refrigerant and do not allow air to remain in the circuit.

Air enclosed in the circuit can cause high pressure resulting in a rupture and other hazards.

Ventilate the room if refrigerant leaks during Installation.

The refrigerant heated generates poisonous gas by decomposition which can cause poisoning.

After completing installation work, make sure that refrigerant gas has not leaked.

If refrigerant gas has leaked and exposed to fan heater, stove, oven and so on, it may generate noxious gases. Please do the gas leakage inspection before starting.

Take a proper measure to suppress the critical concentration of refrigerant if leaked when installing the unit in a small room.

The limit density is made not to be exceeded even if the refrigerant leaks by any chance.

You are necessary to ventilation measures to prevent the accident. If the refrigerant leaks, hypoxia accident may caused.

For the countermeasure to be taken, consult your dealer.

The terminal block cover of unit must be firmly attached to prevent entry of dust and moisture.

Improper mounting of the cover cause electric shock or fire.

Use only optional parts authorised by Mitsubishi Electric.

If the accessories are installed improperly, water leakage, electric shock or fire may result.

Ask your dealer or an authorised company to install them.

Never install on the place where a combustible gas might leak.

The gas may ignite or explode when the gas leaks and collects in surround of the unit.

When the unit is installed at telecommunication centers or hospitals, take a proper provision against noise.

The erroneous operation of air conditioner may be induced by inverter equipment, independent power device, medical equipment or communication equipment.

For special use as for foods, animals/plants, precision equipment or art objects, the applicability should be confirmed beforehand.

As the use for the applications other than that designed originally may result in the deterioration of the quality. Consult your dealer in this regard.

Do not use the unit under a special atmosphere. Installing the unit at the following places may cause a trouble, a place where is much machine oil, salt, humidity or dust, spa district, a place full of sulfur gas, volatile gas, or corrosive gas, a place near high frequency processing machine.

Thermal insulation of the drain pipes is necessary prevent dew condensation. If the drain pipes are not properly insulated,

If the drain pipes are not properly insulated, condensation will result and drip on ceiling, floor or other possessions.

The unit should be securely installed level surface. When the unit inclines, it causes the water leak and the breakdown

Please confirm the horizontal with the spirit level.

Install drain piping (hose) according to this Installation Manual to ensure proper drainage. Improper drain piping (hose) may cause water leakage and damage to furniture or other possessions.

The unit must be properly earth connected. Do not connect the earth wire to gas pipe, city water pipe, lightning rod or telephone earth wire. Improper earth connection may cause electrical shock.

When installing at a watery place, provide an electric leak breaker.

Failure to mount the electric leak breaker may cause electrical shock.

Use breaker or fuse with proper capacity. Make sure that each appliance has a main power

Using a wire or copper wire instead of proper capacity can cause fire or trouble.

Other appliances connected to the same line could cause an overload.

For the power lines, use standard cables of sufficient current capacity.

Otherwise, current leakage, overheating or fire may occur.

When installing the power lines, do not apply tension to the cables.

The tighten or loosen the connections may cause generate heat and cause fire.

A thing embarrassed which gets wet under the unit is not put.

When the room is high humidity or when the drain pipe is clogged, water may drip from the indoor unit.

Arrange the configuration of wiring not to bring up the panel and terminal cover, and fasten the panel and terminal cover securely. The poor mounting of the panel or terminal cover may

The poor mounting of the panel or terminal cover may cause the heat generation of the terminal connection, a fire or electrical shock.

Do not wash the unit with water.

If washed with water, electric shock may be caused.

Do not handle the switch with wet hands. Otherwise electric shock can be resulted.

Be very careful about unit transportation.

The unit should not be carried by only one person if it is more than 20kg. It occasionally causes the damage of the unit and health to be impaired.

Some unit use PP bands for packing. Do not use any PP band for delivery purpose. It may cause the injury. Do not touch the heat exchanger fins with your bear hands. Doing so may cut your hands.

When carrying in outdoor unit, be sure to support it at four points. Carrying in and lifting with 3-point support may make outdoor unit unstable, resulting in a fall of it. Be sure to safety dispose the packing materials. Packing materials, such as catches and other metal or wooden parts, may cause stabs or other injuries.

Do not leave the mounting base being damaged.

The damaged base may cause the falling down of the unit which may give injury.

Turn on the main power switch more than 6 hours before starting operation.

Do not turn the main power switch OFF during seasons of heavy use, doing so can result in failure.

Do not touch the compressor or refrigerant piping without wearing glove on your hands.

Touching directly such part can cause a burn or frostbite as it becomes high or low temperature according to the refrigerant state.

Do not touch the metal edges inside the unit without wearing glove on your hands.

Touching directly it may injure your hands.

Do not remove the panel or the fan guard from the unit when it is running.

You could be injured if you touch rotating, hot or high-voltage parts.

Do not operate the air conditioner without the air filter set place.

Dust may accumulate, and cause a failure.

At emergency (if you smell something burning), stop operation and turn the power source switch off.

Continuing the operation without eliminating the emergency state may cause a machine trouble, fire, or electrical shock.

After stopping operation, be sure to wait for five minutes before turning off the main power switch.

Otherwise, water leakage or unit failure may occur.

Remote controller is not installed for the place where direct sunshine strikes.

Remote controller is not pushed with the thing sharpening ahead.

It occasionally causes the electric shock and the breakdown.

A COMPLETE LINE UP

		PEH-5	PE(H)-7	PE(H)-8	PE(H)-10	PE(H)-15	PE(H)-20
	kW	14.4	17.9	22.0	28.8	44.0	57.6
Cooling capacity	Btu/h	49,150	61,000	75,100	98,300	150,200	196,600
	kcal/h	12,400	15,400	18,900	24,800	37,900	49,600
Heating capacity (PEH only)	kW	14.4	18.8	22.0	28.8	44.0	57.6
	Btu/h	49,150	64,100	75,100	98,300	150,200	196,600
	kcal/h	12,400	16,200	18,900	24,800	37,900	49,600

Note: Cooling & heating capacities are based following conditions.

Cooling: Indoor:27 °CDB, 19 °C WB; Outdoor: 35 °CDB

Heating: Indoor:21°CDB; Outdoor: 7 °CDB, 6 °CWB (PEH only)

Cooling and Heating capacities are based 5m pipe length

Indoor unit

Example PEH-7



Outdoor unit

Example PUH-7



FEATURES

High sensible cooling capacity.

The sensible cooling capacity has been significantly improved through balanced optimised heat exchanger design.

Comfort heating. (PEH only)

The PEH series are designed to provide effective heating even when the outside temperature is down to -10 $^{\circ}$ C.

Highly efficient operation.

The EER(Energy Efficiency Ratio) on these models is greatly improved by revised design specifications and by being manufactured stringently to Mitsubishi Electric high quality standards.

Flexibility of Supply Air Delivery

PE, PEH-15,20 feature belt driven Supply Air fans enabling accurate matching of actual airflow rates to the specified quantities. Accurate commissioning is assisted by the capability to change pulleys and belts if necessary to achieve the desired air balance.

Low ambient cooling. (Special order)

In applications with relatively high internal loads, there may be a requirement for all series to operate on cooling at low ambient conditions. Special order parts is available to maintain the refrigeration circuit in balance at outdoor temperatures as low as -5°C.

Please consult your local Mitsubishi Electric Sales office for application advice on these parts.

Labour saving installation.

The unit operation can commence immediately after connecting to the power supply, refrigerant piping, drain piping, ducting and control system.

Wide electrical control capability.

All series is flexible mechanical control configuration.

In addition Global Remote Controller is prepared as special order.

The Global Remote Controller gives the programmable weekly timer, compressor anti-short cycle timer(3min.), cool/heat/fan/auto changeover etc.(Heat and auto changeover are only PEH.)

The factory standard is for provision of 24 volt terminal block to enable a field wired control of contractors choice to be connected.

Please consult your local Mitsubishi Electric Sales office for application advice on these control.



Grobal Remote Controller

DESCRIPTIONS

Mitsubishi Electric air conditioners series PE(H)/PU(H) are available in a wide range of sizes and models to enables the designer to select the best model for each application.

All series units are completely assembled, wired and strictly tested at the factory.

With the development of all series demands for such features as light weight, compactness, increased capacity, appropriate static pressure, air flow control, and having flexibility of inter facing energy saving electronic controls, Mitsubishi Electric have met market expectations.

MECHANICAL SPECIFICATIONS

General

All units are factory assembled, piped, internally wired. They are also tested and checked under a strict quality control system in the factory.

Exterior surfaces of all units of outdoor unit are phosphatized, zinc-coated steel with powder coating and ivory white baked enamel finish.

Refrigeration Controls

Refrigeration controls include condenser fan, evaporator fan and compressor contactors.

Compressors

All units have high efficiency type hermetic line starting compressors.

Compressors are equipped with thermal overload protector, over-current relay and high pressure protection control.

Crankcase heaters are standard.

Evaporator Coils

Highly efficient cross-finned coil are applied to provide a larger cooling capacity with low air speed on the coil. Coils are made of 9.52mm OD and 0.35mm thick seamless copper tubing mechanically bonded to 0.12mm thick aluminium fins and are factory leak tested at a pressure of 3.3MPa. They are provided with strainers attached to the capillary tubes to further ensure a clean system.

Condenser Coils

Unnecessary power input due to higher discharge pressure is avoided by high performance designs of cross-finned coil.

Condenser coils are made of 9.52mm OD, 0.35mm thick seamless copper tubes mechanically bonded to 0.12mm thick aluminium fins and factory pressure and leak tested at 3.3MPa.

Evaporator Fans


The sirocco fans are made of galvanised steel and balanced to proved accurate air flow performance at low noise level.

Condenser Fan


The direct-drive propeller fan is dynamically balanced, to ensure smooth airflow.

A weatherproof three-phase squirrel cage induction motor is used to drive the condenser fan.

TYPICAL INSTALLATION EXAMPLE



MODEL-DESIGNATION BREAKDOWN



SPECIFICATIONS

PE-7~20MYC

Cooling only

			DE 7141/0	DE OMAYO	DE 40M/0	DE 45MVO	DE 00111/0			
Model name			PE-7MYC	PE-8MYC	PE-10MYC	PE-15MYC	PE-20MYC			
Service reference	_		PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU			
Power supply	Indoor		1PH 2W220~240V 50Hz		3PH 4W380	~ 415V 50Hz				
	Outdoor		3PH 4W 380~415V 50Hz		3PH 4W380	~ 415V 50Hz				
Total cooling ca	apacity	kW	17.9	22.0	28.8	44.0	57.6			
		Btu/h	61,100	75,100	98,300	150,200	196,600			
		kcal/h	15,400	18,900	24,800	37,900	49,600			
Sensible coolin	a capacity	kW	14.3	17.6	23.0	35.2	46.1			
Condidio dodini	goapaony	Btu/h	48,800	60,100	78,500	120,200	157,300			
				30,200	39,600					
Capacity step		%	.2,000	0-100	10,000	· · ·	0-100			
	Refrigerant			0-100	R-22	1 0-5	0-100			
Refrigerant cha	ırae	kg	5.7	5.0	8.7	2 X 4.8	2 X 9.7			
	-	Ng	5.7	5.0	Capillary tube	2 7 4.0	2 X 3.1			
Refrigerant con			DE ZMVC	DE OMYC		PE-15MYC	PE-20MYC			
Indoor Unit	Model name		PE-7MYC	PE-8MYC	PE-10MYC	PE-TSIVIYC	PE-20IVIYC			
	Service reference		PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU			
External finish					Galvanized steel					
Dimension	Height	mm		428		70				
	Width	mm	1,4	15	1,615	1,690	1,993			
	Depth	mm		650	86	35				
Net weight k			67	70	84	180	212			
Indoor coil										
Indoor fan			Centrifu	Centrifugal (Galvanized) - Direct drive Centrifugal (Galvanized) - Belt drive						
Indoor fan moto	or		Single phase induction motor	ga. (Ga.ra200) D	Three phase indu		2011 2011 2011 2011 2011 2011 2011 2011			
		kW		1 X 0.7	1 X 1.0		1 X 3.7			
No. X Motor ou	•	CMM	1 X 0.21 60	70	90	1 X 2.2 140	180			
Indoor fan air fl	ow	CFM			3,179					
		L/S	2,119	2,472	·	4,945	6,358			
Fortament at a Ca			1,000	1,167	1,500	2,333	3,000			
External static pressure		mmAq		12.5			20			
•		Pa	125			200				
Sound pressure		dB(A)	55 56 59		61	62				
Drain connection	on .	mm			25.4					
Outdoor unit	Model name		PU-7MYC	PU-8MYC	PU-10MYC	PU-15MYC	PU-20MYC			
	Service reference		PU-7MYC1-EU(S)	PU-8MYC1-EU(S)	PU-10MYC1-EU(S)	PU-15MYC1-EU(S)	PU-20MYC1-EU(S)			
External finish					Acrylic resin coating					
Color					Munsell 5Y 8/1					
Dimension	Height	mm		980		1,230	961			
	Width	mm		1,400		998	1,996			
	Depth	mm		700		9	98			
Net weight		kg	202	205	230	285	360			
Compressor					etic line start(reciproc					
No. X Motor ou	tput	kW	1 X 5.0	1 X 5.5	1 × 7.5	2 × 5.5	2 X 7.5			
Outdoor coil			1,7,0.0		Cross fin coil					
Outdoor fan					Propeller-Direct drive					
Outdoor fan mo	ntor				ee phase induction m					
		LAA	3 × 0 00				2 🗸 0 24			
No. X Motor output Outdoor fan air flow		KW	2 X 0.09		0.15	1 X 0.24	2 X 0.24			
Outdoor fair all	IIOW	CMM	190	210	220	240	480			
		CFM	6,711	7,415	7,770	8,477	16,954			
		L/S	3,167	3,000	3,667	4,000	8,000			
Sound pressure Protection devi		dB(A)	Over current relay (65 ch, freeze & frost procomp & indoor fan, o (comp & indoor fan, o	utdoor fan)	67	68			

Note 1. Cooling capacity is based on the following conditions.

Indoor;27°CDB,19°CWB, Outdoor;35°CDB

- Cooling capacity is based 5m pipe length.

 2. Refergirant charge volumes are factory charged (at 5m piping length). Refrigerant is enclosed with the outdoor unit.
- 3. Capacity is gross capacity which do not include a deduction for evaporator fan motor heat.
- 4. The measuring point of the Sound pressure level is 1m from the unit surface.
- 5. Specification subject to change without notice.

PEH-5,7,8MYA

Heat pump

Model name			PEH-5MYA	PEH-7MYA	PEH-8	BMYA			
Service reference			PEH-5MYA-EU	PEH-7MYA-EU	PEH-8M	IYA-EU			
Power supply	Indoor		3PH 4W380~415V 50Hz	1PH 2W220~240V 50Hz	3PH 4W380~	-415V 50Hz			
	Outdoor		3PH 4W380~415V 50Hz	3PH 4W380~415V 50Hz	3PH 4W380~	-415V 50Hz			
Total cooling ca	pacity	kW	14.4	17.9	22.	.0			
		Btu/h	49,150	61,100	75,1	00			
		kcal/h	12,400	15,400	18,9	900			
Sensible cooling	g capacity	kW	11.5	14.3	17.	.6			
	. ,	Btu/h	39,400	48,800	60,1	00			
		kcal/h	10,000	12,300	15,1	00			
Sensible heating capacity kW			14.4	18.8	22.	.0			
		Btu/h	49,150	64,100	75,1	00			
		kcal/h	12,400	16,200	18,9	900			
Capacity step		%		0-1	00				
Refrigerant				R-	22				
Refrigerant cha	*	kg	5.0	5.7	6.0	6			
Refrigerant con				Capilla	•				
Indoor Unit	Model name		PEH-5MYA	PEH-7MYA	PEH-8	BMYA			
	Service reference		PEH-5MYA-EU	PEH-7MYA-EU	PEH-8M	IYA-EU			
External finish				Galvaniz	red steel	·			
Dimension	Height	mm		42					
	Width	mm	1,095		1,4	15			
	Depth	mm		. 65					
Net weight		kg	60 67 70						
Indoor coil				Cross					
Indoor fan				Centrifugal (Galvar	nized) - Direct drive				
Indoor fan moto	or		Three phase induction motor	Single phase induction motor	Three phase in	duction motor			
No. X Motor ou	tput	kW	1 X 0.45	1 X 0.21	1 X (
Indoor fan air fl	ow	CMM	42	60	70				
		CFM	1,483	2,119 1,000	2,4				
Cutamal static		L/S	700	67					
External static pressure		mmAq Pa	12.5 125						
Sound pressure	a lovol		5	2					
Drain connection		dB(A) mm	u	25	56)			
Outdoor unit	Model name		PUH-5MYE	PUH-7MYC	PUH-8MYC	PUH-8MYE			
2 a. a. o. o. a. iii	Service								
	reference		PUH-5MYE-EU	PUH-7MYC1-EU(S)	PUH-8MYC1-EU(S)	PUH-8MYE-EU			
External finish				Acrylic res	sin coating				
Color				Munsel					
	Height	mm	1,175	98	30	1,175			
	Width	mm	1,000	1,4	00	1,250			
	Depth	mm	550	70	00	550			
Net weight		kg	150	211	214	188			
Compressor				Hermetic line sta	art(reciprocating)				
No. X Motor ou	tput	kW	1 X 3.73		1 X 5.5				
Outdoor coil				Cross	fin coil				
Outdoor fan				Propeller-D					
Outdoor fan motor				Three phase in					
No. X Motor ou	•	kW	1 X 0.15	2 X		1 X 0.35			
Outdoor fan air	tlow	CMM	95	16		200			
		CFM	3,355	5,8		7,063			
Occurat		L/S	1,583	2,7		3,333			
Sound pressure Protection devi		dB(A)	Over current relay (comp	6 eeze & frost protection, Fuso & indoor fan, outdoor fan) p & indoor fan, outdoor fan	se	65			

Note 1. Cooling and heating capacities are based on the following conditions.

Cooling indoor; 27°CDB, 19°CWB, outdoor:35°CDB

Heating indoor; 21°CDB, outdoor:7.0°CDB, 6.0°CWB

outdoor :7.0°CDB, 6.0°CWB

- Cooling and heating capacities are based 5m pipe length.

 2. Refergirant charge volumes are factory charged (at 5m piping length). Refrigerant is enclosed with the outdoor unit.

 3. Capacity is gross capacity which do not include a deduction for evaporator fan motor heat.

 4. The measuring point of the Sound pressure level is 1m from the unit surface.

- 5. Specification subject to change without notice.

PEH-10,15,20MYA

Heat pump

Model name			PEH-10	DMYA	PEH-15MYA	PEH-20MYA			
Service reference			PEH-10M	MYA-EU	PEH-15MYA-EU	PEH-20MYA-EU			
Power supply	Indoor			3PH 4W380) ~ 415V 50Hz				
	Outdoor			3PH 4W380) ~ 415V 50Hz				
Total cooling ca	pacity	kW	28.	8	44.0	57.6			
		Btu/h	98,3	00	150,200	196,600			
		kcal/h	24,8	00	37,900	49,600			
Sensible cooling	capacity	kW	23.	0	35.2	46.0			
`	. ,	Btu/h	78,5	00	120,200	157,000			
		kcal/h	19,8	00	30,200	39,600			
Sensible heatin	g capacity	kW	28.	8	44.0	57.6			
		Btu/h	98,3	00	150,200	196,600			
		kcal/h	24,8	00	37,800	49,500			
Capacity step		%	0-10	00	0-50)-100			
Refrigerant				F	R-22				
Refrigerant cha	rge	kg	9.9	9	2 X 6.6	2 X 9.7			
Refrigerant con	trol			Capil	lary tube				
Indoor Unit	Model name		PEH-10	DMYA	PEH-15MYA	PEH-20MYA			
	Service reference		PEH-10M	1YA-EU	PEH-15MYA-EU	PEH-20MYA-EU			
External finish	10.0.0			Galvan	ized steel				
Dimension	Height	mm	42			06			
	Width	mm	1,6		1,690	1,993			
	Depth	mm	650		 '	65			
Net weight		kg	84		180				
Indoor coil				Cross fin coil					
Indoor fan			Centrifugal (Galvani	ized) - Direct drive	Centrifugal (Galva	anized) - Belt drive			
Indoor fan moto	or		0 1		induction motor	,			
No. X Motor ou		kW	1 X ·	· · · · · · · · · · · · · · · · · · ·	1 X 2.2	1 X 3.7			
Indoor fan air fl	•	CMM	90		140	180			
indoor ian an in	Svv	CFM	3,17		4,945	6,358			
		L/S	1,50		2,333	3,000			
External static		mmAq	12.	5	2	20			
pressure		Pa	12:	5	2	00			
Sound pressure	e level	dB(A)	59)	61	·			
Drain connection	n	mm			5.4				
Outdoor unit	Model name		PUH-10MYC	PUH-10MYE	PUH-15MYC	PUH-20MYC			
	Service reference		PUH-10MYC1-EU(S)	PUH-10MYE-EU	PUH-15MYC1-EU(S)	PUH-20MYC1-EU(S)			
External finish				Acrylic re	esin coating				
Color					ell 5Y 8/1				
Dimension	Height	mm	980	1,175	1,2	200			
	Width	mm	1,400	1,250		951			
	Depth	mm	700	550	+ '	080			
Net weight		kg	240	221	431	472			
Compressor					tart(reciprocating)				
No. X Motor ou	tput	kW	1 X 7	7.5	2 X 5.5	2 X 7.5			
Outdoor coil				Cross	s fin coil				
Outdoor fan				•	-Direct drive				
Outdoor fan mo	otor				induction motor				
No. X Motor ou		kW	2 X 0.15	0.35	2 X	0.35			
Outdoor fan air	flow	CMM	190	200	2 X	185			
		CFM	6,711	7,063		6,534			
		L/S	3,167	3,333		3,083			
Sound pressure Protection devi		dB(A)	Over current relay (comp	5 eeze & frost protection, Fu o & indoor fan, outdoor fan p & indoor fan, outdoor fal	ise i)	69			

Note 1. Cooling and heating capacities are based on the following conditions.

Cooling indoor; 27°CDB, 19°CWB, outdoor :35°CDB

outdoor :7.0°CDB, 6.0°CWB indoor; 21°CDB,

- Cooling and heating capacities are based 5m pipe length.

 2. Refergirant charge volumes are factory charged (at 5m piping length). Refrigerant is enclosed with the outdoor unit.
- 3. Capacity is gross capacity which do not include a deduction for evaporator fan motor heat.
- 4. The measuring point of the Sound pressure level is 1m from the unit surface.
- 5. Specification subject to change without notice.

ELECTRICAL DATA

PE-7~20MYC-EU

Cooling

VOLT	ITEM		PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU
VOLI			PU-7MYC1-EU	PU-8MYC1-EU	PU-10MYC1-EU	PU-15MYC1-EU	PU-20MYC1-EU
	TOTAL INPUT	kW	7.2	7.8	10.1	17.6	22.0
	TOTAL RUN CURRENT	Α	14.6	14.2	18.9	29.6	39.1
PE-7	POWER FACTOR	%	-	74	74	83	78
240V	START CURRENT	Α	74	83	82	119	140
- 101	COMPRESSOR INPUT	kW	6.0	6.8	8.6	2X7.65	2X9.2
PE-	RUN CURRENT	Α	10.7	12.3	15.9	2X12.45	2X15.95
8~20	INDOOR FAN INPUT	kW	0.8	0.6	1.0	1.7	2.4
415V	RUN CURRENT A		3.2	1.2	2.0	3.5	4.8
	OUTDOOR FAN INPUT	kW	0.4	0.4	0.5	0.6	2X0.6
	RUN CURRENT	Α	0.7	0.7	1.0	1.2	2X1.2
	TOTAL INPUT	kW	7.2	7.8	10.1	17.6	22.0
	TOTAL RUN CURRENT	Α	15.9	15.5	20.7	32.3	42.7
PE-7	POWER FACTOR	%	-	74	74	83	78
220V	START CURRENT	Α	81	91	90	131	152
	COMPRESSOR INPUT	kW	6.0	6.8	8.6	2X7.65	2X9.2
PE-	RUN CURRENT	Α	11.6	13.4	17.6	2X13.65	2X17.55
8~20	INDOOR FAN INPUT	kW	0.8	0.6	1.0	1.7	2.4
380V	RUN CURRENT	Α	3.5	1.3	2.1	3.8	5.2
	OUTDOOR FAN INPUT	kW	0.4	0.4	0.5	0.6	2X0.6
	RUN CURRENT	Α	0.8	0.8	1.0	1.2	2X1.2

PEH-5,7,8MYA-EU

Cooling

			PEH-5MYA-EU	PEH-7MYA-EU	PEH-8MY	A-EU
VOLT	ITEM		PUH-5MYE-EU	PUH-7MYC1-EU	PUH-8MYC1-EU	PUH-8MYE-EU
	TOTAL INPUT	kW	5.5	7.2	7.8	7.9
	TOTAL RUN CURRENT	Α	9.5	14.6	14.2	14.7
 PEH-7	POWER FACTOR	%	80	-	76	75
240V	START CURRENT	Α	69	74	83	83
2101	COMPRESSOR INPUT	kW	4.7	6.0	6.8	6.77
PEH-	RUN CURRENT	Α	8.1	10.7	12.3	12.3
8~20	INDOOR FAN INPUT	kW	0.54	0.8	0.6	0.6
415V	RUN CURRENT	Α	0.9	3.2	1.2	1.2
	OUTDOOR FAN INPUT	kW	0.25	0.4	0.4	0.53
	RUN CURRENT	Α	0.5	0.7	0.7	1.2
	TOTAL INPUT	kW	5.5	7.2	7.8	7.9
	TOTAL RUN CURRENT	Α	10.4	15.9	15.5	16.0
PEH-7	POWER FACTOR	%	80	-	76	75
220V	START CURRENT	Α	69	81	91	91
	COMPRESSOR INPUT	kW	4.7	6.0	6.8	6.77
PEH-	RUN CURRENT	Α	8.85	11.6	13.4	13.4
8~20	INDOOR FAN INPUT	kW	0.54	0.8	0.6	0.6
380V	RUN CURRENT	Α	1.0	3.5	1.3	1.3
	OUTDOOR FAN INPUT	kW	0.25	0.4	0.4	0.53
	RUN CURRENT	Α	0.55	0.8	0.8	1.3

Heating

VOLT	ITEM		PEH-5MYA-EU	PEH-7MYA-EU	PEH-8M	YA-EU
VOLI	I I ⊏IVI		PUH-5MYE-EU	PUH-7MYC1-EU	PUH-8MYC1-EU	PUH-8MYE-EU
	TOTAL INPUT	kW	4.5	6.3	6.5	6.6
	TOTAL RUN CURRENT	Α	8.5	13.6	12.4	12.9
PEH-7	POWER FACTOR	%	73	-	73	71
240V	START CURRENT	Α	69	74	83	83
	COMPRESSOR INPUT	kW	3.7	5.1	5.5	5.47
PEH-	RUN CURRENT	Α	7.1	9.7	10.5	10.5
8~20	INDOOR FAN INPUT	kW	0.54	0.8	0.6	0.6
415V	RUN CURRENT	Α	0.9	3.2	1.2	1.2
	OUTDOOR FAN INPUT	kW	0.25	0.4	0.4	0.53
	RUN CURRENT	Α	0.5	0.7	0.7	1.2
	TOTAL INPUT	kW	4.5	6.3	6.5	6.6
	TOTAL RUN CURRENT	Α	9.2	14.9	13.6	14.1
PEH-7	POWER FACTOR	%	74	-	73	71
220V	START CURRENT	Α	69	81	91	91
	COMPRESSOR INPUT	kW	3.7	5.1	5.5	5.47
PEH-	RUN CURRENT	Α	7.75	10.6	11.5	11.5
8~20	INDOOR FAN INPUT	kW	0.54	0.8	0.6	0.6
380V	RUN CURRENT	Α	1.0	3.5	1.3	1.3
	OUTDOOR FAN INPUT	kW	0.25	0.4	0.4	0.53
	RUN CURRENT	Α	0.55	0.8	8.0	1.3

PEH-10,15,20MYA-EU

Cooling

VOLT	ITEM		PEH-10M\	/A-EU	PEH-15MYA-EU	PEH-20MYA-EU
VOLI	II ⊑IVI		PUH-10MYC1-EU	PUH-10MYE-EU	PUH-15MYC1-EU	PUH-20MYC1-EU
	TOTAL INPUT	kW	10.1	10.2	16.9	21.8
	TOTAL RUN CURRENT	Α	18.9	19.1	30.9	39.3
PEH-7	POWER FACTOR	%	74	74	76	77
240V	START CURRENT	Α	82	82	119	140
	COMPRESSOR INPUT	kW	8.57	8.67	2X6.77	2X9.12
PEH-	RUN CURRENT	Α	15.9	15.9	2X12.2	2X16.1
8~20	INDOOR FAN INPUT	kW	1.0	1.0	2.3	2.5
415V	RUN CURRENT	Α	2.0	2.0	4.1	4.7
	OUTDOOR FAN INPUT	kW	0.53	0.53	2X0.53	2X0.53
	RUN CURRENT	Α	1.0	1.2	2X1.2	2X1.2
	TOTAL INPUT	kW	10.1	10.2	16.9	21.8
	TOTAL RUN CURRENT	Α	20.7	21.0	33.7	42.9
PEH-7	POWER FACTOR	%	74	74	76	77
220V	START CURRENT	Α	90	90	131	152
	COMPRESSOR INPUT	kW	8.57	8.67	2X6.77	2X9.12
PEH-	RUN CURRENT	Α	17.6	17.6	2X13.3	2X17.6
8~20	INDOOR FAN INPUT	kW	1.0	1.0	2.3	2.5
380V	RUN CURRENT	Α	2.1	2.1	4.5	5.1
	OUTDOOR FAN INPUT	kW	0.53	0.53	2X0.53	2X0.53
	RUN CURRENT	Α	1.1	1.3	2X1.3	2X1.3

Heating

VOLT	ITEM		PEH-10M	/A-EU	PEH-15MYA-EU	PEH-20MYA-EU
VOLI	I I EIVI		PUH-10MYC1-EU	PUH-10MYE-EU	PUH-15MYC1-EU	PUH-20MYC1-EU
	TOTAL INPUT	kW	8.3	8.6	14.5	17.2
	TOTAL RUN CURRENT	Α	16.0	16.2	26.9	33.2
PEH-7	POWER FACTOR	%	72	72	75	72
240V	START CURRENT	Α	82	82	115	136
2101	COMPRESSOR INPUT	kW	6.77	7.07	2X5.57	2X6.82
PEH-	RUN CURRENT	Α	13.0	13.0	2X10.2	2X13.05
8~20	INDOOR FAN INPUT	kW	1.0	1.0	2.3	2.5
415V	RUN CURRENT	Α	2.0	2.0	4.1	4.7
	OUTDOOR FAN INPUT	kW	0.53	0.53	2X0.53	2X0.53
	RUN CURRENT	Α	1.0	1.2	2X1.2	2X1.2
	TOTAL INPUT	kW	8.3	8.6	14.5	17.2
	TOTAL RUN CURRENT	Α	17.5	17.8	29.4	36.3
PEH-7	POWER FACTOR	%	72	72	75	72
220V	START CURRENT	Α	90	90	126	148
	COMPRESSOR INPUT	kW	6.77	7.07	2X5.57	2X6.82
PEH-	RUN CURRENT	Α	14.4	14.4	2X11.15	2X14.25
8~20 380V	INDOOR FAN INPUT	kW	1.0	1.0	2.3	2.5
	RUN CURRENT	Α	2.1	2.1	4.5	5.1
	OUTDOOR FAN INPUT	kW	0.53	0.53	2X0.53	2X0.53
	RUN CURRENT	Α	1.1	1.3	2X1.3	2X1.3

SELECTION PROCEDURE

1. Model Selection (With actual examples)

First step, to select the approximate model:

Based on the cooling load and the cooling capacity listed in the capacity table, select the applicable model.

Second step, to select the model:

To select the model, the following conditions must be known:

- (1) Total cooling load or sensible cooling load
- (2) Indoor conditioned temperature (WB*1, DB)
- (3) Designed outdoor temperature (DB)*2
- (4) Designed air flow
- (5) Designed external static pressure (= Wind pressure loss of air duct)*3

Notes:

- *1. The correct WB is required since it has a serious effect on the capacity.
- *2. The cooling capacity decreases as the outdoor temperature increases. Therefore, the estimated highest temperature during an air conditioning time frame is the "designed outdoor temperature". However, it is recommended that the abnormal outdoor temperature which may occur once or twice a year be excluded from the calculation to avoid selection of an excessively large capacity model.
- *3. The wind pressure loss of an air duct should be calculated correctly. If a value having an excessive allowance is used, an excessively large model will be selected. Moreover, an excessively high air flow will be induced during actual operation causing the generation of high operating sounds and carry-over of condensed water.

(Step-1) Confirmation of operation range

Confirm that the conditions given above for the model to be selected are within the operation range listed on Page 36.

(Step-2) Calculation of actual air flow, external static pressure, and fan motor input

Based on the designed air flow and external static pressure, obtain the actual air flow, actual external static pressure, and fan motor power input from the fan performance table for the model selected. For an explanation of how to use the fan performance table, see the following examples.

Example: PE-8MYC, 50Hz

Example 1. (To operate with values near to the designed air flow and external static pressure.)

Condition: Designed air flow 70CMM

Designed external static pressure 60Pa

Calculation: The designed point is A. Therefore, duct resistance line passing A is


dotted line.

Therefore, actual point is B for Δ connection

Actual air flow = 77CMM

Actual external static pressure = 70Pa

Notes: Duct resustance line is secondary curve.



(Step-3) Calculation of net capacity

Based on the indoor conditioned temperature (WB,DB), designed outdoor temperature (DB), and the actual air flow obtained in Step-2, obtain the gross capacity from the gross capacity tables (pages 16~35). Then, calculate the net capacity from the formula below by using the fan motor input obtained in Step-2.

Net capacity (kW) = Gross capacity (kW) - Fan motor input (kW)

Example: PE-8MYC

Condition:

Indoor conditioned temp.: 26°CDB, 19°CWB

Designed outdoor temp.: 40°CDB

Actual air flow: 77CMM

Fan motor input: 0.6kW (See P.11)

Calculation:

The sections of the gross capacity table applicable for the above conditions are shown right.

At 26°CDB, 19°CWB of Indoor, Q = 21.3, SHC = 16.3, T/I = 8.3

		OUTDOOR DB°C					
INDOOR	INDOOR		40.0				
DB°C	WB°C		Q kW	SHC kW	SHF	T/I kW	
26	19		21.3	16.3	0.77	8.3	
			- !	- 1	- !	- !	

Factor for Various Air Flow

PE-8MYC-EU		CMM	60	70	80
PE-8MYC-EU	AIR VOLUME	L/S	1,000	1,167	1,330
COOLING	CAPACITY		0.976	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
l	SHC		0.963	1.0	1 044

Therefore, when air flow is 77(CMM)

Q = 21.3 X (1+(1.025 - 1.0) X $7/10^*$) = 21.7(kW)

SHC = $16.3 \times (1+(1.044 - 1.0) \times 7/10^*) = 16.8(kW)$

 $T/I = 8.3 \times (1+(1.009-1.0)) \times 7/10^*) = 8.4(kW)$

Note *: 7/10 = (77-70)/(80-70)

Therfore, the net capacity is,

Net total cooling capacity = 21.7 (kw) - 0.6(kW)

= 21.1 (kW)

Net sensible cooling capacity = 16.8 (kW) - 0.6 (kW)

= 16.2 (kW)

2. Efficiency Calculation

• Refrigerant cycle energy efficienty

(1) COP = Gross total cooling capacity (kW)

Compressor input (kW)

System energy efficienty

(1) COP = Net cooling capacity (kW)

Compressor input (kW)

(2) ERR = Gross total cooling capacity (kW)

Total input (kW)

(2) ERR = Net cooling capacity (kW)

Total input (kW)

1kW = 3412Btu/h

Notes: 1. COP: Coefficient of performance

2. EER: Energy efficiency ratio

3. Temperature condition of COP, EER (ARI Standard Ratings) Indoor entering air temp. : 80°FDB (=27°CDB), 66°FWB(=19°CWB)

Outdoor entering air temp. : 95°FDB (=35°CDB)

4. Total input = Compressor input + Indoor fan motor input + Outdoor fan motor input (page 11).

CAPACITY TABLES

Cooling Capacity (Standard Air Flow) PEH-5MYE-EU

L L X X X X X X X X X X X X X X X X X X	L	CMM	32	42	20
01-11MC-U14	AIR VOLUME	S/J	584	200	834
	CAPACITY		0.969	1.0	1.025
	TOTAL INPUT		0.989	1.0	1.009
	SHC		0.967	1.0	1.028

Heating Capacity (Standard Air Flow)

PEH-5MYE-EU

	0.0	T/I kW	3.7	3.7	3.8	3.8	3.8	3.8	3.9	3.9	3.9	4.0	4.1	4.1	4.1
	0	Q KW	12.4	12.3	12.3	12.3	12.2	12.2	12.2	12.1	12.1	12.0	12.0	11.9	11.8
OUTDOOR WB °C	0.	T/IKW	3.4	3.4	3.4	3.5	3.5	3.5	3.5	3.5	3.6	3.6	3.6	3.6	3.7
OUTDOC	-5.0	Q kW	10.7	10.7	10.7	10.6	10.6	10.5	10.5	10.4	10.4	10.3	10.3	10.2	10.2
•	0:	T/I kW	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.3	3.3
	-10.0	Q KW	9.2	9.2	9.1	9.1	9.1	0.6	0.6	8.9	8.9	8.8	8.8	8.7	8.7
	INDOOR	DB °C	15	16	17	18	19	20	21	22	23	24	25	26	27

^{*} Q : HEATING CAPACITY T/I : TOTAL INPUT

		CMM	35	42	20
PEH-5MYA-EU	AIK VOLUME	S/J	584	200	834
CIVIE	CAPACITY		0.987	1.0	1.011
ם און אינו	TOTAL INPUT	ΤU	1.021	1.0	0.983

Cooling Capacity (Standard Air Flow) PE-7MYC-EU, PEH-7MYA-EU

	.0	SHF T/I kW	0.74 7.9	0.64 8.0	0.54 8.1	6.7 68.0	0.79 8.0	0.69	0.60 8.2	0.52 8.3	0.94 8.0	0.84 8.1	0.73 8.2	0.65 8.3	0.56 8.5	0.47 8.6	0.86 8.2	0.77 8.3	0.68 8.5	0.59 8.6	0.51 8.7	0.42 8.9	0.91 8.3	0.81 8.5	0.71 8.6	0.63 8.7	0.56 8.9	0.49 9.0	0.93 8.5	0.83 8.6	0.74 8.7	6.8 99.0	0.59 9.0
	46.0	SHCKW	10.1	9.1	8.0	12.1	11.2	10.3	9.4	8.2	13.4	12.4	11.4	10.3	9.4	8.2	13.4	12.3	11.4	10.4	9.4	8.1	14.5	13.6	12.4	11.7	10.7	9.7	15.7	14.6	13.6	12.8	11.8
		Q K	13.6	14.2	14.8	13.6	14.2	14.8	15.5	16.0	14.2	14.8	15.5	16.0	16.9	17.6	15.5	16.0	16.9	17.6	18.4	19.2	16.0	16.9	17.6	18.4	19.2	20.0	16.9	17.6	18.4	19.2	20.0
		T/I kW	7.2	7.3	7.5	7.2	7.3	7.5	9.7	7.7	7.3	7.5	9.7	7.7	7.9	8.0	9.7	7.7	7.9	8.0	8.1	8.2	7.7	7.9	8.0	8.1	8.2	8.3	7.9	8.0	8.1	8.2	8.3
	0.0	SHF	0.73	0.63	0.54	0.87	0.77	0.68	0.59	0.51	0.92	0.82	0.72	0.63	0.55	0.46	0.84	0.75	99.0	0.58	0.50	0.43	0.88	0.79	0.69	0.62	0.55	0.47	0.89	0.81	0.72	0.65	0.58
	40.	SHCKW	10.4	9.2	8.5	12.4	11.6	10.7	9.8	8.6	13.8	12.8	11.8	10.7	9.8	8.7	13.9	12.8	11.9	10.9	9.8	8.6	15.0	14.1	13.0	12.1	11.1	10.0	16.0	15.1	14.0	13.2	12.2
		o ₹	14.3	15	15.7	14.3	15.0	15.7	16.5	17.0	15.0	15.7	16.5	17.0	17.9	18.7	16.5	17.0	17.9	18.7	19.5	20.3	17.0	17.9	18.7	19.5	20.3	21.2	17.9	18.7	19.5	20.3	21.2
		T/I kW	6.7	6.8	6.9	6.7	6.8	6.9	7.0	7.2	6.8	6.9	7.0	7.2	7.3	7.4	7.0	7.2	7.3	7.4	7.5	7.7	7.2	7.3	7.4	7.5	7.7	7.8	7.3	7.4	7.5	7.7	7.8
	35.0	子 子	0.71	0.62	0.54	0.84	0.75	0.67	0.58	0.50	0.89	0.80	0.70	0.62	0.54	0.46	0.82	0.73	0.65	0.57	0.50	0.43	0.86	0.77	0.68	0.61	0.53	0.46	0.86	0.78	0.70	0.63	0.56
	3	SHCKW	10.8	6.6	8.8	12.7	11.9	11.0	10.0	8.9	14.1	13.1	12.0	11.1	10.1	9.0	14.0	13.1	12.2	11.3	10.2	9.0	15.4	14.5	13.3	12.4	11.3	10.1	16.1	15.3	14.3	13.4	12.5
OR DB°C		Q KW	12.1	15.8	16.5	15.1	15.8	16.5	17.2	17.9	15.8	16.5	17.2	17.9	18.8	19.6	17.2	17.9	18.8	19.6	20.4	21.2	17.9	18.8	19.6	20.4	21.2	22.2	18.8	19.6	20.4	21.2	22.2
OUTDOOR DB		T/I kW	6.2	6.3	6.4	6.2	6.3	6.4	9.9	6.7	6.3	6.4	9.9	6.7	8.9	6.9	9.9	6.7	8.9	6.9	7.0	7.2	6.7	6.8	6.9	7.0	7.2	7.3	6.8	6.9	7.0	7.2	7.3
	30.0	SHF	0.70	0.62	0.53	0.82	0.74	99.0	0.58	0.49	0.88	0.78	0.69	0.61	0.53	0.45	0.80	0.72	0.63	0.56	0.49	0.42	0.84	0.75	0.67	0.59	0.52	0.45	0.84	0.76	0.69	0.62	0.55
	3	SHCKW	11.1	10.2	9.1	13.0	12.2	11.3	10.4	9.2	14.5	13.4	12.4	11.4	10.4	9.2	14.5	13.4	12.5	11.5	10.5	9.3	15.7	14.8	13.6	12.6	11.5	10.4	16.5	15.6	14.6	13.7	12.8
		Q K	15.8	16.5	17.2	15.8	16.5	17.2	18.0	18.7	16.5	17.2	18.0	18.7	19.7	20.5	18.0	18.7	19.7	20.5	21.3	22.1	18.7	19.7	20.5	21.3	22.1	23.1	19.7	20.5	21.3	22.1	23.1
		T/I kW	5.8	5.9	0.9	5.8	5.9	0.9	6.1	6.3	5.9	0.9	6.1	6.3	6.4	6.5	6.1	6.3	6.4	6.5	9.9	6.8	6.3	6.4	6.5	9.9	6.8	6.9	6.4	6.5	6.6	6.8	6.9
	25.0	/ SHF	0.70	0.61	0.53	0.81	0.73	0.65	0.57	0.49	0.86	0.77	0.68	09.0	0.52	0.44	0.79	0.70	0.62	0.55	0.48	0.41	0.82	0.74	0.65	0.58	0.51	0.44	0.82	0.75	0.67	0.61	0.54
	.,	SHCKW	11.5	10.5	9.4	13.3	12.5	11.6	10.6	9.4	14.7	13.7	12.7	11.6	10.6	9.4	14.7	13.6	12.7	11.7	10.7	9.5	15.8	15.0	13.8	12.9	11.8	10.6	16.7	15.8	14.8	14.1	13.0
		Q KW	16.5	17.2	17.9	16.5	17.2	17.9	18.7	19.3	17.2	17.9	18.7	19.3	20.4	21.2	18.7	19.3	20.4	21.2	22.1	23.0	19.3	20.4	21.2	22.1	23.0	24.0	20.4	21.2	22.1	23.0	24.0
		T/I kW	5.5	5.6	5.7	5.5	5.6	5.7	5.8	5.9	5.6	5.7	5.8	5.9	6.1	6.2	5.8	5.9	6.1	6.2	6.3	6.4	5.9	6.1	6.2	6.3	6.4	9.9	6.1	6.2	6.3	6.4	9.9
	20.0	V SHF	0.69	0.61	0.52	0.80	0.72	0.64	0.57	0.49	0.85	0.76	0.67	0.59	0.52	0.44	0.78	0.70	0.62	0.55	0.48	0.42	0.80	0.72	0.64	0.57	0.51	0.44	0.81	0.74	0.66	09.0	0.53
	.,	SHCKW	11.7	10.8	9.6	13.5	12.8	11.8	10.9	9.7	15.0	14.0	12.9	11.8	10.9	9.7	15.0	13.9	13.1	12.1	11.0	6.6	15.9	15.3	14.1	13.1	12.0	10.9	17.2	16.2	15.1	14.2	13.2
	~	Q K K	16.9	17.7	18.4	16.9	17.7	18.4	19.3	19.9	17.7	18.4	19.3	19.9	21.2	22.0	19.3	19.9	21.2	22.0	22.8	23.7	19.9	21.2	22.0	22.8	23.7	24.7	21.2	22.0	22.8	23.7	24.7
	RINDOOR	WB °C	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	23	24
	INDOOR	DB °C		20				22					24						² 18						28						30		

PE-7MYC-FII		CMM	20	90	20
PEH-7MYA-EU	AIK VOLUME	S/T	830	1,000	1,167
	CAPACITY		0.975	1.0	1.024
COOLING	TOTAL INPUT		0.989	1.0	1.009
	SHC		0.964	1.0	1.040

Cooling Capacity (Standard Air Flow) (Use for low ambient cooling parts)

PE-7MYC-EU, PEH-7MYA-EU

Heating Capacity (Standard Air Flow)	YA-EU	OUTDOOR WB°C	
apacity (PEH-7MYA-EU		
Heating C			-

5.2

5.1 15.6

4.8

11.0 11.0

15.8 15.7

13.4 5.0

11.3

5.1

13.3 13.2

4.7

11.2

15.4 16.1

2.0 2.0

13.5

4.6

11.5

13.8

4.6 4.7

11.7

Q KW | T/1 KW | Q KW | T/1 KW

5.6

15.6

5.1

13.2 13.1

4.8

15.5

5.2

4.8

11.0 10.9

5.8 5.7

5.3 15.3

5.8

15.4

5.3

13.0 12.8 12.7

4.8 4.8 4.9

10.8 10.6 10.6

15.0

5.3

15.1

5.3

Q KW | T/I KW | Q KW | T/I KW | Q KW | T/I KW

24.6

21.4 6.4

5.9

18.5 18.8

5.9 21.7 6.5 24.8

24.4

6.0 21.3 6.6

18.4

18.4

6.1 21.0 6.7 24.2

18.2

18.2

18.2

18.1 18.0

6.0 21.2 6.6 24.4

6.1 21.0 6.7 24.2

6.2 21.0 6.8 24.1

6.2 21.0 6.9 24.1

7.0 24.0

20.9

6.3

15.0

OUTDOOR WB°C

5.7

15.5 15.4

13.1 13.0 12.9

8.4

5.2

4.8 4.8

10.8

10.8

						_			-			_	_				⊢			-	-	-	-	-	_	-	\rightarrow	-	-	_	-	_	-	ш
	INDOOR	DB°C	15	16	17	18	19	20	21	22	23	24	25	26	27				INDOOR	DB °C	15	16	17	18	19	20	21	22	23	54	22	56	27	* Q : HE
		T/I kW	5.6	5.7	5.8	5.6	5.7	5.8	5.9	6.1	5.7	5.8	5.9	6.1	6.2	6.3	6.9	6.1	6.2	6.3	6.4	6.5	6.1	6.2	6.3	6.4	6.5	6.7	6.2	6.3	6.4	6.5	6.7	
		SHF	69.0	0.60	0.52	0.80	0.72	0.64	0.56	0.49	0.84	0.75	99.0	0.59	0.51	0.44	0.77	69.0	0.61	0.55	0.48	0.42	0.78	0.71	0.63	0.57	0.50	0.44	0.80	0.73	0.65	0.59	0.52	
	15.(SHCkW	10.8	9.6	9.0	12.5	11.8	11.0	10.2	9.2	13.8	12.9	12.0	10.9	10.1	9.0	13.9	12.9	12.1	11.2	10.3	9.3	14.6	14.0	12.9	12.1	11.2	10.2	15.8	14.9	14.0	13.1	12.1	
		κW	15.7	16.5	17.3	12.7	16.5	17.3	18.1	18.7	16.5 1	17.3	18.1	18.7 1	19.7	20.5	18.1	18.7	19.7	20.5	21.4	22.2	18.7 1	19.7	20.5	21.4 1	22.2	23.1 1	19.7	20.5	21.4	22.2	23.1	
-		κw	က္	4	5	5.3	5.4	5.5	5.6	5.8 1	5.4 1	5	5.6	5.8	5.9	6.0	5.6	5.8	5.9	6.0	6.1 2	6.3	5.8 1	5.9	6.0	6.1 2	6.3	6.5	5.9	6.0	6.1	က	2	
		1/1	5.	0 5.	2 5.		_					4 5.	_								_			_	_					_		9 6	2 6.	
	10.0	W SHF	0 0.68	.2 0.60	3 0.52	8 0.80	2 0.72	3 0.63	.5 0.56	5 0.49	1 0.83	.2 0.74	2 0.66	3 0.58	5 0.51	3 0.44	.2 0.76	3 0.68	4 0.61	5 0.54	5 0.48	0.41	.2 0.78	.4 0.70	3 0.63	.4 0.57	5 0.50	.5 0.44	2 0.79	3 0.72	3 0.65	5 0.59	.4 0.52	
		/ SHCkW	11.0	10	9.3	12.8	12.2	11.3	10	9.5	14.1	13	12.	. 11.3	10.	9.3	14	. 13.3	12.4	11.5	10.5	9.2	15	4	13.3	12	11.5	10	. 16.2	15.3	14.3	13.	12	
		Q KW	16.1	17.0	17.8	16.1	17.0	17.8	18.7	19.4	17.0	17.8	18.7	19.4	20.4	21.2	18.7	19.4	20.4	21.2	21.9	22.9	19.4	20.4	21.2	21.9	22.9	23.7	20.4	21.2	21.9	22.9	23.7	
B,C		T/I kW	5.1	5.3	5.4	5.1	5.3	5.4	5.5	9.9	5.8	5.4	5.5	9.9	5.8	5.9	5.5	5.6	5.8	5.9	0.9	6.1	9.9	2.8	5.9	0.9	6.1	6.2	5.8	5.9	0.9	6.1	6.2	
OUTDOOR DB°C		SHF	0.72	0.64	0.56	0.84	0.76	0.67	09.0	0.53	0.86	0.78	69.0	0.62	0.55	0.48	0.79	0.71	0.64	0.57	0.51	0.44	0.82	0.74	99.0	09.0	0.54	0.48	0.82	0.75	69.0	0.62	0.56	.INPU
DUT	5.0	SHCKW	11.9	11.2	10.3	13.9	13.2	12.3	11.4	10.5	15.0	14.2	13.1	12.3	11.4	10.3	15.1	14.1	13.3	12.4	11.4	10.3	16.2	15.4	14.2	13.4	12.5	11.5	17.0	16.3	15.5	14.5	13.5	T/I:TOTAL INPUT
		Q KW	16.5	17.4	18.3	16.5	17.4	18.3	19.1	19.8	17.4	18.3	19.1	19.8	20.8	21.7	19.1	19.8	20.8	21.7	22.5	23.3	19.8	20.8	21.7	22.5	23.3	24.3	20.8	21.7	22.5	23.3	24.3	Ë
f		T/I kW	5.1	5.2	5.3	5.1	5.2	5.3	5.3	5.5	5.2	5.3	5.3	5.5	9.6	5.7	5.3	5.5	9.9	5.7	5.8	5.9	5.5	9.6	2.7	5.8	5.9	6.1	9.6	2.7	5.8	5.9	6.1	ACITY
		SHF T	99.0	09.0	0.52	0.79	0.71	0.63	0.56	0.49	0.82	0.73	0.65	0.58	.51	0.44	0.75	0.68	09.0	0.54	0.47	0.41	0.78	0.70	0.62	0.56	0.50	0.44	0.78	0.72	0.65	0.59	0.52	SHC:SENSIBLE HEAT CAPACITY
	0.0	SHCKW	11.3 0	10.6 0	7	13.3 0	12.6 0	11.7 0	10.9 0	6	14.5 0	13.7 0	12.7 0	11.7 0	10.8 0.	9.7 0	14.6 0	13.6	12.7 0	11.8 0	10.8	9.7 0	15.7 0	14.9 0	13.7 0	12.9 0	11.9 0	10.9 0	16.5 0	15.8 0	14.9 0	14.0 0	12.8 0	E HE
		kW SH	_	17.7	3.6 9.	1:	17.7 1:	18.6	2	20.1 9.	17.7 1.	18.6	2	20.1	21.2	22.0 8	19.5 1	20.1	21.2	22.0 1	22.8	23.7 9	20.1 1	21.2 1.	22.0 1:	22.8 1:	23.7	24.4 1	21.2	22.0 1	22.8 1.	23.7 1.	24.4	ENSIBI
-		κw	0 16.	2 17	3 18.	_			19.	5 20		3 18	4 19.	5 20	.6	7 22					2.				2									SHC:SI
		1/1	5.	5.	5.	9 5.0	1 5.2	3 5.3	5.4	5.	2 5.2	5.	5.	5.	5.	4 5.7	5 5.4	8 5.5	0 5.6	4 5.7	5.	1 6.0	8 5.5	0 5.6	2 5.7	6 5.8	0.9 0.0	4 6.1	8 5.6	2 5.7	5 5.8	9 6.0	2 6.1	
	-5.0	N SHF	0.68	0.60	0.52	0.79	0.71	0.63	0.56	0.49	0.82	0.73	0.65	0.58	0.51	0.44	0.75	0.68	09:0	0.54	0.47	0.41	0.78	0.70	0.62	0.56	0.50	0.44	0.78	0.72	0.65	0.59	0.52	\PACIT
	·	SHCKW	11.5	10.7	9.7	13.3	12.7	11.8	11.0	10.0	14.6	13.7	12.8	11.8	11.0	9.8	14.8	13.7	12.9	12.0	10.9	9.8	15.9	12.1	13.8	13.0	12.1	11.0	16.8	16.0	15.1	14.1	13.0	ING C/
		Q KW	16.9	17.9	18.7	16.9	17.9	18.7	19.7	20.3	17.9	18.7	19.7	20.3	21.5	22.2	19.7	20.3	21.5	22.2	23.1	23.9	20.3	21.5	22.2	23.1	23.9	24.7	21.5	22.2	23.1	23.9	24.7	:COOLING CAPACITY
INDOOR		WBC	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	23	24	Note1. * Q
2	!	DB°C		20				22					24						26						28						30	Ţ,		Note

Q: HEATING CAPACITY T/I: TOTAL INPUT

6.4 20.8 7.0 23.9 18.0 6.4 20.8 7.1 23.9

18.0

17.8 6.5 20.6 7.2 23.7

6.5 20.5 7.2 23.6

17.6

Factor for Various Air Flow

1.011	1.0	0.980		CAPACITY	CAL
1,167	1,000	830	L/S	AIR VOLUME	PEH-/MYA-EU
70	09	50	CMM		1

Factor for Various Air Flow	r Various	Air	Flov	_	
PE-7MYC-EU	Live	CMM	20	09	20
PEH-7MYA-EU	AIR VOLUME	S/J	830	1,000	1,167
	CAPACITY		0.975	1.0	1.024
COOFING	TOTAL INPUT		0.989	1.0	1.009
	SHC		0.964	1.0	1.040

Cooling Capacity (Standard Air Flow) PE-8MYC-EU, PEH-8MYA-EU (combined with PUH-8MYC1-EU)

	46.0	SHF T/1 KW Q KW SHCKW SHF T/1 KW	0.74 7.8 17.6 13.2 0.75 8.5	0.65 7.9 18.3 12.1 0.66 8.6	0.55 8.1 18.9 10.8 0.57 8.7	0.88 7.8 17.6 15.6 0.89 8.5	0.78 7.9 18.3 14.5 0.79 8.6	0.68 8.1 18.9 13.2 0.70 8.7	0.61 8.2 19.5 12.1 0.62 8.8	0.53 8.3 20.2 10.9 0.54 8.9	0.92 7.9 18.3 17.2 0.94 8.6	0.83 8.1 18.9 16.0 0.84 8.7	0.74 8.2 19.5 14.6 0.75 8.8	0.65 8.3 20.2 13.3 0.66 8.9	0.56 8.5 20.9 11.9 0.57 9.1	0.47 8.6 21.7 10.4 0.48 9.2	0.85 8.2 19.5 16.8 0.86 8.8	0.77 8.3 20.2 15.8 0.78 8.9	0.69 8.5 20.9 14.6 0.70 9.1	0.60 8.6 21.7 13.3 0.61 9.2	0.52 8.7 22.4 11.7 0.52 9.3	0.43 8.8 23.1 10.0 0.43 9.5	0.88 8.3 20.2 18.4 0.91 8.9	0.80 8.5 20.9 17.4 0.83 9.1	0.73 8.6 21.7 16.3 0.75 9.2	0.64 8.7 22.4 14.8 0.66 9.3	0.56 8.8 23.1 13.2 0.57 9.5	0.48 8.9 23.9 11.5 0.48 9.6	0.92 8.5 20.9 19.4 0.93 9.1	0.83 8.6 21.7 18.5 0.85 9.2	0.75 8.7 22.4 17.3 0.77 9.3	0.69 8.8 23.1 16.4 0.71 9.5	0.63 8.9 23.9 15.6 0.65 9.6
	40.0	kW SHCkW	8.3 13.5	9.1 12.4	9.8 11.0	8.3 16.1	19.1 14.9	19.8 13.6	20.6 12.5	21.3 11.3	19.1 17.6	19.8 16.4	20.6 15.1	21.3 13.8	22.0 12.3	22.8 10.8	20.6 17.4	3 16.3	22.0 15.1	22.8 13.7	23.6 12.2	24.3 10.5	21.3 18.8	22.0 17.7	22.8 16.6	23.6 15.2	24.3 13.7	25.2 12.1	22.0 20.2	22.8 19.0	23.6 17.7	24.3 16.8	25.2 15.9
		T/I KW Q	7.3	7.4	7.5	7.3	7.4	7.5	7.6	7.8 2	7.4	7.5	7.6	7.8 2	7.9	8.0	7.6		7.9	8.0	8.1 2	8.3	7.8	7.9	8.0 2	8.1	8.3	8.4 2	7.9	8.0	8.1 2	8.3 2	8.4
	35.0	SHCkW SHF	14.0 0.73	12.6 0.63	11.1 0.54	16.7 0.87	15.3 0.77	13.8 0.67	12.7 0.60	11.5 0.52	17.9 0.90	16.7 0.81	5.3 0.72	14.0 0.64	12.6 0.55	11.1 0.47	17.7 0.83	16.5 0.75	15.3 0.67	14.0 0.59	12.5 0.51	10.9 0.43	18.7 0.85	17.7 0.78	16.6 0.70	5.3 0.63	14.0 0.55	12.4 0.48	20.5 0.90	19.4 0.82	17.9 0.73	17.0 0.67	15.9 0.61
OR DB°C		Q kW SI	19.2	19.9	20.6	19.2	19.9	20.6	21.3	22.0	19.9	20.6	21.3	22.0	22.8	23.7	21.3		22.8	23.7	24.4	25.3	22.0	22.8	23.7	24.4	25.3	26.0	22.8	23.7	24.4	25.3	26.0
OUTDOOR DB°C		- T/I KW	6.8	6.9	5 7.0	6.8	6.9	7.0	7.2	2 7.3	6.9	7.0	7.2	3 7.3	7.4	3 7.5	2 7.2	7	3 7.4	3 7.5	9.7	3 7.8	1 7.3	7.4	7.5	9.7	5 7.8	3 7.9	7.4	7.5	2 7.6	5 7.8	62 6
	30.0	SHCkW SHF	14.3 0.72	13.0 0.63	11.6 0.55	16.9 0.85	15.6 0.76	14.2 0.67	13.1 0.59	11.8 0.52	18.2 0.89	17.0 0.80	15.7 0.71	14.4 0.63	13.0 0.55	11.4 0.46	18.0 0.82	16.9 0.74	15.7 0.66	14.3 0.58	12.9 0.51	11.3 0.43	19.3 0.84	18.2 0.77	17.0 0.69	15.7 0.62	14.4 0.55	12.9 0.48	21.0 0.89	19.6 0.80	18.2 0.72	17.2 0.65	16.1 0.59
		Q kW SH	19.9	20.6	21.3	19.9	20.6	21.3	22.1	22.9	20.6	21.3	22.1	22.9	23.7	24.5	22.1	6	23.7	24.5	25.4	26.3	22.9	23.7	24.5	25.4	26.3	27.1	23.7	24.5	25.4	26.3	1 1 1
		T/I kW	6.4	6.5	9.9	6.4	6.5	9.9	6.7	6.9	6.5	9.9	6.7	6.9	7.0	7.1	6.7		7.0	7.1	7.2	7.4	6.9	7.0	7.1	7.2	7.4	7.5	7.0	7.1	7.2	7.4	7.5
	25.0	:kW SHF	.6 0.71	.4 0.63	.1 0.55	.1 0.83					.5 0.87		0.70	.7 0.62	.2 0.54	.7 0.46	.3 0.80			9:00	.2 0.50		.6 0.83	.5 0.76	.3 0.68	0.61	.7 0.54		.3 0.87	9.79	.4 0.70	.3 0.64	0 0 57
		Q kW SHCkW	20.6 14.6	21.3 13.4	22.0 12.1	20.6 17.1	21.3 15.9	22.0 14.5	22.8 13.4	23.6 12.1	21.3 18.5	22.0 17.3	22.8 16.0	23.6 14.7	24.4 13.2	25.3 11.7	22.8 18.3	23.6 17.1	24.4 15.9	25.3 14.6	26.2 13.2	27.1 11.6	23.6 19.6	24.4 18.5	25.3 17.3	26.2 16.0	27.1 14.7	28.0 13.2	24.4 21.3	25.3 19.9	26.2 18.4	27.1 17.3	28.0 16.0
		T/I kW G	6.1	6.2	6.3	6.1			6.4	6.5	6.2	6.3	6.4	6.5	6.7	6.8	6.4			6.8	6.9	7.0 2	6.5	6.7	6.8	6.9	7.0 2	7.2 2	6.7	6.8	6.9	7.0 2	7.2
	20.0	SHF	0.70	0.62	0.55	0.82	0.73	0.65	0.58	0.51	0.86	0.78	0.70	0.62	0.54	0.46	08.0	0.72	0.64	0.57	0.50	0.43	0.82	0.75	0.68	0.61	0.54	0.47	0.86	0.78	0.70	0.63	0.56
	2	V SHCKW	14.9	13.7	12.4	3 17.5		7 14.7	13.6	12.5	18.9	7.71	16.4	15.1	13.7	12.1	18.7			14.9	13.4	11.9	1 20.1	18.9	17.7	16.4	15.0	13.5	21.6	20.3	18.8	17.6	16.2
	INDOOR	WB°C Q kW	15 21.3	16 22.0	17 22.7	15 21.3	16 22.0	17 22.7	18 23.5	19 24.4	16 22.0	17 22.7	18 23.5	19 24.4	20 25.2	1 26.1	18 23.5	19 24.4	20 25.2	21 26.1	22 27.0	23 27.9	19 24.4	20 25.2	1 26.1	22 27.0	23 27.9	24 28.8	20 25.2	21 26.1	22 27.0	23 27.9	24 28 8
	INDOOR	DB°C WE		20		_		22			1		24		2	21	•		2 92 - O		2	2		2	28 21	2	2	2	2	2	30 2	2	_

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

PF-8MYC-FU		CMM	09	20	80
PEH-8MYA-EU	AIK VOLUME	S/J	1,000	1,167	1,330
	CAPACITY		926.0	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

(Use for low ambient cooling parts)

PE-8MYC-EU, PEH-8MYA-EU (combined with PUH-8MYC₁-EU)

Heating Capacity (Standard Air Flow) PEH-8MYA-EU (combined with PUH-8MYC1-EU)

			DOTTDO	OUTDOOR WB°C		
INDOOR	-10.0	0.0	-5	-5.0	0.0	0
DB °C	Q KV	T/I kW	Q KW	T/I kW	Q KW	T/I kW
15	14.7	4.8	16.7	5.2	19.1	9.9
16	14.6	4.8	16.7	5.2	19	9.6
17	14.5	4.9	16.6	5.2	19	2.7
18	14.4	4.9	16.5	5.3	18.9	2.7
19	14.2	2.0	16.4	5.3	18.8	2.7
20	14.2	2.0	16.4	5.3	18.8	2.8
21	14.2	2.0	16.3	5.4	18.7	8.3
22	14.1	2.0	16.3	5.4	18.7	6.3
23	14	2.0	16.2	5.4	18.6	5.9
24	14	2.0	16.1	5.5	18.5	0.9
25	14	2.0	16.2	5.5	18.6	0.9
26	13.8	2.0	16	5.2	18.3	0.9
27	13.8	5.1	15.9	5.5	18.2	6.1

Solution Courd C		15.0	Q kW T/I kW	27.8 7.2	27.7 7.3	27.6 7.4	27.6 7.5	27.4 7.6	27.4 7.7	27.3 7.8	27.3 7.8	27.2 7.9	27.1 8.0	27.1 8.1	26.9 8.1	26.8 8.2
5.0 Q kW T/I kW 21.7 6.1 21.7 6.1 21.6 6.2 21.6 6.2 21.4 6.3 21.4 6.3 21.4 6.4 21.2 6.6 21.2 6.6 21.2 6.6 21.2 6.6	OR WB°C	0.1	T/I kW	9.9	7.0	8.9	8.9	6.9	6.9	7.0	7.1	7.2	7.2	7.3	7.4	7.4
21.7 21.7 21.6 21.6 21.6 21.6 21.4 21.4 21.3 21.3 21.3 21.3 21.3 21.3 21.3 21.3	OUTDOC	10	Q kW	24.6	24.6	24.5	24.4	24.3	24.3	24.2	24.2	24.1	24	24	23.8	23.7
21.7 21.7 21.6 21.6 21.6 21.6 21.4 21.4 21.3 21.3 21.3 21.3 21.3 21.3 21.3 21.3		0	T/I kW	6.1	6.1	6.2	6.2	6.3	6.3	6.4	6.4	6.5	9.9	9.9	6.7	6.7
MDOOR JB 'C 15 16 17 17 18 19 20 21 22 22 23 23 24 25 26		5.		21.7	21.7	21.6	21.6	21.4	21.4	21.4	21.3	21.2	21.2	21.2	21	20.8
 		INDOOR	DB °C	15	16	17	18	19	20	21	22	23	24	25	26	27

* Q : HEATING CAPACITY T/I : TOTAL INPUT

Factor for Various Air Flow

1,167

1,000

AIR VOLUME L/S

PEH-8MYA-EU HEATING

PE-8MYC-EU		CMM	09	70	80
EH-8MYA-EU	AIN VOLOIME	S/J	1,000	1,167	1,330
	CAPACITY		926.0	1.0	1.025
OFIING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

	_	-	-		-			_	_	-	-	_	-				F			-	-	-	\rightarrow	-	-	-	\rightarrow	\rightarrow	\rightarrow	-	-	\rightarrow	_	ū
	INDOOR	DB °C	15	16	17	18	19	20	21	22	23	24	22	56	27				INDOOR	DB °C	15	16	17	18	19	20	21	72	23	24	52	56	27	*
		T/I kW	6.3	6.4	6.5	6.3	6.4	6.5	9.9	7.0	6.4	6.5	9.9	7.0	7.0	7.1	9.9	7.0	7.0	7.1	7.2	7.3	7.0	7.0	7.1	7.2	7.3	7.5	7.0	7.1	7.2	7.3	7.5	
		SHF	69.0	0.62	0.54	0.81	0.72	0.63	0.57	0.51	0.85	0.77	69.0	0.62	0.54	0.47	0.79	0.71	0.63	0.56	0.49	0.42	0.81	0.74	0.67	09.0	0.53	0.46	0.84	0.77	69.0	0.62	0.55	
	15.0	SHCkW	13.6	12.6	11.5	15.9	14.8	13.4	12.5	11.6	17.4	16.4	15.1	13.9	12.7	11.4	17.3	16.1	14.8	13.7	12.4	11.0	18.3	17.4	16.3	15.1	13.8	12.4	19.8	18.6	17.4	16.2	14.8	
		KW	9.7	20.5	21.2	9.7	5	21.2	21.8 1	9	2	21.2	21.8 1	9	23.5	24.3	21.8 1	22.6	23.5	24.3	25.1	6	9	23.5	24.3	25.1	25.9	26.8	2	24.3	_	6	26.8 1	
		ŏ Š	0 18	.2 20	.3 21	0 18	2 20.	3 21	.4 21	6 22.	.2 20.	.3 21		.6 22.		.8	.4 21	6 22	.7 23		9 25	0 25.	.6 22.0		8 2	9 25			7 23.	8 24	9 25.) 25.		
		Ξ	9	9	9	9 1	9	9	9	9	9	9	9 6.4	9	8 6.7	9	9	9	9	8.9	9	2 7.0	9	1 6.7	.9	9	3 7.0	3 7.2	1 6.7	9	9	2 7.0	5 7.2	
	10.0	N SHF	0.69	0.6	0.54	0.8	0.72	0.64	0.58	0.51	0.85	0.77	0.69	0.61	0.53	0.46	0.77	0.70	0.63	0.56	0.49	0.42	0.81	0.74	0.67	09.0	0.53	0.46	0.84	0.76	0.69	0.62	0.55	
		SHCKW	13.8	12.8	11.6	16.2	15.1	13.9	12.9	11.8	17.7	16.6	15.4	14.1	12.8	11.3	17.3	16.2	15.2	14.0	12.7	11.2	18.6	17.8	16.7	15.5	14.2	12.7	20.1	18.9	17.7	16.5	15.2	
		Ø Š	20.1	20.9	21.7	20.1	20.9	21.7	22.4	23.1	20.9	21.7	22.4	23.1	24.0	24.8	22.4	23.1	24.0	24.8	25.8	26.6	23.1	24.0	24.8	25.8	26.6	27.5	24.0	24.8	25.8	26.6	27.5	
ပ		T/I kW	6.9	0.9	6.1	6.3	0.9	6.1	6.2	6.3	0.9	6.1	6.2	6.3	6.5	9.9	6.2	6.3	6.5	9.9	6.7	8.9	6.3	6.5	9.9	2.9	8.9	7.0	6.5	9.9	6.7	6.8	7.0	
OOR DB			99.0	0.61	0.53	08.0	0.73	0.65	0.58	0.51	0.84	0.76	0.68	09.0	0.52	0.44	0.75	69.0	0.63	0.56	0.49	0.42	08.0	0.74	0.67	09.0	0.53	0.46	0.83	0.76	99.0	0.62	0.55	<u> </u>
OUTDOOR	5.0	SHCKW	13.9	12.9	11.7	16.3	15.4	14.4	13.3	12.1	17.8	16.8	15.6	14.2	12.8	11.2	17.2	16.3	15.5	14.2	13.0	11.5	18.9	18.0	17.0	15.9	14.5	13.1	20.4	19.2	18.0	16.8	15.6	- VEC
		k	4	21.2	22.0	20.4	21.2	22.0 1	22.9	23.6	21.2	0	6	23.6	24.5	25.3	22.9	23.6	2	25.3	26.3	27.2	23.6	2	25.3	26.3	27.2	28.2	24.5	25.3	26.3	.2	28.2	F
		δ Š	8 20.	9 21		8 20	9 21	0 22			9 21	0 22.) 22.					3 23	.4 24.	5 25	6 26	7 27	3 23	.4 24.	5 25	6 26				5 25	6 26	7 27		È
		Ξ	5.	5.	3 6.0	2.	5.	9	9 6.0	6.3	5.	9	3 6.0	6.3	8 6.4	5.6.5	0.9	9	9	9	9	9	9	9	9	9	3 6.7	6.9	8 6.4	9	9	9	6.9	2
	0.0	/ SHF	0.69	0.61	0.53	0.80	0.72	0.65	0.58	0.51	0.85	0.76	0.68	09:0	0.53	0.45	0.77	0.70	0.63	0.57	0.50	0.43	0.80	0.73	0.67	09:0	0.53	0.47	0.83	0.76	0.68	0.62	0.55	F 4 L
		SHCKW	14.2	13.2	11.9	16.6	15.6	14.5	13.5	12.3	18.3	17.1	15.7	14.4	13.1	11.7	17.8	16.8	15.7	14.6	13.3	11.9	19.2	18.2	17.2	16.0	14.7	13.3	20.5	19.5	18.2	17.0	15.8	
		Ø K§	20.7	21.6	22.5	20.7	21.6	22.5	23.2	24.0	21.6	22.5	23.2	24.0	24.8	25.8	23.2	24.0	24.8	25.8	26.7	27.5	24.0	24.8	25.8	26.7	27.5	28.6	24.8	25.8	26.7	27.5	28.6	1
		T/I kW	5.8	6.3	0.9	8.3	6.3	0.9	6.1	6.2	6.3	0.9	6.1	6.2	6.3	6.4	6.1	6.2	6.3	6.4	6.5	6.7	6.2	6.3	6.4	6.5	6.7	8.9	6.3	6.4	6.5	6.7	8.9	2
		SHF	69.0	0.61	0.53	08.0	0.72	0.64	0.58	0.51	0.85	0.76	0.67	09.0	0.53	0.46	0.78	0.71	0.63	0.57	0.50	0.44	08.0	0.73	99.0	09.0	0.53	0.47	0.82	0.75	0.68	0.62	0.55	Ę
	-5.0	SHCKW	14.4	13.4	12.0	16.7	15.8	14.5	13.5	12.5	18.6	17.2	15.8	14.6	13.4	12.1	18.3	17.2	15.9	14.9	13.6	12.2	19.5	18.4	17.4	16.2	14.8	13.6	20.7	19.7	18.5	17.2	16.0	0
		×ķ	20.9	21.9	22.6	20.9	21.9	22.6	23.5	24.3	21.9 1	22.6	23.5	24.3		26.2	23.5	24.3	25.2	26.2	27.1	27.8	24.3	25.2	26.2	27.1	27.8	29.0	25.2	26.2	27.1	8	29.0	
		Ø	15 20	16 2	17 2:	15 20	16 2	17 2	18 2:	19 2,	16 2	17 2:	18 2;	19 2	20 2	21 20	18 23	19 2,	20 2		22 2.	23 2	19 2	20 2		22 2	23 2.	24 29	20 2	21 20	22 2	23 27.	24 29	,
		DB°C WBC	-	20	1	1	1	22 1	1	1	1	1	24		2	2	1	_	26 2	21	2	2	_		28 21	2	2	2	2	2	30 2	2	2	*
		ᆲ	l	. 4		i		1			ı		. 4						1				i		1				i		(.)		- 1	

Note1.*Q::COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

Cooling Capacity (Standard Air Flow) PE-8MYC-EU, PEH-8MYA-EU (combined with PUH-8MYE-EU)

		T/I kW	8.6	8.7	8.8	8.6	8.7	8.8	8.9	9.0	8.7	8.8	8.9	9.0	9.2	9.3	8.9	9.0	9.2	9.3	9.4	9.6	9.0	9.2	9.3	9.4	9.6	9.7	9.2	9.3	9.4	9.6	9.7
	_	SHF	0.75	99.0	0.57	0.89	0.79	0.70	0.62	0.54	0.94	0.84	0.75	99.0	0.57	0.48	98.0	0.78	0.70	0.61	0.52	0.43	0.91	0.83	0.75	99.0	0.57	0.48	0.93	0.85	0.77	0.71	0.65
	46.0	SHCkW	13.2	12.1	10.8	15.6	14.5	13.2	12.1	10.9	17.2	16.0	14.6	13.3	11.9	10.4	16.8	15.8	14.6	13.3	11.7	10.0	18.4	17.4	16.3	14.8	13.2	11.5	19.4	18.5	17.3	16.4	15.6
	-	Q kW S	17.6	18.3	18.9	17.6	18.3	18.9	19.5	20.2	18.3	18.9	19.5	20.2	20.9	21.7	19.5	20.2	20.9	21.7	22.4	23.1	20.2	20.9	21.7	22.4	23.1	23.9	20.9	21.7	22.4	23.1	23.9
_		T/I KW (6.7	8.0	8.2	7.9	8.0	8.2	8.3	8.4	8.0	8.2	8.3	8.4	9.8	8.7	8.3	8.4	9.8	8.7	8.8	8.9	8.4	9.8	8.7	8.8	6.8	0.6	9.8	8.7	8.8	8.9	0.6
	-	SHF T.	0.74	0.65	0.55	0.88	0.78	0.68	0.61	0.53	0.92	0.83	0.74	0.65	0.56	0.47	0.85	0.77	69.0	09.0	0.52	0.43	0.88	0.80	0.73	0.64	0.56	0.48	0.92	0.83	0.75	0.69	0.63
	40.0	SHCkW	13.5	12.4 (11.0 (16.1	14.9	13.6	12.5 (11.3	17.6	16.4	15.1	13.8	12.3	10.8	17.4	16.3	15.1	13.7 (12.2	10.5	18.8	17.7	16.6	15.2	13.7 (12.1	20.2	19.0	17.7	16.8	15.9 (
	-	kW	18.3	19.1	19.8	18.3	19.1	19.8	20.6	21.3	19.1	19.8	20.6	<i>د</i> ن	22.0	22.8	20.6	21.3	22.0	22.8	23.6	24.3	ω.	22.0	22.8	23.6	24.3		22.0 2	22.8	23.6	24.3	25.2
-		kW	7.4	7.5	7.6	7.4	7.5	7.6	7.7	7.9	7.5	7.6	7.7	7.9 21	8.0 2	8.1 2	7.7	7.9 2	8.0 2	8.1 2	8.2 2	8.4	7.9 21	8.0 2	8.1 2	8.2 2	8.4	8.5	8.0 2	8.1 2	8.2 2	8.4 2	8.5 2
		SHF T/I	0.73	0.63	0.54 7	7 78.		. 79.	. 60	0.52	06.0		0.72	0.64	0.55	0.47	0.83	0.75		0.59	0.51	0.43	0.85	82.0	0.70	0.63	0.55		06:0	0.82	0.73	0.67	0.61
	35.0	SHCKWS	0	9		7 0	.3 0.77	0	0		6	6.7 0.81						2	.3 0.67		2				.0 9.9								\dashv
S		kW SHC	2 14.	9 12.	.6 11.1	.2 16.	9 15.	13.8	3 12.7	0 11.5	9 17.	_	.3 15.3	0 14.0	.8 12.6	7 11.1	3 17.7	.0 16.	8 15.3	7 14.0	4 12.	3 10.9	0 18.	17.7	_	4 15.3	3 14.0	0 12.4	8 20.5	7 19.4	17.9	3 17.0	0 15.9
OUTDOOR DB°C		kW Q k	.9 19.	0 19.	1 20.6	9 19.	.8 19.	1 20.	.3 21.3	4 22.0	0 19.	1 20.6	3 21.3	4 22.0	.5 22.	.6 23.7	3 21.3	4 22.0	5 22.8	6 23.7	7 24.4	9 25.	.4 22.	5 22.	6 23.7	7 24.4	9 25.3		5 22.8	6 23.7	7 24.4	9 25.	.0 26.0
DUT		ĭ	9	3 7.0	5 7.1	9	.9	7 7.1	7	7.4	9 7.0	7.1	1 7.3	3 7.4	7	7	2 7.3	1 7.4	3 7.5	3 7.6	7.7	3 7.9	7	7	7	7.7	5 7.9	3 8.0	9 7.5	7.6	2 7.7	7	80
	30.0	W SHF	0.72	0.63	0.55	0.85	0.76	0.67	0.59	0.52	0.89	0.80	0.71	0.63	0.55	0.46	0.82	0.74	0.66	0.58	0.51	0.43	0.84	72.0	0.69	0.62	0.55	0.48	0.89	0.80	0.72	0.65	0.59
		/ SHCkW	14.3	13.0	11.6	16.9	15.6	14.2	13.1	11.8	18.2	17.0	15.7	14.4	13.0	11.4	18.0	16.9	15.7	14.3	12.9	11.3	19.3	18.2	17.0	15.7	14.4	12.9	21.0	19.6	18.2	17.2	16.1
_		/ Q KW	19.9	20.6	21.3	19.9	20.6	21.3	22.1	22.9	20.6	21.3	22.1	22.9	23.7	24.5	22.1	22.9	23.7	24.5	25.4	26.3	22.9	23.7	24.5	25.4	26.3	27.1	23.7	24.5	25.4	26.3	27.1
		T/I kW	6.5	9.9	6.7	6.5	9.9	6.7	6.8	7.0	9.9	6.7	6.8	7.0	7.1	7.2	6.8	7.0	7.1	7.2	7.3	7.5	7.0	7.1	7.2	7.3	7.5	7.6	7.1	7.2	7.3	7.5	7.6
	25.0	SHF	0.71	0.63	0.55	0.83	0.75	99.0	0.59	0.51	0.87	0.79	0.70	0.62	0.54	0.46	0.80	0.73	0.65	0.58	0.50	0.43	0.83	0.76	0.68	0.61	0.54	0.47	0.87	0.79	0.70	0.64	0.57
	2	SHCkW	14.6	13.4	12.1	17.1	15.9	14.5	13.4	12.1	18.5	17.3	16.0	14.7	13.2	11.7	18.3	17.1	15.9	14.6	13.2	11.6	19.6	18.5	17.3	16.0	14.7	13.2	21.3	19.9	18.4	17.3	16.0
		Q kW	20.6	21.3	22.0	20.6	21.3	22.0	22.8	23.6	21.3	22.0	22.8	23.6	24.4	25.3	22.8	23.6	24.4	25.3	26.2	27.1	23.6	24.4	25.3	26.2	27.1	28.0	24.4	25.3	26.2	27.1	28.0
		T/I kW	6.2	6.3	6.4	6.2	6.3	6.4	6.5	9.9	6.3	6.4	6.5	9.9	8.9	6.9	6.5	9.9	8.9	6.9	7.0	7.1	9.9	8.9	6.9	7.0	7.1	7.3	8.9	6.9	7.0	7.1	7.3
	0.	SHF	0.70	0.62	0.55	0.82	0.73	0.65	0.58	0.51	0.86	0.78	0.70	0.62	0.54	0.46	0.80	0.72	0.64	0.57	0.50	0.43	0.82	0.75	0.68	0.61	0.54	0.47	0.86	0.78	0.70	0.63	0.56
	20.0	SHCkW	14.9	13.7	12.4	17.5	16.1	14.7	13.6	12.5	18.9	17.7	16.4	15.1	13.7	12.1	18.7	17.6	16.2	14.9	13.4	11.9	20.1	18.9	17.7	16.4	15.0	13.5	21.6	20.3	18.8	17.6	16.2
		Q kW	21.3	22.0	22.7	21.3	22.0	22.7	23.5	24.4	22.0	22.7	23.5	24.4	25.2	26.1	23.5	24.4	25.2	26.1	27.0	27.9	24.4	25.2	26.1	27.0	27.9	28.8	25.2	26.1	27.0	27.9	28.8
<u> </u>	NDOOR	WB °C	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	23	24
	NDOOR	DB°C 1		20				22					24						56	<u> </u>					28		<u> </u>	<u> </u>			30		

Note1.* Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

PE-8MYC-FU		CMM	09	70	08
PEH-8MYA-EU	AIR VOLUME	S/I	1,000	1,167	1,330
	CAPACITY		0.976	1.0	1.025
000	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

(Use for low ambient cooling parts)

PE-8MYC-EU, PEH-8MYA-EU (combined with PUH-8ME-EU)

(combined with PUH-8MYE-EU) ī . į Heating

_	
Fl0 ∭	
¥	
daro	₽
(Star	<u> </u> ¥
acity	≱ 8-H
Caba	PE
ත	

Q KW T/1 KW Q KW T/1 KW Q KW T/1 KW
T/I KW Q KW T/I KW
T/I KW Q KW
T/I kW
DB°C

	0.	T/I kW	7.3	7.4	7.5	9.7	7.7	7.8	7.9	7.9	8.0	8.1	8.2	8.2	8.3
	15.0	Q KW	27.8	27.7	27.6	27.6	27.4	27.4	27.3	27.3	27.2	27.1	27.1	26.9	26.8
R WB°C	0.	T/I kW	6.7	7.1	6.9	6.9	7.0	7.0	7.1	7.2	7.3	7.3	7.4	7.5	7.5
OUTDOOR WB°C	10.0	Q KW	24.6	24.6	24.5	24.4	24.3	24.3	24.2	24.2	24.1	24	24	23.8	23.7
)	T/I kW	6.2	6.2	6.3	6.3	6.4	6.4	6.5	6.5	6.6	6.7	6.7	6.8	6.8
	5.0	Q KW	21.7	21.7	21.6	21.6	21.4	21.4	21.4	21.3	21.2	21.2	21.2	21	20.8
	INDOOR	DB°C	15	16	17	18	19	20	21	22	23	24	25	56	27

^{*} Q : HEATING CAPACITY T/I : TOTAL INPUT

Factor for Various Air Flow

) - -	:	
PF-8MYC-FU		CMM	09	20	80
PEH-8MYA-EU	AIR VOLUME	NS	1,000	1,167	1,330
	CAPACITY		926.0	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

	10.0	SHCKW SHF T/I KW Q KW SHCKW SHF T/I KW	13.8 0.69 6.1 19.7 13.6 0.69 6.4	12.8 0.61 6.3 20.5 12.6 0.62 6.5	11.6 0.54 6.4 21.2 11.5 0.54 6.6	16.2 0.81 6.1 19.7 15.9 0.81 6.4	15.1 0.72 6.3 20.5 14.8 0.72 6.5	13.9 0.64 6.4 21.2 13.4 0.63 6.6	12.9 0.58 6.5 21.8 12.5 0.57 6.7	11.8 0.51 6.7 22.6 11.6 0.51 7.1	17.7 0.85 6.3 20.5 17.4 0.85 6.5	16.6 0.77 6.4 21.2 16.4 0.77 6.6	15.4 0.69 6.5 21.8 15.1 0.69 6.7	14.1 0.61 6.7 22.6 13.9 0.62 7.1	12.8 0.53 6.8 23.5 12.7 0.54 7.1	11.3 0.46 6.9 24.3 11.4 0.47 7.2	17.3 0.77 6.5 21.8 17.3 0.79 6.7	16.2 0.70 6.7 22.6 16.1 0.71 7.1	15.2 0.63 6.8 23.5 14.8 0.63 7.1	14.0 0.56 6.9 24.3 13.7 0.56 7.2	12.7 0.49 7.0 25.1 12.4 0.49 7.3	11.2 0.42 7.1 25.9 11.0 0.42 7.4	18.6 0.81 6.7 22.6 18.3 0.81 7.1	17.8 0.74 6.8 23.5 17.4 0.74 7.1	16.7 0.67 6.9 24.3 16.3 0.67 7.2	15.5 0.60 7.0 25.1 15.1 0.60 7.3	14.2 0.53 7.1 25.9 13.8 0.53 7.4	12.7 0.46 7.3 26.8 12.4 0.46 7.6	20.1 0.84 6.8 23.5 19.8 0.84 7.1	18.9 0.76 6.9 24.3 18.6 0.77 7.2		17.7 0.69 7.0 25.1 17.4 0.69 7.3
		Q KW SH	20.1	20.9	21.7	20.1	20.9	21.7 1	22.4	23.1	20.9	21.7	22.4	23.1	24.0 13	24.8	22.4 1	23.1	24.0 1	24.8 1	25.8 13	26.6	23.1	24.0 1	24.8	25.8 1	26.6	27.5	24.0 2	24.8 1	25.8 1	
၁့		T/I kW	0.9	6.1	6.2	0.9	6.1	6.2	6.3	6.4	6.1	6.2	6.3	6.4	9.9	6.7	6.3	6.4	9.9	6.7	8.9	6.9	6.4	9.9	6.7	8.9	6.9	7.1	9.9	6.7	8.9	
OUTDOOR DB°C	0	∦S	99.0	0.61	0.53	0.80	0.73	0.65	0.58	0.51	0.84	92.0	0.68	09.0	0.52	0.44	0.75	69.0	0.63	0.56	0.49	0.42	0.80	0.74	0.67	09:0	0.53	0.46	0.83	92.0	0.68	
OUT	5.0	SHCKW	13.9	12.9	11.7	16.3	15.4	14.4	13.3	12.1	17.8	16.8	15.6	14.2	12.8	11.2	17.2	16.3	15.5	14.2	13.0	11.5	18.9	18.0	17.0	15.9	14.5	13.1	20.4	19.2	18.0	
		Q KW	20.4	21.2	22.0	20.4	21.2	22.0	22.9	23.6	21.2	22.0	22.9	23.6	24.5	25.3	22.9	23.6	24.5	25.3	26.3	27.2	23.6	24.5	25.3	26.3	27.2	28.2	24.5	25.3	26.3	
		T/I kW	5.9	0.9	6.1	5.9	0.9	6.1	6.1	6.4	0.9	6.1	6.1	6.4	6.5	9.9	6.1	6.4	6.5	9.9	6.7	8.9	6.4	6.5	9.9	6.7	8.9	7.0	6.5	9.9	6.7	
	0	SHF	69.0	0.61	0.53	0.80	0.72	0.65	0.58	0.51	0.85	0.76	0.68	09.0	0.53	0.45	0.77	0.70	0.63	0.57	0.50	0.43	0.80	0.73	0.67	09.0	0.53	0.47	0.83	0.76	0.68	9
	0.	SHCKW	14.2	13.2	11.9	16.6	15.6	14.5	13.5	12.3	18.3	17.1	15.7	14.4	13.1	11.7	17.8	16.8	15.7	14.6	13.3	11.9	19.2	18.2	17.2	16.0	14.7	13.3	20.5	19.5	18.2	
		Q KW	20.7	21.6	22.5	20.7	21.6	22.5	23.2	24.0	21.6	22.5	23.2	24.0	24.8	25.8	23.2	24.0	24.8	25.8	26.7	27.5	24.0	24.8	25.8	26.7	27.5	28.6	24.8	25.8	26.7	
		T/I KW	5.9	0.9	6.1	5.9	0.9	6.1	6.2	6.3	0.9	6.1	6.2	6.3	6.4	6.5	6.2	6.3	6.4	6.5	9.9	8.9	6.3	6.4	6.5	9.9	8.9	6.9	6.4	6.5	9.9	
	0	SHF	69.0	0.61	0.53	0.80	0.72	0.64	0.58	0.51	0.85	92.0	0.67	0.60	0.53	0.46	0.78	0.71	0.63	0.57	0.50	0.44	0.80	0.73	99.0	09.0	0.53	0.47	0.82	0.75	0.68	
	-5.0	SHCKW	14.4	13.4	12.0	16.7	15.8	14.5	13.5	12.5	18.6	17.2	15.8	14.6	13.4	12.1	18.3	17.2	15.9	14.9	13.6	12.2	19.5	18.4	17.4	16.2	14.8	13.6	20.7	19.7	18.5	
		Q KW	20.9	21.9	22.6	20.9	21.9	22.6	23.5	24.3	21.9	22.6	23.5	24.3	25.2	26.2	23.5	24.3	25.2	26.2	27.1	27.8	24.3	25.2	26.2	27.1	27.8	29.0		26.2	27.1	
5	ž	WBC	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	
	1	DB°C		50				22					24						56						78						30	

Factor for Various Air Flow

1,330 1.011 70 1.0 60 1,000 0.989 1.010 AIR VOLUME L/S CAPACITY TOTAL INPUT PEH-8MYA-EU HEATING

Cooling Capacity (Standard Air Flow)
PE-10MYC-EU, PEH-10MYA-EU (combined with PUH-10MYC₁-EU)

44 34												Q	OUTDOOR DB°C	DB°C											
O. M. Shell, Shel		DOOR	20.0				25.0				30.0				35.0				40.0				46.0		
27.6 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 2.0 1.0 2.0 1.0 2.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 2.0 2.0 2.0		-	4CKW		∐ kW		SHCKW		T/I KW	κW	\dashv	\neg	kW	ΚW	знски		T/I KW	ΚW	HCKW		ΚW	ΚW		_	Κ
28.9 18.2 28.9 18.2 18.2 28.9 18.2 18.2 28.9 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2 18.2			19.6	0.71	8.1	27.0	19.2	0.71		26.1	7	0.72	9.1	25.1	18.1	0.72	9.7			0.74	10.5	2			1.3
300 67 68 68 68 28 28 28 28 28 28 28 28 28 28 28 28 <t< td=""><td></td><td></td><td>18.2</td><td>0.63</td><td>8.2</td><td>28.1</td><td>17.9</td><td>0.64</td><td>9.8</td><td>27.1</td><td>κį</td><td>0.64</td><td></td><td>26.0</td><td>16.7</td><td>0.64</td><td>9.8</td><td>24.7</td><td>1.91</td><td>0.65</td><td>10.6</td><td>8</td><td>4</td><td></td><td>4.1</td></t<>			18.2	0.63	8.2	28.1	17.9	0.64	9.8	27.1	κį	0.64		26.0	16.7	0.64	9.8	24.7	1.91	0.65	10.6	8	4		4.1
27.8 2.5. 0.81 8.1 2.0. 9.0. 8.1 2.0. 9.0. 8.1 2.0. 9.0. 8.1 2.0. 9.0. 8.1 2.0. 9.0.		-	16.7	0.56	8.3	29.1	16.3	0.56	8.7	28.1	ω,	0.56		26.9	15.1	95.0		25.6		0.57	10.7	_	8	.57	1.5
28.9 21.3 0.74 8.2 28.4 21.0 0.75 8.6 27.1 0.05 8.9 27.1 0.05 8.9 27.1 0.05 8.0 27.2 0.05 18.0 0.05 8.0 20.0 1.0 20.0 1.0 0.0 20.0 1.0 0.0 2.0 1.0 0.0 2.0 1.0 0.0 2.0 1.0 0.0 2.0 0.0 2.0 1.0 0.0 2.0 0.0	1		22.5	0.81	8.1	27.0	22.2	0.82		26.1	8.	0.84	9.1	25.1	21.4	0.85	9.7	23.9	20.9	0.87	10.5	2			1.3
300 188 0.66 8.3 20.1 1.95 0.67 8.1 1.90 0.68 9.2 1.65 0.16 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 0.05 1.05 1.05 0.05 1.05 0.05 1.05 1.05 0.05 0.05 1.05 0.05 1.05 0.05 0.05 1.05 0.05 0.05 0.05 1.05 0.05			21.3	0.74	8.2	28.1	21.0	0.75		27.1		92.0	9.2	26.0	19.9	0.77	8.6	24.7	19.4	0.78	10.6	3			4.
311 183 0.59 88 201 17.5 0.09 93 27.9 16.9 0.69 10.9 0.89 0.7 0.7 0.7 0.89 0.89 0.2 0.2 0.89 0.99 0.89 0.99 0.89 0.89 0.99 0.89 0.99 0.89 0.89 0.99 0.89 0.99 0.99 0.89 0.99 0.99 0.99			19.8	99.0	8.3	29.1	19.5	0.67	8.7	28.1		99.0		26.9	18.3	99.0	6.6	25.6	17.8	0.70	10.7	-			1.5
31. 6.0 <td></td> <td></td> <td></td> <td>0.59</td> <td>8.3</td> <td>30.2</td> <td>18.0</td> <td>0.59</td> <td></td> <td>29.1</td> <td>2</td> <td>09.0</td> <td></td> <td>27.9</td> <td>16.9</td> <td>0.61</td> <td>10.0</td> <td>26.5</td> <td>16.3</td> <td>0.62</td> <td>10.8</td> <td>6</td> <td></td> <td></td> <td>9.1</td>				0.59	8.3	30.2	18.0	0.59		29.1	2	09.0		27.9	16.9	0.61	10.0	26.5	16.3	0.62	10.8	6			9.1
32.6 32.7 32.6 32.7 <th< td=""><td>L</td><td></td><td>16.5</td><td>0.51</td><td>8.4</td><td>31.2</td><td>16.2</td><td>0.52</td><td></td><td>30.1</td><td>8</td><td>0.52</td><td>9.4</td><td>28.8</td><td>15.3</td><td>0.53</td><td>10.1</td><td></td><td>14.6</td><td>0.54</td><td>10.9</td><td></td><td></td><td></td><td>1.7</td></th<>	L		16.5	0.51	8.4	31.2	16.2	0.52		30.1	8	0.52	9.4	28.8	15.3	0.53	10.1		14.6	0.54	10.9				1.7
300 310 612 <td></td> <td></td> <td>24.6</td> <td>0.85</td> <td>8.2</td> <td>28.1</td> <td>24.2</td> <td>98.0</td> <td></td> <td>27.1</td> <td>7</td> <td>0.88</td> <td></td> <td>26.0</td> <td>23.2</td> <td>0.89</td> <td>9.8</td> <td>24.7</td> <td></td> <td>0.92</td> <td>10.6</td> <td></td> <td></td> <td>94</td> <td>1.4</td>			24.6	0.85	8.2	28.1	24.2	98.0		27.1	7	0.88		26.0	23.2	0.89	9.8	24.7		0.92	10.6			94	1.4
31.1 31.2 0.68 0.83 0.84 <th< td=""><td></td><td></td><td>23.0</td><td>0.77</td><td>8.3</td><td>29.1</td><td>22.6</td><td>0.78</td><td>8.7</td><td>28.1</td><td>1</td><td>0.79</td><td></td><td>26.9</td><td>21.6</td><td>0.80</td><td>6.6</td><td>25.6</td><td>21.1</td><td>0.82</td><td>10.7</td><td>1</td><td></td><td></td><td>1.5</td></th<>			23.0	0.77	8.3	29.1	22.6	0.78	8.7	28.1	1	0.79		26.9	21.6	0.80	6.6	25.6	21.1	0.82	10.7	1			1.5
32.1 19.6 6.64 8.4 31.2 19.2 0.61 8.9 30.1 18.7 0.62 9.4 28.6 10.2 10.4 10.6 10			21.3	89.0	8.3	30.2	20.8	69.0		29.1	4	0.70		27.9	19.8	0.71	10.0	26.5	19.4	0.73	10.8	6	2		1.6
346 186 6.54 8.6 3.86 18.1 6.54 9.0 22.4 17.6 0.54 17.0 0.55 10.2 23.4 16.5 0.56 11.0 27.6 27.7 27.2 27.			19.6	0.61	8.4	31.2	19.2	0.61		30.1		0.62		28.8	18.2	0.63	10.1	27.3	17.6	0.65	10.9				1.7
346 161 0.47 86 310 146 0.47 161 0.47 0.49 140 0.49 140 0.49 140 0.47 161 0.47 0.49 140 0.47 161 0.47 0.49 100 0.45 160 0.40 0.81 0.40 0.81 0.41 0.41 0.40 0.40 0.81 0.41 0.41 0.40 0.40 0.81 0.41 0.41 0.40 0.40 0.81 0.41 0.41 0.41 0.40 0.40 0.81 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42 0.42			18.6	0.54	8.5	33.6	18.1	0.54	9.0	32.4		0.54		31.0	17.0	0.55	10.2	29.4	16.5	0.56	11.0	9		22	1.8
31.1 24.2 0.04 8.9 3.04 0.04 0.04 0.04 0.04 0.04 0.06 0.04			16.1	0.47	9.8	33.6	15.6	0.46	9.1	32.4		0.47		31.0	14.6	0.47	10.3	29.4	14.0	0.48	11.1				2.0
32.1 2.6 0.70 8.4 31.2 2.2.3 0.71 8.9 30.1 21.8 0.72 9.4 10.1 27.3 0.70 0.70 8.4 31.2 22.3 0.71 8.9 30.1 21.8 0.64 9.0 32.4 20.4 9.0 0.64 9.0 31.0 0.04 9.0 32.4 20.4 10.0 0.67 11.0 27.6 19.0 0.05 34.6 19.6 0.57 8.4 33.6 19.3 0.57 9.4 10.0 0.67 11.0 27.6 19.0 0.69 35.8 18.0 0.57 8.4 18.2 0.54 18.1 15.0 10.4 19.2 3.2 17.2 0.61 3.2 17.0 0.62 18.0 3.0 18.0 3.0 18.0 3.0 18.0 3.0 18.0 3.0 3.0 18.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0			24.2	0.78	8.3	30.2	23.9	0.79	8.8	29.1	4	0.81	9.3	27.9	22.9	0.82	10.0	26.5	22.4	0.85	10.8	6			1.6
346 1.18 0.63 8.5 3.36 21.5 0.64 9.0 32.4 20.9 31.0 20.1 0.65 10.2 29.4 19.7 0.67 11.0 27.6 19.1 0.60 34.6 19.6 0.57 19.1 32.4 18.8 0.56 31.0 10.2 10.4 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7 10.6 10.7<				0.70	8.4	31.2	22.3	0.71		30.1	8.	0.72	9.4	28.8	21.2	0.74	10.1	27.3	20.7	0.76	10.9				1.7
34.6 13.6 0.57 9.4 18.8 0.58 9.6 31.0 18.1 0.58 17.0 0.51 17.0 0.50 9.6 31.0 18.1 0.50 17.0 0.51 18.0 0.50 18.0 0.50 18.0 0.50 18.0 0.50 18.0 0.50 8.7 17.7 0.51 9.2 33.0 16.0 0.50 18.0				0.63	8.5	33.6	21.5	0.64	9.0	32.4	6	0.64		31.0	20.1	0.65	10.2	29.4	19.7	0.67	11.0				1.8
35.8 18.0 0.50 8.7 3.4.7 17.7 0.51 9.2 32.0 16.0 0.50 10.4 9.0 10.0 9.0			19.6	0.57	8.4	33.6	19.3	0.57	9.1	32.4	8	0.58		31.0	18.1	0.58	10.3	29.4	17.6	09.0	11.1				2.0
35.9 16.3 0.44 8.8 35.9 15.9 0.45 0.46 0.45 0.45 0.46 0.45 0.46 0.45 0.45 0.46 0.45 0.46 0.45 0.46 0.47 0.46 0.46 0.47 0.47 0.46 0.46 0.46 0.47 0.46 0.46 0.47 0.46 0.46 0.47 0.46 0.46 0.47 0.46 0.47	1		18.0	0.50	8.7	34.7	17.7	0.51	9.5	33.5	7	0.51		32.0	16.6	0.52	10.4	30.4	16.1	0.53		9	2		2.1
32.1 6.6 0.81 8.4 31.2 6.6 0.82 8.8 30.1 25.8 9.8 30.1 25.8 9.8 30.1 24.8 0.86 10.1 27.3 24.2 0.89 10.1 27.3 28.4 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.79<			16.3	0.44	8.8	35.9	15.9	0.44	9.3	34.6	5	0.45		33.1	15.0	0.45	10.6	31.4	14.4	0.46		2	7		2.2
34.6 25.4 0.73 8.5 3.6 0.74 9.0 32.4 24.7 0.76 9.0 9.0 32.4 24.7 0.76 9.0 0.74 0.76 9.0 32.0 0.76 9.0 31.0 24.7 0.70 10.3 29.4 23.6 0.76 9.1 32.4 22.2 0.68 9.6 31.0 10.0 10.2 10.0 10.0 10.0 20.2 0.68 9.6 31.0 10.1 0.74 10.1 20.2 0.68 9.6 31.0 20.7 0.70 10.2 20.7 0.70 0.70 10.2 20.7 0.62 9.8 32.0 20.7 0.69 9.2 32.0 0.60 9.2 10.0 0.62 9.8 32.0 0.60 9.2 10.2 0.62 9.8 32.0 0.60 9.2 10.2 0.62 9.8 32.0 10.0 9.2 10.0 10.2 10.2 10.4 10.2 10.2 10.2 <t< td=""><td></td><td></td><td>26.0</td><td>0.81</td><td>8.4</td><td>31.2</td><td>25.6</td><td>0.82</td><td>8.9</td><td>30.1</td><td>3</td><td>0.84</td><td></td><td>28.8</td><td>24.8</td><td>98.0</td><td>10.1</td><td>27.3</td><td>24.2</td><td>0.89</td><td>10.9</td><td></td><td>4</td><td>16</td><td>1.7</td></t<>			26.0	0.81	8.4	31.2	25.6	0.82	8.9	30.1	3	0.84		28.8	24.8	98.0	10.1	27.3	24.2	0.89	10.9		4	16	1.7
34.6 22.8 0.66 8.6 3.6 22.7 0.68 31.0 21.7 0.70 10.3 29.4 21.2 0.72 11.1 27.6 20.4 0.74 35.8 21.3 0.60 8.7 34.6 19.0 0.62 9.8 32.0 20.7 0.62 9.8 32.0 20.1 0.63 10.4 10.7 20.2 11.1 27.0 0.60 9.2 33.5 20.7 0.62 9.8 32.0 20.4 10.5 10.4 10.5 10.6 10.6 10.6 10.6 10.6 10.6 10.6 10.6 10.6 10.6 10.7 10.4 10.7 10.4 10.7 20.4 10.7 20.5 10.7 20.5 10.7 20.5 10.7			25.4	0.73	8.5	33.6	25.0	0.74	9.0	32.4		92.0		31.0	24.2	0.78	10.2	29.4	23.6	0.80	11.0			83	8.
35.8 21.3 0.60 8.7 3.6.4 9.2 3.6.4 10.6 9.2 3.6.7 0.62 9.8 32.0 20.1 0.63 10.4 10.6 10.4 10.6			22.8	99.0	8.6	33.6	22.5	0.67	9.1	32.4	2	0.68	9.6	31.0	21.7	0.70	10.3	29.4	21.2	0.72	11.1				2.0
36.9 19.7 0.53 8.8 35.9 19.3 0.55 9.9 33.1 18.5 0.56 10.6 11.2 0.56 9.9 33.1 18.5 0.56 10.6 11.6 11.7 11.4 29.5 17.1 0.48 10.0 32.2 16.7 16.7 10.9 17.5 14.6 10.2 20.4 10.7 22.5 16.1 10.4 17.5 17.2 17.2 0.48 10.0 26.3 10.7 20.4 10.7 20.4 10.7 20.4 10.7 20.4 10.7 20.4 10.7 20.4 20.7 10.4 20.3 20.4 20.5 10.7 20.4 20.7 20.8 31.0 20.3 20.7 20.8 31.0 20.3 0.7 20.3 0.7 20.3 0.7 20.3 0.7 20.3 0.7 20.3 0.7 20.3 0.7 20.3 20.3 0.7 20.3 0.7 20.3 20.3 0.7 20.3	1			09.0	8.7	34.7	20.9	09.0	9.2	33.5		0.62	9.8	32.0	20.1	0.63	10.4	30.4	19.6	0.64		9			2.1
38.0 17.9 0.47 9.4 35.7 17.2 0.48 10.0 34.2 16.7 0.49 10.7 32.5 16.1 0.49 11.5 0.49 11.5 30.5 15.2 0.48 10.0 34.2 16.7 0.49 10.7 32.5 16.1 0.49 10.7 10.4 10.7 26.3 10.2 29.4 10.2 29.4 20.7 20.4 20.7 31.0 20.3 31.0 20.3 0.78 10.2 20.4 20.4 20.7 20.8 10.7 20.8 10.2 20.4 20.7 20.8 20.7 20.8 20.7 20.8 20.7 20.8 20.7 20.8 20.7 20.8 20.7 20.8 20.7 20.9 20.7 20.9 20.7 20.9 20.7 20.9 20.7 20.9 20.7 20.9 20.7 20.9 20.9 20.9 20.7 20.8 20.9 20.9 20.9 20.9 20.9 20.9				0.53	8.8	35.9	19.3	0.54	9.3	34.6		0.55	6.6	33.1	18.5	0.56	10.6	31.4	17.9	0.57	11.4	2			2.3
34.6 28.0 0.81 8.5 3.5 0.82 0.82 0.85 0.77 0.86 0.72 0.86 0.72 0.76 0.85 0.72 0.75 0.75 0.75 0.75 0.75 0.75 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.75 0.76 0.76 0.76 0.76 0.76 0.76 0.76 0.76 0				0.47	8.9	36.9	17.5	0.47	9.4	35.7	2		10.0	34.2	16.7	0.49	10.7	32.5	16.1	0.49	11.5	5	2		2.4
34.6 25.8 0.75 8.6 35.6 25.3 0.75 9.1 32.4 24.3 0.77 9.6 31.0 24.3 0.78 10.4 32.0 10.0 10.4 10.4 32			28.0	0.81	8.5	33.6	27.5	0.82	9.0	32.4	0.	0.83		31.0	26.3	0.85	10.2		26.0	0.89	11.0	9	4		1.8
35.8 24.5 0.68 8.7 34.6 25.6 0.70 9.8 32.0 0.30 0.70 0			25.8	0.75	9.8	33.6	25.3	0.75	9.1	32.4	6	0.77		31.0	24.3	0.78	10.3	29.4		0.81	11.1	9.	2		2.0
36.9 23.0 0.62 8.5 8.5 22.6 0.63 9.3 34.6 22.2 0.64 9.9 33.1 21.6 0.65 8.9 36.9 11.7 0.57 8.4 35.7 20.6 0.58 10.0 34.2 20.1 0.59 10.7 32.5 10.5 10.5 10.5 10.5 10.5 10.5 10.5 10			24.5	99.0	8.7	34.7	23.9	69.0		33.5	9	0.70			23.0	0.72	10.4	30.4		0.74	11.2	9			2.1
38.0 21.4 0.56 8.9 36.9 21.0 0.57 9.4 35.7 20.6 0.58 10.0 34.2 20.1 0.59 10.7 32.5 19.5 0.60 11.5 30.5 18.6 0.61	. 1		23.0	0.62	8.5	35.9	22.6	0.63	9.3	34.6	2	0.64		33.1	21.6	0.65	10.6	31.4	21.0	0.67		2	2		2.3
		Н	21.4	0.56	8.9	36.9	21.0	0.57	9.4	35.7		28	10.0	34.2	20.1	0.59	10.7	32.5	19.5	09.0	11.5	5	9	.61	2.4

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

PE-10MYC-EII	()	CMM	80	90	100
PEH-10MYA-EU	AIK VOLUME	S/T	1,330	1,550	1,660
	CAPACITY		0.977	1.0	1.035
COOLING	TOTAL INPUT		0.991	1.0	1.005
	SHC		0.968	1.0	1.037

(Use for low ambient cooling parts)

PE-10MYC-EU, PEH-10MYA-EU (combined with PUH-10MYC₁-EU)

(combined with PUH-10MYC1-EU)

OUTDOOR WB°C

Heating Capacity (Standard Air Flow) PEH-10MYA-EU

24.8 6.9

21.4 6.3

18.4 5.8 18.3 5.8

Q kw | T/I kw | Q kw | T/I kw

-10.0

24.5

205.8 6.3 6.3

24.6 24.5

21.3

5.8

18.2

24.4 24.3

6.4

21.2

5.9

18.2

18.1 5.9 21.1 6.4

21.0 6.5 20.9 6.5

18.0 5.9 17.9 5.9

24.3

24.2

6.5 9.9

20.8

0.9

17.8 17.7

24.1

20.7

0.9

24.0 23.9

20.6 6.6

17.6 6.0

6.7 6.7 6.8

20.5

17.5 6.0

23.7 23.6

20.4

17.4 6.1

20.3

6.1

17.3

		DB.	15	16	17	18	19	20	21	22	23	24	25	26	27					DB.(12	16	17	18	19	70	21	53	23	24	52	56	27
		T/I kW	9.2	9.3	9.3	9.2	9.3	9.3	9.4	9.6	9.3	9.3	9.4	9.6	9.7	8.6	9.4	9.6	9.7	9.8	6.6	10.0	9.6	9.7	9.8	6.6	10.0	10.0	9.7	9.8	6.6	10.0	10.0
	0.	SHF	0.70	0.63	0.55	08.0	0.73	0.65	0.58	0.51	0.84	92.0	99.0	0.61	0.54	0.47	0.77	69.0	0.62	0.56	0.50	0.44	08.0	0.72	0.65	0.59	0.53	0.47	08.0	0.74	0.68	0.62	0.56
	15.	SHCKW	18.2	16.8	15.4	20.8	19.5	18.2	16.8	15.2	22.6	21.2	19.7	18.2	17.3	15.1	22.3	20.8	19.9	18.0	16.6	15.0	23.9	23.3	20.9	19.6	18.1	16.5	25.7	23.8	22.6	21.2	19.7
		S K W	25.9	26.9	27.9	25.9	26.9	27.9	28.9	29.9	26.9	27.9	28.9	29.9	32.2	32.2	28.9	29.9	32.2	32.2	33.3	34.3	29.9	32.2	32.2	33.3	34.3	35.3	32.2	32.2	33.3	34.3	35.3
		T/I kW	9.8	8.7	8.8	9.8	8.7	8.8	8.9	9.0	8.7	8.8	8.9	9.0	9.1	9.1	8.9	9.0	9.1	9.1	9.2	9.3	9.0	9.1	9.1	9.2	9.3	9.2	9.1	9.1	9.2	9.3	9.2
	0.0	SHF	0.70	0.62	0.54	08'0	0.72	0.65	85.0	0.51	0.83	0.75	29.0	09.0	0.53	0.46	92.0	69.0	0.62	95.0	0.50	0.44	0.79	0.72	0.65	0.59	0.53	0.47	62'0	0.73	0.67	0.61	0.55
	10.	SHCKW	18.6	17.2	15.6	21.2	20.0	18.6	17.2	15.7	23.1	21.7	20.0	18.6	17.7	15.3	22.7	21.3	20.5	18.5	17.0	15.5	24.5	23.9	21.5	20.1	18.6	17.0	26.3	24.3	23.0	21.6	20.0
		Q KW	26.7	27.7	28.7	26.7	27.7	28.7	29.7	30.8	27.7	28.7	29.7	30.8	33.1	33.1	29.7	30.8	33.1	33.1	34.2	35.3	30.8	33.1	33.1	34.2	35.3	36.2	33.1	33.1	34.2	35.3	36.2
B°C		T/I kW	8.1	8.3	8.4	8.1	8.3	8.4	8.5	9.8	8.3	8.4	8.5	9.8	9.8	8.7	8.5	9.8	9.8	8.7	8.8	8.9	9.8	9.8	8.7	8.8	8.9	9.0	9.8	8.7	8.8	8.9	0.6
OUTDOOR DB°C	5.0	봀	0.69	0.61	0.54	0.79	0.72	0.65	0.58	0.51	0.83	0.75	0.67	09.0	0.53	0.46	0.76	0.69	0.62	0.56	0.50	0.44	0.79	0.72	0.65	0.59	0.53	0.47	0.79	0.73	0.67	0.61	0.55
OUT	5	SHCKW	18.9	17.4	15.9	21.6	20.4	19.1	17.6	16.0	23.5	22.0	20.4	18.9	17.9	15.5	23.1	21.7	20.9	18.9	17.4	15.8	24.9	24.3	21.9	20.6	19.0	17.3	26.7	24.7	23.4	21.9	20.2
		Q KW	27.3	28.4	29.4	27.3	28.4	29.4	30.4	31.5	28.4	29.4	30.4	31.5	33.9	33.9	30.4	31.5	33.9	33.9	35.0	36.1	31.5	33.9	33.9	35.0	36.1	36.9	33.9	33.9	35.0	36.1	36.9
		T/I kW	7.8	8.0	8.1	7.8	8.0	8.1	8.2	8.2	8.0	8.1	8.2	8.2	8.3	8.4	8.2	8.2	8.3	8.4	8.5	8.6	8.2	8.3	8.4	8.5	8.6	8.6	8.3	8.4	8.5	8.6	8.6
	0.0	¥S	0.69	0.61	0.54	0.79	0.72	0.64	0.58	0.51	0.82	0.75	0.67	09.0	0.53	0.46	0.76	0.69	0.62	0.56	0.50	0.44	0.79	0.72	0.64	0.59	0.53	0.47	0.79	0.73	0.67	0.61	0.55
)	SHCkW	19.2	17.7	16.1	22.0	20.7	19.3	17.8	16.4	23.8	22.3	20.7	19.2	18.2	15.8	23.5	22.1	21.3	19.2	17.7	16.0	25.4	24.6	22.1	20.9	19.3	17.6	27.1	25.1	23.8	22.2	20.5
		Q KW	27.8	28.9	29.9	27.8	28.9	29.9	30.9	32.1	28.9	29.9	30.9	32.1	34.4	34.4	30.9	32.1	34.4	34.4	35.6	36.6	32.1	34.4	34.4	35.6	36.6	37.5	34.4	34.4	35.6	36.6	37.5
		T/I KW	7.5	7.7	7.8	7.5	7.7	7.8	7.9	7.9	7.7	7.8	7.9	7.9	8.0	8.1	7.9	7.9	8.0	8.1	8.2	8.2	7.9	8.0	8.1	8.2	8.2	8.3	8.0	8.1	8.2	8.2	8.3
	-5.0	/ SHF	0.69	0.61	0.54	0.79	0.71	0.64	0.57	0.51	0.82	0.74	0.67	09.0	0.53	0.46	0.76	0.69	0.62	0.56	0.50	0.44	0.79	0.71	0.64	0.58	0.53	0.47	0.79	0.73	0.67	0.61	0.55
	7	SHCKW	19.5	18.0	16.3	22.3	20.9	19.4	17.9	16.6	24.0	22.6	20.9	19.5	18.4	16.0	23.7	22.4	21.6	19.5	17.9	16.2	25.7	24.9	22.2	21.0	19.5	17.9	27.5	25.4	24.0	22.5	20.7
		Q KW	28.2	29.3	30.3	28.2	29.3	30.3	31.3	32.6	29.3	30.3	31.3	32.6	34.9	34.9	31.3	32.6	34.9	34.9	36.0	37.0	32.6	34.9	34.9	36.0	37.0	37.8	34.9	34.9	36.0	37.0	37.8
	200	C WB°C	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21		23	24
	Ž	DB°C		20				22					24						26						28						30		

Q KW | T/I KW | Q KW | T/I KW | Q KW | T/I KW 37.2 9.5 35.4 10.8 37.3 9.6 36.6 10.2 36.2 10.3 27.4 8.4 31.4 9.5 35.6 10.7 36.9 10.0 36.8 10.1 36.4 10.3 36.1 10.4 35.9 10.5 37.1 37.0 OUTDOOR WB°C 27.2 8.5 31.1 9.6 32.7 8.5 31.6 9.4 8.7 9.0 9.3 32.8 8.6 8.8 8.9 9.1 31.8 9.2 32.0 9.1 32.6 32.5 32.2 32.1 32.3 31.7 27.6 8.4 28.5 7.6 28.4 7.8 7.8 28.1 8.0 28.0 8.1 27.8 8.2 27.7 8.3 28.1 7.9 27.9 8.1 28.6 7.7 28.3

* Q : HEATING CAPACITY T/I : TOTAL INPUT

Factor for Various Air Flow

	4	CMM	80	06	100
PEH-10MYA-EU	AIK VOLUME	S/J	1,330	1,500	1,660
CIVIEVUIT	CAPACITY		0.989	1.0	1.008
פאבו ליוב	TI IGINI IATOT	L	1 025	10	0 087

PE-10MYC-FII		CMM	80	90	100
PEH-10MYA-EU	AIR VOLUME	S/T	1,330	1,550	1,660
	CAPACITY		0.977	1.0	1.035
	TOTAL INPUT		0.991	1.0	1.005
	SHC		0.968	1.0	1.037

Cooling Capacity (Standard Air Flow) PE-10MYC-EU, PEH-10MYA-EU (combined with PUH-10MYE-EU)

T/I kW 11.4 11.5 11.6 11.8 11.9 11.9 12.1 12.2 12.3 12.1 12.5 12.2 12.5 11.7 11.7 12.1 12.2 12.4 12.4 12.1 0.75 99.0 99.0 0.87 0.78 0.62 0.54 0.74 0.50 92.0 0.63 0.54 0.75 0.57 0.48 69.0 99.0 0.58 0.61 SFF SHCKW 20.1 20.4 21.8 17.0 22.0 17.0 19.1 17.0 23.4 15.4 13.8 18.7 17.2 15.6 20.4 18.7 15.8 13.3 21.7 20.1 15.5 13.7 22.8 18.9 15.2 25.4 23.2 20.2 18.6 13.9 17.1 22.5 23.3 23.3 24.9 27.6 27.6 24.9 27.6 27.6 28.6 27.6 27.6 28.6 29.5 30.5 27.6 28.6 29.5 30.5 22.5 23.3 24.1 24.9 24.1 25.7 25.7 29.5 25.7 27.6 24.1 ŏ 25.7 T/I kW 11.1 11.0 11.5 10.6 10.6 10.8 10.9 11.0 10.7 10.8 10.9 11.0 11.2 10.9 1. 11.2 11.3 11.5 11.0 11.2 11.3 11.5 11.6 11.3 11.6 10.7 0.73 0.76 0.72 0.74 0.74 0.65 0.70 0.62 0.92 0.82 0.65 0.56 0.48 0.85 09.0 0.53 0.46 0.89 0.64 0.49 0.67 0.60 0.87 0.54 0.67 0.57 0.81 0.57 봀 SHCKW 21.0 22.4 21.2 17.6 16.1 14.5 20.9 19.4 17.8 16.3 14.6 21.1 19.4 17.6 16.5 14.0 19.7 17.6 14.4 24.2 23.6 19.6 17.9 16.1 26.0 22.5 19.5 22.7 20.7 16.1 23.9 25.6 26.5 27.3 29.4 29.4 26.5 29.4 27.3 29.4 30.4 31.4 32.5 Q W 24.7 25.6 26.5 29.4 30.4 31.4 32.5 29.4 30.4 23.9 25.6 24.7 27.3 31.4 29.4 29.4 24.7 27.3 T/I KW 10.4 10.4 10.1 10.1 10.2 10.3 10.1 10.2 10.3 10.5 10.3 10.5 10.8 10.3 10.5 10.8 9.8 6.6 10.0 10.2 10.4 10.2 10.7 10.4 10.7 9.8 6.6 10.0 6.6 10.0 10.7 0.85 0.55 0.74 0.68 0.71 0.63 0.82 0.58 0.86 0.78 0.70 0.56 0.49 0.85 0.72 0.72 0.56 0.89 0.80 0.47 0.65 0.52 0.45 0.63 0.78 0.65 0.59 0.64 0.61 0.53 붌 SHCkW 21.6 17.0 22.9 21.2 18.1 24.8 21.6 18.1 21.4 19.9 18.3 16.9 19.8 18.2 14.6 16.6 24.2 21.7 20.1 18.5 26.3 24.3 23.0 20.1 16.7 23.2 20.1 15.0 16.7 15.3 15.1 Ø Š 28.8 27.9 31.0 28.8 31.0 31.0 32.0 33.1 26.0 26.0 26.9 27.9 26.0 26.9 27.9 31.0 28.8 31.0 32.0 31.0 32.0 31.0 34.2 25.1 26.9 25.1 28.8 31.0 33.1 34.2 33.1 T/I KW 9.3 9.3 9.3 9.4 9.2 9.6 9.2 9.6 9.7 9.9 10.0 9.5 9.6 9.7 10.0 10.1 9.6 9.7 6.6 10.0 10.1 9.5 9.3 9.5 9.4 9.2 9.3 9.3 9.4 6.6 9.7 0.64 92.0 0.60 0.79 0.70 0.54 0.72 0.64 0.58 0.51 92.0 0.68 0.55 0.48 0.83 0.70 0.64 0.58 0.72 0.56 0.84 0.68 0.52 0.88 0.62 0.47 0.45 0.84 0.62 0.77 0.81 봀 23.4 22.2 SHCKW 20.4 17.6 18.8 23.6 18.7 17.3 21.8 20.5 17.5 22.1 18.7 15.1 21.8 20.9 25.3 22.2 19.0 17.2 27.0 24.9 20.6 15.8 19.0 15.8 23.7 17.2 15.5 20.7 24.7 29.1 32.4 Ø Š¥ 28.1 29.1 27.1 30.1 32.4 32.4 30.1 32.4 32.4 33.5 34.6 30.1 32.4 33.5 34.6 32.4 32.4 33.5 34.6 35.7 27.1 26.1 27.1 28.1 29.1 35.7 26.1 30.1 28.1 T/I KW 9.5 9.3 8.6 8.8 8.9 8.9 9.0 9.1 8.9 9.0 9.2 9.3 9.0 9.2 9.5 9.2 9.4 8.6 8.7 8.8 8.7 9.0 8.7 8.8 9.2 9.1 9.4 9.1 9.4 9.1 9.3 0.69 0.54 0.82 0.75 0.63 0.71 0.82 0.75 0.46 0.79 0.71 0.64 0.57 0.74 0.67 0.60 0.54 0.47 0.82 0.64 0.59 0.52 0.86 0.78 0.61 0.51 0.44 0.69 0.57 0.56 0.67 봀 25.0 23.9 22.6 18.1 23.9 25.6 22.5 20.9 SHCkW 17.9 22.2 21.0 19.5 18.0 22.6 20.8 19.2 21.5 19.3 25.0 19.3 27.5 25.3 21.0 19.2 22.3 17.7 17.5 24.2 15.6 15.9 16.3 16.2 36.9 35.9 33.6 28.1 27.0 29.1 30.2 30.2 33.6 33.6 30.2 31.2 33.6 34.7 35.9 31.2 33.6 33.6 34.7 35.9 36.9 33.6 33.6 27.0 28.1 28.1 29.1 31.2 34.7 ŏ 29.1 31.2 T/I kW 8.6 8.7 9.0 8.4 8.4 8.5 8.6 8.4 8.5 8.7 8.8 8.5 8.9 9.0 8.6 8.8 8.2 8.3 8.4 8.5 8.3 8.4 8.6 8.9 8.8 8.7 8.7 0.62 0.56 0.71 0.63 0.81 99.0 0.59 0.85 0.77 0.68 0.61 0.54 0.47 0.78 0.70 0.63 0.57 0.50 0.44 0.81 0.73 99.0 09.0 0.53 0.47 0.81 0.75 0.68 0.51 붌 SHCKW 36.9 23.0 38.0 21.4 22.5 21.3 18.6 26.0 22.8 17.9 28.0 25.8 19.6 24.2 22.6 19.6 25.4 21.3 18.2 21.3 19.8 18.3 16.5 24.6 23.0 19.6 16.1 21.8 18.0 16.3 19.7 24.5 16.7 31.1 32.1 28.9 27.8 28.9 30.0 32.1 34.6 34.6 34.6 35.8 36.9 34.6 34.6 35.8 36.9 38.0 34.6 34.6 35.8 27.8 30.0 28.9 31.1 34.6 31.1 32.1 § 32.1 30.0 INDOOR INDOOR WB °C 24 16 19 23 12 15 16 17 18 19 16 18 20 8 19 20 22 23 19 22 23 24 20 22 17 17 7 7 20 21 21 OB C 20 22 24 26 28 30

PE-10MYC-EII	L C	CMM	80	90	100
PEH-10MYA-EU	AIK VOLUME	S/J	1,330	1,550	1,660
	CAPACITY		0.977	1.0	1.035
COOLING	TOTAL INPUT		0.991	1.0	1.005
	SHC		0.968	1.0	1.037

Note1.* Q:COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

(Use for low ambient cooling parts)

PE-10MYC-EU, PEH-10MYA-EU (combined with PUH-10MYE-EU)

Heating Capacity (Standard Air Flow) PEH-10MYA-EU

	=		
	ī	ī	
	7	•	
	5	<u> </u>	
	Ę	5	
	Ē		
	:	Ξ	
	_	ì	
	Ξ	L	
	Ξ		Ì
ĺ	C	1	
	4	c	
•	4		
:	:	S	
	7	C	
	(1	
	3	C	
	9	Ē	
	ì	7	
ı	ì	ĭ	
	1	=	

		7 K	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.6	7.6	7.7	7.8	7.8	7.9			
	0.0	Q KW	24.8	24.5	24.6	24.5	24.4	24.3	24.3	24.2	24.1	24.0	23.9	23.7	23.6			
R WB°C	0	T/I kW	6.4	6.4	6.4	6.5	6.5	9.9	9.9	9.9	6.7	6.7	6.8	6.8	6.9			
OUTDOOR WB°C	-5.0	Q KW	21.4	205.8	21.3	21.2	21.1	21.0	20.9	20.8	20.7	20.6	20.5	20.4	20.3			
	0	T/I kW	6.1	6.1	6.1	6.2	6.2	6.2	6.2	6.3	6.3	6.3	6.3	6.4	6.4			
	-10.0	Q KW	18.4	18.3	18.2	18.2	18.1	18.0	17.9	17.8	17.7	17.6	17.5	17.4	17.3			
	INDOOR	DB°C	15	16	17	18	19	20	21	22	23	24	25	26	27			
		•																
		T/I kW	9.3	9.4	9.4	9.3	9.4	9.4	9.2	9.7	9.4	9.4	9.2	9.7	9.8	9.9	9.2	
	15.0	SHF	0.70	0.63	0.55	0.80	0.73	0.65	0.58	0.51	0.84	0.76	0.68	0.61	0.54	0.47	77.0	
	15	SHCkW	18.2	16.8	15.4	20.8	19.5	18.2	16.8	15.2	22.6	21.2	19.7	18.2	17.3	15.1	22.3	
		Q kW	25.9	26.9	27.9	25.9	26.9	27.9	28.9	29.9	26.9	27.9	28.9	29.9	32.2	32.2	28.9	
		T/I kW	8.7	8.8	8.9	8.7	8.8	8.9	9.0	9.1	8.8	8.9	9.0	9.1	9.2	9.2	9.0	
	10.0	SHF	0.70	0.62	0.54	0.80	0.72	0.65	0.58	0.51	0.83	0.75	0.67	09.0	0.53	0.46	92.0	,
	10	SHCKW	18.6	17.2	15.6	21.2	20.0	18.6	17.2	15.7	23.1	21.7	20.0	18.6	17.7	15.3	22.7	

28.7

8.5

15.9 0.54 21.6 0.79

0.54

16.1

29.9

0.54

0.61

18.0 16.3 22.3

29.3 30.3 28.2 29.3

16

20

17 15 16 17

15

27.8 22.0 0.79 28.9 20.7 0.72 29.9 19.3 0.64 30.9 17.8 0.58

0.79

0.61

28.4 29.4 27.3 28.4

Q kW SHCkW SHF | T/I kW

T/I kW

SHC KW SHF

T/I KW

SH 0.69

SHCKW 19.5

δ Š 28.2

DB°C WB°C

INDOOR

27.8 19.2 0.69 17.7 0.61

27.3 18.9 0.69

OUTDOOR DB°C

26.7 27.7 28.7

8.4 8.5

20.4 0.72 29.4 19.1 0.65 17.6 0.58 30.8

8.7

0.51 0.83

16.0

0.51

16.4

32.1

8.0

0.51 0.82 0.74 20.9 0.67

16.6

19

24.0

16

28.9 23.8 0.82 29.9 22.3 0.75 30.9 20.7 0.67 32.1 19.2 0.60 34.4 18.2 0.53

30.4 31.5 28.4

8.2 8.3 8.3

7.9

30.3 31.3 32.6 29.3

22

18

7.8

0.71 19.4 0.64 17.9 0.57

20.9

8.0

23.5

29.7

28.7 29.7 30.8 33.1 33.1

8.5

0.75

22.0

8.2 8.3 8.3 8.4 8.5 8.3 8.3

8.6

20.4 0.67

30.4 29.4

8.0

31.3 32.6 34.9 34.9

18 19

24

8.0 8.1

19.5 0.60

7.9

22.6

30.3

17

8.7

18.9 0.60 17.9 0.53

31.5 33.9 33.9 30.4

8 8 8 9 9 9 9 8 8

	0.	T/I kW	9.9	9.8	10.0	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	11.0	11.1
	15.0	Q kW	37.3	37.2	37.1	37.0	36.9	36.8	36.6	36.4	36.2	36.1	35.9	35.6	35.4
OUTDOOR WB°C	0.	T/I kW	8.7	9.8	8.8	8.9	9.0	9.1	9.2	9.2	9.3	9.4	9.2	9.6	9.7
оитрос	10.0	Q KW	32.8	32.7	32.6	32.5	32.3	32.2	32.1	32.0	31.8	31.7	31.6	31.4	31.1
	0	T/I kW	8.0	7.9	8.1	8.1	8.2	8.3	8.4	8.4	8.5	8.6	8.7	8.7	8.8
	5.0	Q KW	28.6	28.5	28.4	28.3	28.1	28.1	28.0	27.9	27.8	27.7	27.6	27.4	27.2
	INDOOR	DB°C	15	16	17	18	19	20	21	22	23	24	25	26	27

10.0 10.1

19.6 0.59

9.8

32.2

9.5

23.9 0.72 21.5 0.65

33.1 33.1 34.2 35.3

8.7 8.8

24.3 0.72

33.9

8.4

1.8

34.9

20

34.9 36.0 37.0

7 22

28

8.2

33.9 21.9 0.65 20.6 0.59

8.5 9.8 8.7 8.7 8.4

30.8

8.7

24.9 0.79

31.5

8.3

32.2 33.3

9.5

6.6

10.1

0.47

35.3 32.2

9.6

0.47

17.0 26.3

36.2 33.1

9.1

0.47

17.3

36.9

0.53

18.1 16.5 25.7

34.3

9.4

0.53

9.0

0.53

19.0

0.53

36.6 19.3

8.3 8.4

19.5

23

8.3

9.3

0.59

20.1 18.6

8.9

35.0 36.1 9.8 6.6

0.80

9.5 9.5

0.79

8.7 8.8 8.9 9.0

26.7 0.79 33.9 24.7 0.73 35.0 23.4 0.67 21.9 0.61

33.9

34.4 27.1 0.79

8.1

27.5 0.79

34.9

20

17.9

37.8

24

37.5 17.6 0.47

8.5 8.6

34.4 25.1 0.73 35.6 23.8 0.67 36.6 22.2 0.61

8.2

25.4 0.73 24.0 0.67

34.9

21 22 23

8.3 8.3

36.0

30

22.5 0.61

37.0

20.7

37.8

23.8 0.74

32.2

10.0

0.50

16.6

33.3

9.3

0.50 0.44 0.79

17.0

8.9

0.50

17.4

0.50

35.6 17.7

8.3

0.50 0.44 0.79 24.9 0.71 22.2 0.64 21.0 0.58 0.53 0.47

17.9

10.1

0.44 0.80 23.3 0.72 20.9 0.65

34.3 29.9

9.4 9.1

15.5 24.5

9.0

0.44

15.8

36.1

8.7

16.0 0.44 32.1 25.4 0.79 34.4 24.6 0.72 34.4 22.1 0.64 35.6 20.9 0.59

36.6

8.3 8.0

16.2

37.0 32.6

25.7

9.7

23.9

6.6

18.0 0.56

32.2

9.5

18.5 0.56

33.1 34.2 35.3

8.8

18.9 0.56

0.62

9.5

33.1

8.7

20.9 0.62

33.9 33.9 35.0

8.4

8.1

34.9

20 7 22 23 19

26

8.2

19.5 0.56

34.9 36.0

8.0

22.4

8.5 8.6

9.7

20.8 0.69

29.9 32.2

9.1

0.69 20.5 0.62

21.3

30.8

8.7

21.7 0.69

31.5

29.7

9.8

8.8

15.5 0.46 23.1 0.76

0.46

15.8

34.4

8.2

0.53 0.46 0.76 0.69 21.6 0.62

18.4 16.0 23.7

20

21 18 19

30.9 23.5 0.76 32.1 22.1 0.69 34.4 21.3 0.62 34.4 19.2 0.56

8.0

31.3 32.6

8.7

10.1

0.62 0.56

34.3

9.4

21.6 0.61

35.3

10.0

0.68

22.6

33.3

9.3

23.0 0.67 24.3 0.73

33.1 34.2 10.1

19.7

35.3

9.6

0.55

20.0

36.2

9.1

20.2

36.1

8.7

T/I:TOTAL INPUT SHC:SENSIBLE HEAT CAPACITY Note1. * Q :COOLING CAPACITY

Factor for Various Air Flow

PF-10MYC-FII	L	CMM	80	90	100
PEH-10MYA-EU	AIR VOLUME	S/J	1,330	1,550	1,660
	CAPACITY		0.977	1.0	1.035
	TOTAL INPUT		0.991	1.0	1.005
	SHC		896'0	1.0	1.037

Factor for Various Air Flow	or Vari	ous	Air	Flov	>
	Little Control Control	CMM	80	06	
PEH-10MYA-EU	AIK VOLUME	S/J	1,330	1,500	
CNIF	CAPACITY		0.989	1.0	
	TOTAL INPUT	TU	1.025	1.0	

1,660 1.008 0.984

Q: HEATING CAPACITY T/I: TOTAL INPUT

Cooling Capacity (Standard Air Flow) PE-15MYC-EU

	46.0	SHF T/I kW Q kW SHCkW SHF T/I kW	0.74 17.6 35.2 26.4 0.75 19.2	0.65 17.9 36.6 24.1 0.66 19.4	0.55 18.3 37.8 21.5 0.57 19.7	0.88 17.6 35.2 31.3 0.89 19.2	17.9 36.6 29.1 0.79	0.68 18.3 37.8 26.4 0.70 19.7	0.61 18.5 39.0 24.2 0.62 19.9	0.53 18.8 40.4 21.8 0.54 20.1	0.92 17.9 36.6 34.4 0.94 19.4	0.83 18.3 37.8 31.9 0.84 19.7	0.74 18.5 39.0 29.2 0.75 19.9	0.65 18.8 40.4 26.7 0.66 20.1	0.56 19.2 41.8 23.8 0.57 20.6	0.47 19.4 43.4 20.9 0.48 20.8	0.85 18.5 39.0 33.5 0.86 19.9	0.77 18.8 40.4 31.5 0.78 20.1	0.69 19.2 41.8 29.3 0.70 20.6	0.60 19.4 43.4 26.5 0.61 20.8	0.52 19.7 44.8 23.3 0.52 21.0	0.43 19.9 46.2 19.9 0.43 21.5	0.88 18.8 40.4 36.8 0.91 20.1	0.80 19.2 41.8 34.7 0.83 20.6	0.73 19.4 43.4 32.6 0.75 20.8	0.64 19.7 44.8 29.6 0.66 21.0	0.56 19.9 46.2 26.4 0.57 21.5	0.48 20.1 47.8 23.0 0.48 21.7	0.92 19.2 41.8 38.9 0.93 20.6	0.83 19.4 43.4 36.9 0.85 20.8	0.75 19.7 44.8 34.5 0.77 21.0	0.69 19.9 46.2 32.9 0.71 21.5	
	40.0	Q kW SHCKW	36.6 27.1	38.2 24.7	39.6 22.0	36.6 32.2	7	39.6 27.1	41.2 25.0	42.6 22.6	38.2 35.1	39.6 32.8	41.2 30.3	42.6 27.6	44.0 24.7	45.6 21.6	41.2 34.8	42.6 32.6	44.0 30.2	45.6 27.4	47.2 24.4	48.6 21.0	42.6 37.5	44.0 35.4	45.6 33.1	47.2 30.4	48.6 27.3	50.4 24.2	44.0 40.3	45.6 38.0	47.2 35.5	48.6 33.6	
	35.0	SHF T/I kW	0.73 16.5	0.63 16.7	0.54 17.0	0.87 16.5	16.	0.67 17.0	0.60 17.2	0.52 17.6	0.90 16.7	0.81 17.0	0.72 17.2	0.64 17.6	0.55 17.9	0.47 18.1	0.83 17.2	0.75 17.6	0.67 17.9	0.59 18.1	0.51 18.3	0.43 18.8	0.85 17.6	0.78 17.9	0.70 18.1	0.63 18.3	0.55 18.8	0.48 19.0	0.90 17.9	0.82 18.1	0.73 18.3	0.67 18.8	, ,
DB°C	35	Q kW SHCkW	38.4 28.0	39.8 25.3	41.2 22.3	38.4 33.4	8	41.2 27.6	42.6 25.4	44.0 22.9	39.8 35.8	41.2 33.4	42.6 30.7	44.0 28.0	45.6 25.1	47.4 22.1	42.6 35.4	44.0 33.0	45.6 30.6	47.4 28.0	48.8 25.0	50.6 21.9	44.0 37.4	45.6 35.4	47.4 33.3	48.8 30.6	50.6 27.9	52.0 24.8	45.6 41.1	47.4 38.7	48.8 35.7	50.6 34.0	
OUTDOOR DB°C		T/I KW	15.4	15.6	15.8	35 15.4	15.6	15.8	16.3	16.5	15.6	15.8	16.3	16.5	16.7	17.0	16.3	16.5	16.7	17.0	17.2	17.6	16.5	16.7	17.0	17.2	17.6	17.9	16.7	17.0	17.2	17.6	
	30.0	SHCKW SHF	28.7 0.72	26.1 0.63	23.2 0.55	33.8 0.85	2	28.4 0.67	26.1 0.59	23.6 0.52	36.5 0.89	34.0 0.80	31.4 0.71	28.8 0.63	25.9 0.55	22.8 0.46	36.1 0.82	33.8 0.74	31.4 0.66	28.6 0.58	25.8 0.51	22.6 0.43	38.5 0.84	36.3 0.77	33.9 0.69	31.5 0.62	28.8 0.55	25.8 0.48	42.0 0.89	39.3 0.80	36.4 0.72	34.4 0.65	
		/I kW Q kW	14.5 39.8	14.7 41.2	14.9 42.6	14.5 39.8	4	14.9 42.6	15.1 44.2	15.6 45.8	14.7 41.2	14.9 42.6	15.1 44.2	15.6 45.8	15.8 47.4	16.0 49.0	15.1 44.2	15.6 45.8	15.8 47.4	16.0 49.0	16.3 50.8	16.7 52.6	15.6 45.8	15.8 47.4	16.0 49.0	16.3 50.8	16.7 52.6	17.0 54.2	15.8 47.4	16.0 49.0	16.3 50.8	16.7 52.6	
	25.0	W SHF T/I	3 0.71	9 0.63	0.55	0.83	0.75	99.0	0.59	0.51	. 0.87	0.79	0.70	0.62	0.54	0.46	0.80	0.73	3 0.65	2 0.58	0.50	0.43	0.83	0.76	0.68	0.61	0.54	0.47	. 0.87	0.79	0.70	0.64	
		Q kW SHCkW	41.2 29.3	42.6 26.9	44.0 24.2	41.2 34.2	31		45.6 26.7	47.2 24.1	42.6 37.1	44.0 34.6	45.6 32.0	47.2 29.3	48.8 26.4	50.6 23.4	45.6 36.5	47.2 34.3	48.8 31.8	50.6 29.2	52.4 26.3	54.2 23.2	47.2 39.2	48.8 36.9	50.6 34.5	52.4 32.1	54.2 29.4	56.0 26.5	48.8 42.5	50.6 39.8	52.4 36.8	54.2 34.6	
		T/I kW	13.8	14.0	14.2	13.8			14.5	14.7	14.0	14.2	14.5	14.7	15.1	15.4	14.5	14.7	15.1	15.4	15.6	15.8	14.7	15.1	15.4	15.6	15.8	16.3	15.1	15.4	15.6	15.8	
	20.0	SHCkW SHF	29.8 0.70	27.4 0.62		35.0 0.82			2	25.0 0.51	37.9 0.86	35.4 0.78	32.7 0.70	30.2 0.62	27.3 0.54	24.3 0.46	37.4 0.80	35.1 0.72	32.4 0.64	29.7 0.57	26.9 0.50	23.7 0.43	40.1 0.82	37.8 0.75	35.4 0.68	32.8 0.61	30.0 0.54	27.0 0.47	3.2 0.86	40.6 0.78	37.7 0.70	35.2 0.63	
		Q kW SHC	42.6 29	44.0 27	45.4 24	42.6 35			47.0 27	48.8 25	44.0 37	45.4 35	47.0 32	48.8 30	50.4 27	52.2	47.0 37	48.8 35	50.4 32	52.2 29	54.0 26	55.8 23	48.8 40	50.4 37	52.2 35	54.0 32	55.8 30	57.6 27	50.4 43.	52.2 40	54.0 37	55.8 35	
	NDOOR	WB °C	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	23	
	INDOOR	DB °C		20				22					24						26						28						30		_

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

10 0/14/20		CMM	120	140	160
7E-13M-10-E0	AIN VOLOIME	S/7	2,000	2,334	2,660
	CAPACITY		0.976	1.0	1.025
	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

(Use for low ambient cooling parts)

PE-15MYC-EU

													OUTDOOR DB°	S DB°C							
INDOOR	INDOOR		-5.0	0			0.0				5.0				10.0	0			15.	0	
DB°C	WB °C	Q kW	SHCKW	SHF	T/I kW	Q kW	SHCKW	SHF	T/I kW	Q KW	SHCkW	SHF	T/I kW	Q KW	SHCKW	SHF	T/I kW	Q KW	SHCKW	SHF	T/I kW
	15	41.8	28.9	0.69	12.7	40.7	27.9	69.0	13.8	39.4	26.8	89.0	14.9	40.1	27.5	69.0	14.4	43.2	29.8	69.0	13.1
20	16	43.7	26.7	0.61	12.9	42.6	25.9	0.61	14.0	41.0	24.9	0.61	15.2	41.8	25.5	0.61	14.7	45.0	27.7	0.62	13.3
	17	45.2	24.0	0.53	13.1	44.2	23.5	0.53	14.3	42.7	22.7	0.53	15.5	43.4	23.3	0.54	14.9	46.6	25.2	0.54	13.6
	15	41.8	33.5	0.80	12.7	40.7	32.6	08.0	13.8	39.4	31.6	0.80	14.9	40.1	32.3	0.81	14.4	43.2	35.0	0.81	13.1
	16	43.7	31.5	0.72	12.9	42.6	30.8	0.72	14.0	41.0	29.8	0.73	15.2	41.8	30.2	0.72	14.7	45.0	32.5	0.72	13.3
22	17	45.2	29.0	0.64	13.1	44.2	28.6	0.65	14.3	42.7	27.8	0.65	15.5	43.4	27.9	0.64	14.9	46.6	29.4	0.63	13.6
	18	46.9	27.1	0.58	13.4	45.7	26.5	0.58	14.3	44.3	25.8	0.58	15.7	44.9	25.9	0.58	15.2	48.0	27.4	0.57	13.8
	19	48.6	24.9	0.51	13.6	47.2	24.2	0.51	14.8	45.7	23.4	0.51	16.0	46.2	23.6	0.51	15.7	49.6	25.4	0.51	14.5
	16	43.7	37.2	0.85	12.9	42.6	36.0	0.85	14.0	41.0	34.5	0.84	15.2	41.8	35.3	0.85	14.7	45.0	38.3	0.85	13.3
	17	45.2	34.4	0.76	13.1	44.2	33.7	92.0	14.3	42.7	32.5	92.0	15.5	43.4	33.3	0.77	14.9	46.6	35.9	0.77	13.6
24	18	46.9	31.5	0.67	13.4	45.7	30.9	89.0	14.3	44.3	30.2	89.0	15.7	44.9	30.8	69.0	15.2	48.0	33.2	69.0	13.8
	19	48.6	29.3	09.0	13.6	47.2	28.4	09.0	14.8	45.7	27.5	09.0	16.0	46.2	28.2	0.61	15.7	49.6	30.6	0.62	14.5
	20	50.4	26.8	0.53	13.8	48.8	25.8	0.53	15.1	47.3	24.7	0.52	16.5	48.0	25.6	0.53	16.0	51.6	28.0	0.54	14.5
	21	52.4	24.3	0.46	14.1	50.7	22.9	0.45	15.3	49.0	21.7	0.44	16.8	49.7	22.6	0.46	16.2	53.4	25.0	0.47	14.7
	18	46.9	36.7	0.78	13.4	45.7	35.0	7.70	14.3	44.3	33.3	0.75	15.7	44.9	34.7	0.77	15.2	48.0	38.0	0.79	13.8
	19	48.6	34.4	0.71	13.6	47.2	33.0	0.70	14.8	45.7	31.6	69.0	16.0	46.2	32.4	0.70	15.7	49.6	35.3	0.71	14.5
56	20	50.4	31.8	0.63	13.8	48.8	30.9	0.63	15.1	47.3	29.9	0.63	16.5	48.0	30.4	0.63	16.0	51.6	32.6	0.63	14.5
	21	52.4	29.8	0.57	14.1	20.7	28.7	0.57	15.3	49.0	27.5	0.56	16.8	49.7	27.9	0.56	16.2	53.4	30.0	0.56	14.7
	22	54.2	27.2	0.50	14.3	52.5	26.2	0.50	15.6	50.9	25.1	0.49	17.1	51.5	25.4	0.49	16.5	55.2	27.2	0.49	14.9
	23	55.7	24.4	0.44	14.8	54.2	23.3	0.43	15.8	52.6	22.2	0.42	17.4	53.2	22.5	0.42	16.7	57.0	24.1	0.42	15.1
	19	48.6	39.0	08.0	13.6	47.2	37.8	08.0	14.8	45.7	36.7	08.0	16.0	46.2	37.3	0.81	15.7	49.6	40.3	0.81	14.5
	20	50.4	36.9	0.73	13.8	48.8	35.9	0.73	15.1	47.3	34.9	0.74	16.5	48.0	35.5	0.74	16.0	51.6	38.3	0.74	14.5
28	21	52.4	34.8	99.0	14.1	50.7	33.8	0.67	15.3	49.0	32.9	0.67	16.8	49.7	33.4	0.67	16.2	53.4	35.9	0.67	14.7
	22	54.2	32.4	09.0	14.3	52.5	31.5	09.0	15.6	6.03	30.7	09.0	17.1	51.5	31.1	09.0	16.5	55.2	33.3	09.0	14.9
	23	22.7	29.7	0.53	14.8	54.2	28.9	0.53	15.8	52.6	28.0	0.53	17.4	53.2	28.3	0.53	16.7	97.0	30.4	0.53	15.1
	24	58.0	27.1	0.47	15.0	56.2	26.2	0.47	16.3	54.5	25.3	0.46	17.6	92.0	25.5	0.46	17.3	58.8	27.2	0.46	15.6
	20	50.4	41.4	0.82	13.8	48.8	40.4	0.83	15.1	47.3	39.4	0.83	16.5	48.0	40.2	0.84	16.0	51.6	43.5	0.84	14.5
	21	52.4	39.5	0.75	14.1	50.7	38.3	0.76	15.3	49.0	37.1	0.76	16.8	49.7	37.9	0.76	16.2	53.4	41.0	0.77	14.7
30	22	54.2	37.0	0.68	14.3	52.5	35.9	0.68	15.6	50.9	34.8	0.68	17.1	51.5	35.4	0.69	16.5	55.2	38.2	0.69	14.9
	23	55.7	34.4	0.62	14.8	54.2	33.5	0.62	15.8	52.6	32.5	0.62	17.4	53.2	33.0	0.62	16.7	57.0	35.5	0.62	15.1
	24	58.0	32.1	0.55	15.0	56.2	31.1	0.55	16.3	54.5	30.2	0.55	17.6	55.0	30.4	0.55	17.3	58.8	32.5	0.55	15.6
* 504014		XHOWE		1		- L	YEI O A O A O E A FI		11 14 10 1.1/1	H											

Note1. * Q : COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

DF 4584XC F11		CMM	120	140	160
7E-13M10-E0	AIR VOLUME	S/I	2,000	2,334	2,660
0141000	CAPACITY		926.0	1.0	1.025
COOCIING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

PEH-15MYA-EU

No.						ļ							7	OUTDOOR DB°C	JB°C											
Mathematic No. Math	INDOOR			20.0				25.	0			30.0				35.0				40.0	•			46.0		
	DB °C	WB °C		SHCkW		T/I kW		SHCkW		ΚW	Κ	HCKW		ΚW	ΚŅ	НСКМ		κ	ΚŅ	HCKW		Κ	ΚŅ		Σ	Κ
440 27.4 60.2 63.5 61.5 62.5 63.5 62.5 63.5 62.5 63.5 62.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5 63.5		15	42.6	29.8	0.70	13.2	41.2	29.3	0.71	13.9	39.8	28.7		8	4	0	0.73	15.8	36.6			6	2	4		8.4
1, 4, 4, 4, 4, 2, 4, 3, 4,	20	16	44.0	27.4	0.62	13.5	42.6	26.9	0.63	14.1	41.2	26.1		0	8	3	0.63	16.1	38.2	24.7		-	9	1		3.7
4.6 4.0 6.0 4.0 6.0 4.0 6.0 4.0 6.0 4.0 6.0 <		17	45.4	24.8	0.55	13.7	44.0	24.2	0.55	14.3	42.6	23.2	55	2	.2	3	0.54	16.3	39.6	0.		9.	8.	.5	_	8.9
1. 1. 1. 1. 1. 1. 1. 1.		15	42.6	35.0	0.82	13.2	41.2	34.2	0.83	13.9	39.8	33.8	85	8	4	4	0.87	15.8	36.6	2		6		.3		3.4
1.1 4.4 2.0		16	44.0	32.3	0.73	13.5	42.6	31.8	0.75	14.1	41.2	31.2		0	8		0.77	16.1	38.2				9	1		3.7
41 42 62 63 63 64 62 63 63 64<	22	17	45.4	29.3	0.65	13.7	44.0	29.1	99.0	14.3	42.6	4		2	.2		29.0	16.3	39.6			9	8.	4		8.9
14. 14.		18	47.0	27.2	0.58	13.9	45.6	26.7	0.59	14.5	44.2				9.		09.0	16.5				80		2		9.1
44 44 65 65 65<		19	48.8	25.0	0.51	14.1	47.2	24.1	0.51	15.0	45.8	9		8	0.	6	0.52	16.9	42.6	9						9.3
17 454 384 0.84 0.84 612 314 0.84<		16	44.0	37.9	0.86	13.5	42.6	37.1	0.87	14.1		5		0.	8		06.0	16.1	38.2	1				4		3.7
48 470 670 48 670 48 670 470		17	45.4	35.4	0.78	13.7	44.0	34.6	0.79	14.3	42.6	0		2	2	4	0.81	16.3	39.6	ω,		9.	ω.			8.9
148 148 148 149 149 149 149 149 149 149 149 149 149	24	18	47.0	32.7	0.70	13.9	45.6	32.0	0.70	14.5	44.2			9	9.		0.72	16.5		က		89		2		9.1
20 50.4 41.5 48.6 26.4 61.5 61.5 61.6 62.6 61.7 41.6 61.6 61.6 61.7 41.6 61.6 61.6 61.7 41.6 61.6 61.6 61.7 41.6 61.6 61.7 61.6 61.7 61.6 61.7 61.6 61.7 61.6 61.7 61.6 61.7 6		19	48.8	30.2	0.62	14.1	47.2	29.3	0.62	15.0	45.8	28.8	63	8	0	0	0.64	16.9		9.		0	4	7		9.3
18 4.70 5.72 5.43 5.44 5.06 5.45 5.04 5.04 5.04 5.04 5.04 5.05 5.04		20	50.4	27.3	0.54	14.5	48.8	26.4	0.54	15.2	47.4	25.9	22	_	9		0.55	17.1	44.0			4		8		9.7
18 470 371 680		21	52.2	24.3	0.46	14.8	50.6	23.4	0.46	15.4	49.0	22.8			4.			17.4	45.6	.6		7	4	6		0.0
19 488 35.1 0.72 44.0 33.0 0.75 46.0 47.0 43.0 0.75 46.0 47.0 43.0 0.75 46.0 47.0 47.0 43.0 0.75 47.0 48.0 30.2 0.65 47.4 31.4 0.66 16.1 45.0 0.67 17.1 44.0 30.2 0.69 18.4 41.8 31.4 0.66 18.7 44.0 30.2 0.69 18.7 41.8 41.8 41.8 41.8 41.8 41.8 41.8 41.0 30.2 0.69 18.7 41.4 41.0 30.2 0.69 18.4 41.8 41		18	47.0	37.4	0.80	13.9	45.6	36.5	08.0	14.5	44.2			9	9	4	0.83	16.5		8		8		2		9.1
20 50.4 32.4 66.4 14.5 48.8 31.8 0.65 15.4 31.4 66.6 16.1 45.6 30.6 17.1 44.0 30.2 0.69 18.7 43.4 26.5 0.70 21 52.2 29.7 0.57 14.8 50.6 29.2 0.58 15.4 49.0 28.6 0.58 16.3 47.4 28.0 0.59 17.4 45.6 27.4 0.50 18.7 43.4 28.5 0.61 22 52.0 0.50 15.0 52.4 26.3 0.50 16.5 52.6 0.51 16.5 48.8 25.0 0.51 17.6 48.8 25.0 0.51 18.7 48.8 49.0 39.0 0.61 18.6 49.0 39.0 18.0 48.8 49.0 39.0 18.4 48.0 39.0 18.4 48.0 39.0 18.0 48.0 28.0 18.0 48.0 28.0 18.0 48.0 28.0		19	48.8	35.1	0.72	14.1	47.2	34.3	0.73	15.0	45.8	8		8	0		0.75	16.9	42.6	9				.5		9.3
21 52.2 53.7 14.8 50.6 20.7 14.8 50.6 15.4 49.0 28.6 16.3 47.4 28.0 0.59 17.4 45.6 27.4 60.5 17.4 45.6 27.9 17.6 48.8 25.0 0.51 17.6 47.2 24.4 0.50 18.9 48.8 25.0 0.51 17.6 47.2 24.4 0.50 18.9 48.8 18.9 48.8 25.0 0.51 17.6 47.2 24.4 0.52 18.9 48.8 38.0 0.89 18.9 48.8 18.9 48.8 48.9 18.0 48.8 18.0 48.8 18.0 48.8 18.0 48.8 18.0 48.8 18.9 48.8 38.9 0.76 18.2 48.8 38.9 0.76 18.2 48.8 38.9 0.78 18.2 48.8 38.9 0.78 18.2 48.8 38.9 0.78 18.9 48.8 38.9 0.89 18.9 4	26	20	50.4	32.4	0.64	14.5	48.8	31.8	0.65	15.2	47.4	_			9	9	0.67	17.1	44.0	2		4		3	_	9.7
25 54,0 65,0 15,0 65,0 1		21	52.2	29.7	0.57	14.8	9.09	29.5	0.58	15.4	49.0	9		3	4.		0.59	17.4	45.6	4.				2		0.0
23 55.8 23.7 6.43 16.7 6.48 6.10 6.49 6.40 6.10 6.40 6		22	54.0	26.9	0.50	15.0	52.4	26.3	0.50	15.6	50.8	25.8	51	2	8		0.51	17.6	47.2	4	0.52			8		2.2
488 40.1 68.2 14.1 47.2 39.2 08.3 15.0 44.0 37.4 08.5 16.9 42.6 37.4 08.5 16.9 42.6 37.4 08.5 16.9 45.6 37.4 48.0 38.5 0.70 14.1 45.6 37.4 48.0 36.3 0.77 16.1 45.6 37.4 44.0 35.4 0.78 17.1 44.0 35.4 0.80 18.4 41.8 34.7 38.7 0.70 17.4 45.6 37.1 0.80 18.2 47.4 33.3 0.77 17.4 45.6 35.4 0.80 18.2 47.4 33.3 0.77 17.4 48.6 36.7 18.7 48.8 36.7 18.7 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0 18.2 48.8 36.0		23	55.8	23.7	0.43	15.2	54.2	23.2	0.43	16.1	52.6	9		6	9	6	0.43	18.0	48.6			_	2	6		9.0
20 504 37.8 0.75 14.5 48.8 36.9 0.76 15.2 47.4 36.3 0.77 16.1 45.6 35.4 0.78 17.1 44.0 35.4 0.78 17.1 45.0 35.4 0.78 17.4 45.0 33.1 0.79 17.4 45.6 33.1 0.79 17.4 45.6 33.1 0.79 17.4 45.6 33.1 0.79 17.4 45.6 33.1 0.79 17.4 45.6 33.1 0.79 17.4 45.6 33.1 0.79 47.8 32.0 0.69 16.3 47.8 30.6 0.65 17.4 47.6 30.7 17.4 47.6 47.6 47.8 32.6 0.69 17.1 47.8 30.6 17.8 47.8 30.6 17.1 47.6 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47.8 47		19	48.8	40.1	0.82	14.1	47.2	39.2	0.83	15.0	45.8	38.5	0.84	- ∞	0.	4.	0.85	16.9	42.6	.5		0	4	8		9.3
21 52.2 35.4 0.68 14.8 50.6 34.5 0.69 16.3 47.4 33.3 0.70 17.4 45.6 33.1 0.73 18.7 43.4 32.6 0.69 16.3 47.8 33.3 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 45.6 33.1 0.70 17.4 47.6 47.8 30.6 0.65 17.1 52.0 24.8 30.6 17.1 52.0 24.8 17.1 52.0 24.8 17.1 52.0 24.8 17.1 52.0 24.8 17.1 52.0 24.8 17.1 43.0 17.1 43.0 17.1 43.0 43.0 17.1 43.0 43.1 43.8 30.9 17.1 43.0 43.1 43.1 4		20	50.4	37.8	0.75	14.5	48.8	36.9	0.76	15.2	47.4	3		_	9		0.78	17.1	0.44	4		4	ω.			9.7
22 54.0 32.8 0.61 15.0 52.4 32.1 0.61 15.6 50.8 15.2 16.3 16.5 50.8 16.5 1	28	21	52.2	35.4	0.68	14.8	9.09	34.5	0.68	15.4	49.0	6		3	4.	_	0.70	17.4	45.6	_		_	4	9		0.0
23 55.8 30.0 0.54 15.2 54.2 29.4 16.1 52.6 28.8 0.55 16.9 50.6 18.0 48.6 27.3 0.56 19.1 46.2 26.4 0.57 18.0 48.6 27.3 0.56 19.1 46.2 26.4 18.2 26.4 18.2 50.4 48.6 27.3 0.48 17.1 52.0 24.8 0.56 17.1 40.0 0.47 18.2 26.4 41.1 0.90 17.1 44.0 40.3 0.92 18.4 41.1 0.90 17.1 44.0 40.3 0.92 18.4 41.1 0.90 17.1 44.0 40.3 0.92 18.4 41.1 40.0 17.1 44.0 40.3 18.3 41.8 4		22	54.0	32.8	0.61	15.0	52.4	32.1	0.61	15.6	50.8			2	8		0.63	17.6			9.64	6		9	_	2.2
24 57.6 27.0 0.47 15.6 6.0 26.5 0.48 16.3 52.6 0.48 17.1 52.0 24.8 18.2 52.6 0.48 17.1 45.0 24.8 16.1 45.0 0.89 16.1 45.0 24.8 17.1 40.0 17.1 44.0 40.3 0.80 17.1 40.0 17.1 44.0 40.3 0.89 18.1 47.4 38.7 0.80 17.1 40.0 17.1 44.0 40.3 0.80 47.2 48.6 47.2 48.6 48.6 47.2 48.6 48		23	55.8	30.0	0.54	15.2	54.2	29.4	0.54	16.1	52.6	8		6	9		0.55	18.0	48.6					4		9.0
20 50.4 43.2 0.86 14.5 48.8 42.5 0.87 15.2 47.4 40.0 16.3 47.4 45.6 47.1 45.6 47.4 45.6 47.4 45.6 47.4 45.6 47.4 45.6 47.4 47.6 47.4 47.4 47.6 47.6 47.4 47.6 4		24	57.6	27.0	0.47	15.6	56.0	26.5	0.47	16.3	54.2	8			0.		0.48	18.2	50.4	2						9.6
21 52.2 40.6 0.78 14.8 50.6 39.8 0.79 15.6 50.8 36.9 15.0 40.8 60.70 15.0 60.70 15.0 60.70 15.0 60.8 15.0 <t< td=""><td></td><td>20</td><td>50.4</td><td>43.2</td><td>0.86</td><td>14.5</td><td>48.8</td><td>42.5</td><td>0.87</td><td>15.2</td><td>47.4</td><td>0</td><td></td><td>1</td><td>9</td><td></td><td>06.0</td><td>17.1</td><td>44.0</td><td>3</td><td>0.92</td><td>4</td><td></td><td>6</td><td></td><td>9.7</td></t<>		20	50.4	43.2	0.86	14.5	48.8	42.5	0.87	15.2	47.4	0		1	9		06.0	17.1	44.0	3	0.92	4		6		9.7
22 54.0 37.7 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.8 0.70 15.0 52.4 36.0 16.1 16.2 52.6 34.4 0.65 16.9 50.6 34.0 0.67 18.0 18.0 18.0 18.0 18.0 18.0 18.0 18.0		21	52.2	40.6	0.78	14.8	9.09	39.8	0.79	15.4	49.0	8		ო	4.	_	0.82	17.4	45.6	0	0.83	7	4	6		0.0
55.8 35.2 0.63 15.2 54.2 34.6 0.64 16.1 52.6 34.4 0.65 17.1 52.0 34.8 0.67 18.9 50.6 34.0 0.67 18.0 59.4 0.65 17.1 52.0 31.8 0.61 18.2 50.4 31.9 0.63 19.3 47.8 31.1 0.65	30	22	54.0	37.7	0.70	15.0	52.4	36.8	0.70	15.6	50.8	4		2	8		0.73	17.6		2		6		2	_	2.2
57.6 32.4 0.56 15.6 56.0 32.1 0.57 16.3 54.2 32.1 0.59 17.1 52.0 31.8 0.61 18.2 50.4 31.9 0.63 19.3 47.8 31.1 0.65		23	55.8	35.2	0.63	15.2	54.2	34.6	0.64	16.1	52.6	4		6	9	\dashv	0.67	18.0	48.6	9		_	2	6	\dashv	9.6
		24	9'2'9	32.4	0.56	15.6	26.0	32.1	0.57	16.3	54.2	32.1	29		0		0.61	18.2	50.4		63		ω,			9.6

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

117 4 5 4 5 1 1 7 0		CMM	120	140	160
PER-IDIMIA-EU	AIR VOLOIME	S/J	2,000	2,334	2,660
	CAPACITY		0.976	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

(Use for low ambient cooling parts)

PEH-15MYA-EU

Heating Capacity (Standard Air Flow)

PEH-15MYA-EU

- 1			-		_						_						1
		0.0	T/I kW	12.5	12.5	12.7	12.7	12.7	12.9	12.9	13.2	13.2	13.4	13.4	13.4	13.6	
		0	Q kW	38.3	38.1	38.1	37.9	37.7	37.7	37.5	37.5	37.3	37.1	37.3	36.7	36.5	
	R WB °C	0	T/I kW	11.6	11.6	11.6	11.8	11.8	11.8	12.0	12.0	12.0	12.3	12.3	12.3	12.3	
	OUTDOOR WB°C	-5.0	Q KW	33.5	33.5	33.3	33.1	32.9	32.9	32.7	32.7	32.5	32.3	32.5	32.1	31.9	
	J	0.	T/I kW	10.7	10.7	10.9	10.9	11.2	11.2	11.2	11.2	11.2	11.2	11.2	11.2	11.4	
		-10.0	Q kW	29.5	29.3	29.1	28.9	28.5	28.5	28.5	28.3	28.1	28.1	28.1	27.7	27.7	
		NDOOR	D. BO	15	16	17	18	19	20	21	22	23	24	25	26	27	
			T/I kW	12.6	12.8	13.0	12.6	12.8	13.0	13.2	13.9	120.8	13.0	13.2	13.9	13.9	, , ,
		15.0	¥S.	0.69	0.62	0.54	0.81	0.72	0.63	0.57	0.51	0.85	0.77	0.69	0.62	0.54	1,1
		15	SHCKW	29.8	27.7	25.2	35.0	32.5	29.4	27.4	25.4	38.3	35.9	33.2	30.6	28.0	L
			Q KW	43.2	45.0	46.6	43.2	45.0	46.6	48.0	49.6	45.0	46.6	48.0	49.6	51.6	100
			T/I kW	13.9	14.1	14.3	13.9	14.1	14.3	14.6	15.1	14.1	14.3	14.6	15.1	15.3	45.0
		0.	SFF	69.0	0.61	0.54	0.81	0.72	0.64	0.58	0.51	0.85	0.77	0.69	0.61	0.53	40
		10.0	SHCkW	27.5	25.5	23.3	32.3	30.2	27.9	25.9	23.6	35.3	33.3	30.8	28.2	25.6	0
			Q KW	40.1	41.8	43.4	40.1	41.8	43.4	44.9	46.2	41.8	43.4	44.9	46.2	48.0	10.4
		-	$\overline{}$	_	-	_	-	-	-	-	-	-	-	-			_

14.6

13.5 41.0 29.8 0.73

13.7 42.7 27.8 0.65 14.8

13.7 44.3 25.8 0.58 15.1

31.6 0.80 14.3

39.4 42.7

13.2

32.6 0.80 42.6 30.8 0.72 44.2 28.6 0.65 45.7 26.5 0.58

40.7

33.5 0.80

41.8

12.4 12.6

31.5 0.72 29.0 0.64

43.7 45.2

16

17

22

15.4

45.7 23.4 0.51

14.8

22.7 0.53

13.5

13.7

13.2

27.9 0.69 42.6 25.9 0.61 44.2 23.5 0.53

40.7

12.2

28.9 0.69

41.8

12.4 12.6

26.7 0.61 24.0 0.53

43.7 45.2

16

20

17 15

39.4 26.8 0.68 14.3 41.0 24.9 0.61 14.6

Q kW SHCkW SHF T/I kW

Q KW SHCKW SHF T/I KW

T/I kW

SHCKW SHF

Ø Š¥

DB°C WBC

INDOOR

OUTDOOR DB°C

41.0 34.5 0.84 14.6

13.5 14.2

42.6 36.0 0.85

12.4

37.2 0.85

16 17 18 19

24

34.4 0.76 31.5 0.67

47.2 24.2 0.51

13.1

24.9 0.51

48.6 43.7 45.2 46.9 48.6 50.4 52.4

19

12.8

27.1 0.58

46.9

18

14.8

42.7 32.5 0.76

13.7

33.7 0.76 45.7 30.9 0.68

44.2

15.4

15.1

13.7 44.3 30.2 0.68 14.2 45.7 27.5 0.60 14.5 47.3 24.7 0.52

47.2 28.4 0.60

13.1

29.3 0.60

26.8 0.53 24.3 0.46

20 21

48.8 25.8 0.53 50.7 22.9 0.45

49.7

49.0 21.7 0.44

	D. B	15.0	W Q KW T/I KV	.7 55.7	.6 55.5	.2 55.3	.2 55.3	.4 54.9	.4 54.9	.6 54.7	.8 54.7	.1 54.5	.1 54.3	.3 54.3	.5 53.9	E 537
	OUTDOOR WB 'C	10.0	Q kW T/I kW	49.3 14.7	49.3 15.6	49.1 15.2	48.9 15.2	48.7 15.4	48.7 15.4	48.5 15.6	48.5 15.8	48.3 16.1	48.1 16.1	48.1 16.3	47.7 16.5	17 5 16 5
	0	0.	T/I KW	13.6	13.6	13.8	13.8	14.0	14.0	14.3	14.3	14.5	14.7	14.7	14.9	0 7 7
		5.0	Q KW	43.5	43.5	43.3	43.3	42.9	42.9	42.9	42.7	42.5	42.5	42.5	42.1	7 11 7
		INDOOR	D. BO	15	16	17	18	19	20	21	22	23	24	25	26	27
13.2	13.9	13.9	14.1	14.3	14.5	13.9	13.9	14.1	14.3	14.5	15.0	13.9	14.1	14.3	14.5	7

Factor for Various Air Flow

Note1. * Q

30

DEU 16MVA EII	JMI IOA GIV	CMM	120	140	160
03-4-1212	AIN VOLOIME	S/J	2,000	2,334	2,660
	CAPACITY		926.0	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

			KW.	9	9	ω	ω,	0	0	6	ω	5		_	<u>و</u>	6	
		5.0	Ξ	13.	13.	13.	13.	14.0	14.0	14.3	14.3	14.	14.7	14.7	14.9	14	
		4,	Q KW	43.5	43.5	43.3	43.3	42.9	42.9	42.9	42.7	42.5	42.5	42.5	42.1	41.7	
		INDOOR	DB °C	15	16	17	18	19	20	21	22	23	24	25	56	27	
13.2	13.9	13.9	14.1	14.3	14.5	13.9	13.9	14.1	14.3	14.5	15.0	13.9	14.1	14.3	14.5	15.0	
0.79	0.71	0.63	0.56	0.49	0.42	0.81	0.74	0.67	09.0	0.53	0.46	0.84	0.77	69.0	0.62	0.55	
38.0	35.3	32.6	30.0	27.2	24.1	40.3	38.3	35.9	33.3	30.4	27.2	43.5	41.0	38.2	35.5	32.5	
48.0	49.6	516	53.4	55.2	57.0	49.6	51.6	53.4	55.2	57.0	58.8	51.6	53.4	55.2	57.0	58.8	
14.6	15.1	15.3	15.6	15.8	16.1	12.1	15.3	15.6	15.8	16.1	16.6	15.3	15.6	15.8	16.1	16.6	
0.77	0.70	0.63	0.56	0.49	0.42	0.81	0.74	0.67	09.0	0.53	0.46	0.84	0.76	69.0	0.62	0.55	
34.7	32.4	30.4	27.9	25.4	22.5	37.3	35.5	33.4	31.1	28.3	25.5	40.2	37.9	35.4	33.0	30.4	
44.9	46.2	48.0	49.7	51.5	53.2	46.2	48.0	49.7	51.5	53.2	55.0	48.0	49.7	51.5	53.2	55.0	
15.1	15.4	15.9	16.1	16.4	16.7	15.4	15.9	16.1	16.4	16.7	16.9	15.9	16.1	16.4	16.7	16.9	
0.75	0.69		0.56	0.49	0.42	0.80	0.74	29.0	09.0	0.53	0.46	0.83	92.0	99.0	0.62	0.55	
33.3	31.6	29.9	27.5	25.1	22.2	36.7	34.9	32.9	30.7	28.0	25.3	39.4	37.1	34.8	32.5	30.2	
44.3	45.7	47.3	49.0	50.9	52.6	45.7	47.3	49.0	50.9	52.6	54.5	47.3	49.0	50.9	52.6	54.5	
13.7	14.2	14.5	14.7	14.9	15.2	14.2	14.5	14.7	14.9	15.2	15.7	14.5	14.7	14.9	15.2	15.7	
0.77	0.70	0.63	0.57	0.50	0.43	0.80	0.73	0.67	09.0	0.53	0.47	0.83	0.76	99.0	0.62	0.55	
35.0	33.0	30.9	28.7	26.2	23.3	37.8	35.9	33.8	31.5	28.9	26.2	40.4	38.3	35.9	33.5	31.1	
45.7	47.2	48.8		52.5	54.2	47.2	48.8	50.7	52.5	54.2	56.2	48.8	50.7	52.5	54.2	56.2	
12.8	13.1	13.3	13.5	13.7	14.2	13.1	13.3	13.5	13.7	14.2	14.4	13.3	13.5	13.7	14.2	14.4	
0.78	0.71	0.63	0.57	0.50	0.44	0.80	0.73	99.0	09.0	0.53	0.47	0.82	0.75	0.68	0.62	0.55	
36.7	34.4	31.8	29.8	27.2	24.4	39.0	36.9	34.8	32.4	29.7	27.1	41.4	39.5	37.0	34.4	32.1	
46.9	48.6	50.4	52.4	54.2	55.7	48.6	50.4	52.4	54.2	55.7	58.0	50.4	52.4	54.2	55.7	58.0	
18	19	20	21	22	23	19	20	21	22	23	24	20	21	22	23	24	
\vdash		1		1	1	_		1	1	1	1	-				1	1

CITY T/I: TOTAL INPUT

Factor for Various Air Flow

		CMM	120	140	160
PEH-15MYA-EU	AIK VOLUME	S/7	2,000	2,334	2,660
CINIT	CAPACITY		0.989	1.0	1.011
	TOTAL INPUT	L L	1.015	1.0	0.989

26

Cooling Capacity (Standard Air Flow) PE-20MYC-EU

												ď	OUTDOOR DB°C	B°C										
INDOOR	NDOOR		20.0				25.0				30.0				35.0			4	40.0			46.0		
D. BO	WB °C	Q KW	SHCkW	붛	T/I kW	W W W	SHCKW	붛	T/I kW	Q KW	SHCkW	SHF T/I	NX I	Κ	SHCKW SHF	1	kw Q kw	/ SHCkW	SHF	T/I kW	Q KW	SHCkW	SHF	T/I kW
	15	9:29	39.2	0.71	17.7	54.0	38.4	0.71	18.5	52.2	37.4	0.72	19.8 5	50.2 36.	3.2 0.72	21	.1 47.8	35.3	0.74	22.9	45.0	33.9	0.75	24.6
20	16	8'.29	36.4	0.63	17.9	56.2	35.7	0.64	18.7	54.2	34.6	0.64	20.1 5	52.0 33.	3.4 0.64	21	.4 49.4	32.2	0.65	23.1	46.6	30.9	99.0	24.9
	17	0.09	33.3	0.56	18.1	58.2	32.6	0.56	19.0	56.2	31.5	0.56	20.1	53.8 30	30.2 0.56	56 21.6	6 51.2	29.0	0.57	23.3	48.2	27.6	0.57	25.1
	15	55.6	45.1	0.81	17.7	54.0	44.3	0.82	18.5	52.2	43.7	0.84	19.8	50.2 42	42.8 0.85	35 21.1	1 47.8	3 41.7	0.87	22.9	45.0	40.2	0.89	24.6
	16	57.8	42.5	0.74	17.9	56.2	41.9	0.75	18.7	54.2	41.0	0.76	20.1 5	52.0 36	39.9 0.77	7 21.4	4 49.4	38.8	0.78	23.1	46.6	37.4	0.80	24.9
22	17	0.09	39.6	99.0	18.1	58.2	39.0	0.67	19.0	56.2	38.0	0.68	20.1 5	53.8 36	36.6 0.68	38 21.6	51.2	35.7	0.70	23.3	48.2	34.3	0.71	25.1
	18	62.2	36.5	0.59	18.1	60.4	35.9	0.59	19.2	58.2	34.9	0.60	20.3 5	55.8 33	33.8 0.61	31 21.8	8 53.0	32.7	0.62	23.5	49.8	31.2	0.63	25.3
	19	64.2	33.0	0.51	18.3	62.4	32.4	0.52	19.4	60.2	31.6	0.52	20.5	57.6 30	30.6 0.53	53 22.0	0 54.6	3 29.3	0.54	23.8	51.4	27.8	0.54	25.5
	16	8.73	49.2	0.85	17.9	56.2	48.4	98.0	18.7	54.2	47.5	0.88	20.1	52.0 46	46.4 0.89	39 21.4	4 49.4	45.3	0.92	23.1	46.6	43.9	0.94	24.9
	17	0.09	46.1	0.77	18.1	58.2	45.1	0.78	19.0	56.2	44.3	0.79	20.1	53.8 43	43.1 0.80	30 21.6	51.2	42.2	0.82	23.3	48.2	40.8	0.85	25.1
24	18	62.2	42.6	99.0	18.1	60.4	41.7	69.0	19.2	58.2	40.8	0.70	20.3	55.8 39	39.7 0.71	71 21.8	8 53.0	38.8	0.73	23.5	49.8	37.5	0.75	25.3
	19	64.2	39.3	0.61	18.3	62.4	38.4	0.61	19.4	60.2	37.5	0.62	20.5	57.6 36	36.3 0.63	3 22.0	0 54.6	35.3	0.65	23.8	51.4	34.0	99.0	25.5
	20	69.2	37.3	0.54	18.5	67.2	36.2	0.54	19.6	64.8	35.3	0.54	20.7 6	62.0 3	34.1 0.55	55 22.2	2 58.8	32.9	0.56	24.0	55.2	31.5	0.57	25.7
	21	69.2	32.3	0.47	18.7	67.2	31.2	0.46	19.8	64.8	30.2	0.47	20.9	62.0 29	29.1 0.47	7 22.5	5 58.8	3 27.9	0.48	24.2	55.2	26.5	0.48	26.2
	18	62.2	48.5	0.78	18.1	60.4	47.7	0.79	19.2	58.2	46.9	0.81	20.3	55.8 45	45.8 0.82	32 21.8	8 53.0	44.9	0.85	23.5	49.8	43.4	0.87	25.3
. 32	19	64.2	45.2	0.70	18.3	62.4	44.6	0.71	19.4	60.2	43.6	0.72	20.5	57.6 42.	2.4 0.74	74 22.0	0 54.6	41.4	0.76	23.8	51.4	40.2	0.78	25.5
56	20	69.2	43.5	0.63	18.5	67.2	42.9	0.64	19.6	64.8	41.7	0.64	20.7 6	62.0 40	40.3 0.65	35 22.2	2 58.8	39.4	0.67	24.0	55.2	38.1	69.0	25.7
	21	69.2	39.2	0.57	18.7	67.2	38.6	0.57	19.8	64.8	37.5	0.58	20.9	62.0 36	36.3 0.58	38 22.5	5 58.8	35.3	0.60	24.2	55.2	34.0	0.62	26.2
	22	71.6	36.0	0.50	19.0	69.4	35.3	0.51	20.1	0.79	34.4	0.51	21.4 6	64.0 33	33.2 0.52	52 22.7	7 60.8	32.2	0.53	24.4	57.2	30.9	0.54	26.4
	23	73.8	32.5	0.44	19.2	71.8	31.8	0.44	20.3	69.2	31.0	0.45	21.6 6	66.2 30	30.1 0.45	15 23.1	1 62.8	3 28.9	0.46	24.9	29.0	27.4	0.47	26.8
	19	64.2	52.0	0.81	18.3	62.4	51.1	0.82	19.4	60.2	9.05	0.84	20.5	57.6 49	49.6 0.86	36 22.0	0 54.6	3 48.4	0.89	23.8	51.4	46.9	0.91	25.5
	20	69.2	50.8	0.73	18.5	67.2	50.0	0.74	19.6	64.8	49.4	0.76	20.7 6	62.0 48	48.3 0.78	78 22.2	2 58.8	3 47.2	0.80	24.0	55.2	45.6	0.83	25.7
28	21	69.2	45.6	99.0	18.7	67.2	45.0	0.67	19.8	64.8	44.3	0.68	20.9	62.0 43	43.4 0.70	70 22.5	5 58.8	3 42.3	0.72	24.2	55.2	40.9	0.74	26.2
	22	71.6	42.7	09.0	19.0	69.4	41.9	09.0	20.1	0.79	41.3	0.62	21.4 6	64.0 40	40.3 0.63	3 22.7	7 60.8	39.2	0.64	24.4	57.2	37.8	99.0	26.4
	23	73.8	39.3	0.53	19.2	71.8	38.7	0.54	20.3	69.2	38.0	0.55	21.6	66.2 37	37.0 0.56	56 23.1	1 62.8	35.8	0.57	24.9	29.0	34.2	0.58	26.8
	24	76.0	35.8	0.47	19.4	73.8	34.9	0.47	20.5	71.4	34.3	0.48	21.8 6	68.4 33	33.4 0.49	19 23.3	3 65.0	32.1	0.49	25.1	61.0	30.5	0.50	27.0
	20	69.2	56.0	0.81	18.5	67.2	55.0	0.82	19.6	64.8	54.1	0.83	20.7 6	62.0 52	52.7 0.85	35 22.2	2 58.8	3 52.1	0.89	24.0	55.2	50.8	0.92	25.7
	21	69.2	51.6	0.75	18.7	67.2	50.7	0.75	19.8	64.8	49.8	0.77	20.9	62.0 48	48.7 0.78	78 22.5	5 58.8	3 47.8	0.81	24.2	55.2	46.4	0.84	26.2
30	22	71.6	48.9	0.68	19.0	69.4	47.8	69.0	20.1	0.79	47.2	0.70	21.4 6	64.0 46	46.0 0.72	72 22.7	7 60.8	3 45.0	0.74	24.4	57.2	43.5	92.0	26.4
	23	73.8	46.0	0.62	19.2	71.8	45.1	0.63	20.3	69.2	44.4	0.64	21.6	66.2 43	43.3 0.65	35 23.1	1 62.8	3 42.0	0.67	24.9	29.0	40.4	69.0	26.8
	24	76.0	42.8	0.56	19.4	73.8	41.9	0.57	20.5	71.4	41.3	0.58	21.8 6	68.4 40	40.3 0.5	.59 23.3	3 65.0	39.0	0.60	25.1	61.0	37.2	0.61	27.0
Note1.	Note1. * Q :COOLING CAPACITY	JLING CA	PACITY		:SENSIE	SHC:SENSIBLE HEAT CAPACITY	T CAPA(∑IT⁄	T/I:TOT/	T/I:TOTAL INPUT														

024400 14	LIVIL	CMM	160	180	200
PE-ZUMITO-EU	AIR VOLUME	S/7	2,660	3,000	3,320
0	CAPACITY		0.976	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

(Use for low ambient cooling parts)

PE-20MYC-EU

													OUTDOOR DB°	R DB°C							
INDOOR	INDOOR		-5.0	0			0.0				5.0				10.0	0			15.0	0	
DB °C	WB °C	Q KW	SHCKW	SHF	T/I kW	Q KW	SHCkW	SH	T/I kW	Q KW	SHCKW	SH	T/I kW	Q KW	SHCKW	SHF	T/I kW	Q KW	SHCKW	SFF	T/I kW
	15	56.4	38.9	69.0	16.5	54.8	37.8	0.69	17.9	52.9	36.5	0.69	19.4	53.4	37.1	0.70	18.6	22.0	39.9	0.70	17.0
20	16	58.5	36.0	0.61	16.7	56.8	34.9	0.61	18.1	54.9	33.8	0.61	19.6	55.4	34.3	0.62	18.9	59.2	37.0	0.63	17.2
	17	60.6	32.7	0.54	16.9	58.8	31.7	0.54	18.4	56.9	30.7	0.54	19.9	57.4	31.3	0.54	19.1	61.4	33.8	0.55	17.2
	15	56.4	44.6	0.79	16.5	54.8	43.3	0.79	17.9	52.9	41.8	0.79	19.4	53.4	42.4	0.80	18.6	57.0	45.6	0.80	17.0
	16	58.5	41.8	0.71	16.7	56.8	40.7	0.72	18.1	54.9	39.5	0.72	19.6	55.4	40.0	0.72	18.9	59.2	42.9	0.73	17.2
22	17	9.09	38.8	0.64	16.9	58.8	37.9	0.64	18.4	6.95	36.9	0.65	19.9	57.4	37.3	0.65	19.1	61.4	39.9	0.65	17.2
	18	62.5	35.9	0.57	17.1	6.09	35.1	0.58	18.6	6'89	34.1	0.58	20.1	59.4	34.4	0.58	19.4	63.6	36.9	0.58	17.4
	19	65.2	33.2	0.51	17.1	63.3	32.2	0.51	18.6	61.0	31.1	0.51	20.4	61.6	31.4	0.51	19.6	65.8	33.5	0.51	17.7
	16	58.5	48.0	0.82	16.7	56.8	46.8	0.82	18.1	54.9	45.6	0.83	19.6	55.4	46.2	0.83	18.9	59.2	49.7	0.84	17.2
	17	9.09	45.1	0.74	16.9	58.8	43.9	0.75	18.4	56.9	42.6	0.75	19.9	57.4	43.3	0.75	19.1	61.4	46.7	92.0	17.2
24	18	62.5	41.8	0.67	17.1	6.09	40.7	0.67	18.6	6'89	39.4	0.67	20.1	59.4	40.1	29.0	19.4	9.69	43.2	89.0	17.4
	19	65.2	39.0	09.0	17.1	63.3	37.9	09.0	18.6	61.0	36.5	09.0	20.4	61.6	37.2	09.0	19.6	8.29	40.1	0.61	17.7
	20	2.69	36.8	0.53	17.3	2.79	35.8	0.53	18.9	65.5	34.6	0.53	20.4	66.2	35.3	0.53	19.9	70.8	38.1	0.54	17.9
	21	2.69	31.9	0.46	17.6	67.7	31.0	0.46	19.1	65.5	30.0	0.46	20.7	66.2	30.7	0.46	19.9	70.8	33.2	0.47	18.1
	18	62.5	47.5	92.0	17.1	6.09	46.2	92.0	18.6	6'89	44.7	0.76	20.1	59.4	45.4	92.0	19.4	63.6	48.9	7.0	17.4
	19	65.2	44.9	69.0	17.1	63.3	43.6	69.0	18.6	61.0	42.0	69.0	20.4	61.6	42.6	69.0	19.6	65.8	45.7	69.0	17.7
56	20	2.69	43.1	0.62	17.3	2.79	41.9	0.62	18.9	65.5	40.5	0.62	20.4	66.2	41.0	0.62	19.9	70.8	43.8	0.62	17.9
	21	2.69	38.9	0.56	17.6	2.79	37.8	0.56	19.1	65.5	36.6	0.56	20.7	66.2	37.0	0.56	19.9	70.8	39.5	0.56	18.1
	22	72.0	35.9	0.50	17.8	70.1	34.9	0.50	19.4	2.79	33.7	0.50	20.9	68.4	34.1	0.50	20.1	73.2	36.5	0.50	18.3
	23	73.9	32.4	0.44	17.8	72.0	31.5	0.44	19.6	8.69	30.6	0.44	21.2	70.7	30.9	0.44	20.4	75.4	33.0	0.44	18.5
	19	65.2	51.4	0.79	17.1	63.3	49.9	0.79	18.6	61.0	48.1	0.79	20.4	61.6	48.9	0.79	19.6	829	52.6	0.80	17.7
	20	69.7	49.7	0.71	17.3	67.7	48.5	0.72	18.9	65.5	47.1	0.72	20.4	66.2	47.7	0.72	19.9	70.8	51.2	0.72	17.9
28	21	69.7	44.5	0.64	17.6	67.7	43.6	0.64	19.1	65.5	42.5	0.65	20.7	66.2	42.9	0.65	19.9	70.8	45.9	0.65	18.1
	22	72.0	42.0	0.58	17.8	70.1	41.0	0.59	19.4	67.7	39.8	0.59	20.9	68.4	40.3	0.59	20.1	73.2	43.1	0.59	18.3
	23	73.9	39.0	0.53	17.8	72.0	38.0	0.53	19.6	8.69	36.9	0.53	21.2	70.7	37.3	0.53	20.4	75.4	39.8	0.53	18.5
	24	75.6	35.7	0.47	18.0	73.8	34.7	0.47	19.6	71.5	33.4	0.47	21.5	72.5	33.9	0.47	20.6	77.6	36.3	0.47	18.5
	20	2.69	25.0	0.79	17.3	2.79	53.4	0.79	18.9	9:59	51.6	0.79	20.4	66.2	52.6	0.79	19.9	70.8	56.5	08.0	17.9
	21	69.7	50.8	0.73	17.6	67.7	49.3	0.73	19.1	65.5	47.7	0.73	20.7	66.2	48.6	0.73	19.9	70.8	52.3	0.74	18.1
30	22	72.0	48.1	0.67	17.8	70.1	46.8	0.67	19.4	67.7	45.2	0.67	20.9	68.4	46.1	0.67	20.1	73.2	49.6	0.68	18.3
	23	73.9	44.9	0.61	17.8	72.0	43.7	0.61	19.6	8.69	42.4	0.61	21.2	70.7	43.3	0.61	20.4	75.4	46.6	0.62	18.5
	24	75.6	41.4	0.55	18.0	73.8	40.4	0.55	19.6	71.5	39.1	0.55	21.5	72.5	40.1	0.55	20.6	77.6	43.3	0.56	18.5
Note1 * Q COOLING CAPACITY	SOO! IN	GAPAC		NHC: SHC	NSIBI F	HFATC	ISIBI E HEAT CAPACITY		TI INDI INDI IT	TIM											

Note1.*Q:COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

	LIVII ON GIV	CMM	160	180	200
FE-20MIT C-EU	AIR VOLUME	S/I	2,660	3,000	3,320
ONITION	CAPACITY		926.0	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	SHC		0.963	1.0	1.044

Cooling Capacity (Standard Air Flow) PEH-20MYA-EU

38.4 0.77 18.4 52.2 34.6 0.77 18.4 0.77 18.4 0.77 18.4 0.77 18.4 0.77 18.4 22.7 34.6 0.44 18.5 34.6 0.64 18.6 54.2 34.6 0.64 18.6 54.2 34.6 0.64 18.9 52.0 33.4 0.64 18.7 30.6 18.8 56.2 31.6 0.65 18.4 32.0 0.65 18.4 32.0 0.65 18.4 32.2 0.65 21.7 42.8 0.67 22.7 46.0 40.6 30.9 0.68 18.0 68.6 21.0 47.8 41.7 0.67 22.7 48.7 0.69 22.0 48.8 0.62 22.0 48.8 0.67 22.0 48.8 0.68 21.0 18.6 48.9 0.69 22.1 48.4 0.69 22.1 48.4 0.69 22.1 48.4 0.60 22.1 48.4 0.60 22.1 48.4 <th< th=""><th>S KW</th><th>1 1 1 #</th><th>20.0 SHCKW</th><th>HS 11</th><th>T/I KW 0</th><th>Q KW</th><th>25.0 SHCKW</th><th>岩</th><th>KW II</th><th>Q KW</th><th>30.0 SHCKW</th><th>OUI SHF 171</th><th>W. W.</th><th></th><th>35.0 SHCKW</th><th>当 生</th><th>1/1 KW</th><th>Z KW</th><th>40.0 SHCKW</th><th> HS</th><th>Z1 KW</th><th>§</th><th>46.0 SHCKW SP</th><th>SHF T/I</th><th>Ž Š</th></th<>	S KW	1 1 1 #	20.0 SHCKW	HS 11	T/I KW 0	Q KW	25.0 SHCKW	岩	KW II	Q KW	30.0 SHCKW	OUI SHF 171	W. W.		35.0 SHCKW	当 生	1/1 KW	Z KW	40.0 SHCKW	HS	Z1 KW	§	46.0 SHCKW SP	SHF T/I	Ž Š
35.7 0.64 186 64.2 34.6 189 62.0 189 64.2 18.6 18	39.2 0.71 17.5	0.71 17.5	17.5	4	ill ro	1				2.2			9.7	0.2	-	1	-	7.8	-	1	+-	2.0	+	5	: 🚓
32.6 0.56 18.6 56.2 31.5 0.56 18.9 53.6 0.56 21.4 51.2 50.7 52.7 45.0 0.57 22.1 45.0 40.2 40.8 40.8 20.2 41.7 0.80 41.7 0.85 21.0 47.8 41.7 0.87 22.7 45.0 40.2 40.8 40.8 41.7 0.87 22.7 45.0 40.2 40.8 40.8 21.4 41.7 0.87 22.7 45.0 0.80 20.8 40.8 21.8 21.8 30.8 21.8 30.8 21.8 30.8 21.8 30.7 0.7 22.1 48.7 30.8 30.8 30.7 30.7 30.7 30.8 30.8 30.7 30.7 30.7 30.8 30.8 30.8 30.7 30.7 30.8 30.8 30.8 30.7 30.7 30.8 30.8 30.8 30.7 30.8 30.8 30.8 30.8 30.8 30.8 30.8	57.8 36.4 0.63 17.7 5	0.63 17.7	17.7		5	56.2		0.64		7	9		6	0	4		21.2		7	0.65	ල.	9	6		ω
44.3 0.82 1.84 6.22 4.37 0.84 1.97 6.02 4.28 0.86 4.10 4.13 0.81 4.14 0.87 4.14 0.10 4.14 0.07 2.12 4.14 0.17 2.12 4.14 0.17 2.12 4.14 0.17 2.12 4.14 0.17 2.12 4.14 0.17 2.12 4.14 0.17 2.14 6.12 3.14 0.07 2.14 4.14 0.07 2.14 4.15 0.07 2.14 4.14 0.07 2.14 0.17 2.14 6.14 3.14 0.14 <th< td=""><td>60.0 33.3 0.56 17.9 58</td><td>0.56 17.9</td><td>17.9</td><td>-</td><td>1 22</td><td>58.2</td><td>-</td><td>-</td><td>_∞</td><td>2</td><td>5.</td><td></td><td>6</td><td>8</td><td></td><td>.56</td><td>21.4</td><td>51.2</td><td>0</td><td>0.57</td><td>-</td><td>2</td><td>9.</td><td></td><td>_</td></th<>	60.0 33.3 0.56 17.9 58	0.56 17.9	17.9	-	1 22	58.2	-	-	_∞	2	5.		6	8		.56	21.4	51.2	0	0.57	-	2	9.		_
41.9 0.75 186 64.2 41.0 0.76 189 62.0 39.0 0.77 21.2 484 38.0 0.75 41.6 0.75 41.9 0.75 18.6 64.2 41.0 0.76 41.9 60.0 48.4 60.0 68.3 3.8 6.0 32.7 0.70 22.3 46.4 3.0 0.0 68.3 3.8 6.0 32.7 0.70 22.3 46.4 3.0 0.0 68.2 3.0 6.0 3.0 46.4 30.6 0.23 21.0 46.0 20.2 20.3 46.4 46.2 30.2 32.7 0.70 20.1 46.4 0.89 21.2 46.4 46.2 30.2 46.4 46.2 30.2 30.4 46.0 46.2	55.6 45.1 0.81 17.5 54	0.81 17.5	17.5		2	54.0				2	_			2	8		21.0	47.8		0.87					4
39.0 0.67 18.8 56.2 38.0 0.68 19.9 53.8 0.68 19.4 51.8 51.0 51.0 51.1 48.2 33.0 0.7 51.2 65.0 23.3 49.0 23.1 48.2 0.59 13.0 66.2 34.0 0.05 20.1 55.8 33.8 0.64 21.2 69.2 22.3 48.2 31.2 0.65 32.4 0.56 18.0 68.2 44.7 0.88 18.2 62.0 43.2 0.64 46.3 0.92 22.3 48.6 0.99 45.1 0.06 18.0 62.0 43.1 0.07 20.1 45.1 0.07 20.1 45.2 62.0 20.2 48.4 60.2 20.2 48.6 60.2 20.2 48.6 60.2 20.2 48.6 60.2 20.2 48.6 60.2 20.2 48.6 60.2 20.2 48.6 60.2 60.2 49.2 46.2 60.2 40.2 </td <td>57.8 42.5 0.74 17.7 56</td> <td>0.74 17.7</td> <td>17.7</td> <td></td> <td>26</td> <td>56.2</td> <td></td> <td>0.75</td> <td></td> <td>7</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>0.77</td> <td>21.2</td> <td>49.4</td> <td>8</td> <td>0.78</td> <td>_</td> <td></td> <td></td> <td></td> <td>(0</td>	57.8 42.5 0.74 17.7 56	0.74 17.7	17.7		26	56.2		0.75		7						0.77	21.2	49.4	8	0.78	_				(0
35.9 0.59 19.0 68.2 34.9 0.60 20.1 65.8 33.8 0.61 21.0 68.2 34.9 0.60 20.1 65.8 33.8 0.61 21.0 63.9 21.2 45.9 20.5 43.9 0.62 23.2 45.9 19.9 65.2 43.9 0.52 23.9 46.8 30.9 21.2 49.4 45.2 0.52 23.9 46.8 30.9 20.4 48.2 0.52 43.9 0.54 49.9 0.52 43.9 0.54 49.9 0.52 40.9 0.54 49.2 0.52 20.2 40.4 0.50 20.2 20.4 40.9 0.52 20.2 40.4 0.09 20.4 42.2 0.52 20.3 40.8 0.07 20.2 60.2 20.7 20.2 20.2 20.7 20.2 20.2 20.7 20.2 20.2 20.2 20.2 20.2 20.2 20.2 20.2 20.2 20.2 20.2 <th< td=""><td>60.0 39.6 0.66 17.9 58</td><td>0.66 17.9</td><td>17.9</td><td>\dashv</td><td>28</td><td></td><td>-</td><td></td><td></td><td>7</td><td></td><td></td><td></td><td></td><td></td><td></td><td>21.4</td><td>51.2</td><td>_</td><td>0.70</td><td>-</td><td>7</td><td></td><td></td><td></td></th<>	60.0 39.6 0.66 17.9 58	0.66 17.9	17.9	\dashv	28		-			7							21.4	51.2	_	0.70	-	7			
32.4 0.52 1.92 6.02 3.04 6.02 2.1 6.02	62.2 36.5 0.59 17.9 60.4	0.59 17.9	17.9		9					2							21.6	53.0		0.62		8			_
48.4 6.86 18.6 64.2 47.5 6.88 18.0 6.89 21.2 49.4 45.3 6.92 22.3 48.6 48.9 6.92 48.4 6.52 44.3 6.078 18.9 58.2 44.1 6.08 18.9 58.2 48.1 6.08 18.9 58.2 48.1 6.08 18.9 6.07 28.2 48.2 6.08 18.0 6.02 28.2 48.1 6.08 21.8 58.2 0.68 23.5 6.04 28.2 48.8 36.2 6.05 28.2 6.05 28.0 38.1 0.55 22.0 58.8 32.9 0.56 22.0 38.1 0.55 22.0 58.8 32.9 0.56 23.0 38.1 0.57 22.0 38.1 0.57 22.0 38.1 0.57 22.0 38.1 0.57 22.0 38.1 0.56 22.0 38.1 0.56 22.0 38.1 22.0 38.8 22.0 38.8 23.0 <t< td=""><td>64.2 33.0 0.51 18.1 62.4</td><td>0.51 18.1</td><td>18.1</td><td></td><td>62</td><td></td><td></td><td></td><td>-</td><td>-</td><td></td><td></td><td>-</td><td>9</td><td></td><td>-</td><td>21.8</td><td>54.6</td><td>က</td><td>0.54</td><td>2</td><td>-</td><td>89</td><td></td><td>_</td></t<>	64.2 33.0 0.51 18.1 62.4	0.51 18.1	18.1		62				-	-			-	9		-	21.8	54.6	က	0.54	2	-	89		_
44.1 6.08 18.8 6.62 44.3 0.79 19.9 53.8 43.1 0.80 21.4 51.2 42.0 0.82 23.1 48.2 48.9 0.79 19.9 53.8 0.71 21.6 53.0 0.82 0.93 0.82 0.93 0.82 0.93 0.83 0.93 0.84 0.75 0.83 0.71 21.6 53.0 0.82 0.29 0.74 0.83 0.75 0.83 0.83 0.83 0.83 0.85 0.84 0.85 0.85 0.84 0.85 <th< td=""><td>57.8 49.2 0.85 17.7 56.2</td><td>0.85 17.7</td><td>17.7</td><td></td><td>56</td><td></td><td></td><td>98.0</td><td></td><td>54.2</td><td>.5</td><td></td><td>6</td><td>0</td><td>4</td><td></td><td>21.2</td><td></td><td>3</td><td>0.92</td><td>6</td><td>9</td><td>6</td><td></td><td>(0</td></th<>	57.8 49.2 0.85 17.7 56.2	0.85 17.7	17.7		56			98.0		54.2	.5		6	0	4		21.2		3	0.92	6	9	6		(0
41.7 6.66 19.0 68.2 40.6 6.7 5.6 30.7 6.7 5.0 6.8 6.7 5.0 6.0 4.0 6.6 4.0 6.0 4.0 6	60.0 46.1 0.77 17.9 58.2	0.77 17.9	17.9		58					2	က		6	8			21.4		2	0.82	1	2	8		m
38.4 0.61 19.2 60.2 37.5 0.62 36.3 0.63 21.6 36.3 0.63 21.6 36.3 0.64 36.3 0.64 36.4 36.4 36.4 36.4 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 36.4 36.5 <th< td=""><td>62.2 42.6 0.68 17.9 60.4</td><td>0.68 17.9</td><td>17.9</td><td></td><td>.09</td><td></td><td></td><td></td><td></td><td>2</td><td>8</td><td></td><td>-</td><td>8</td><td></td><td></td><td>21.6</td><td>53.0</td><td>8</td><td>0.73</td><td>3</td><td>8</td><td></td><td></td><td>_</td></th<>	62.2 42.6 0.68 17.9 60.4	0.68 17.9	17.9		.09					2	8		-	8			21.6	53.0	8	0.73	3	8			_
36.2 0.54 19.4 64.8 35.3 0.54 20.5 22.0 38.0 20.5 62.0 31.2 65.0 52.0 58.0 62.0 62.0 62.0 22.0 58.0 62.0 62.0 62.0 20.1 65.0 62.0 <th< td=""><td>64.2 39.3 0.61 18.1 62.4</td><td>0.61 18.1</td><td>18.1</td><td></td><td>62.</td><td></td><td></td><td></td><td></td><td>2</td><td>2</td><td></td><td></td><td>9.</td><td></td><td></td><td>21.8</td><td>54.6</td><td>3</td><td>0.65</td><td>2</td><td></td><td></td><td></td><td>~</td></th<>	64.2 39.3 0.61 18.1 62.4	0.61 18.1	18.1		62.					2	2			9.			21.8	54.6	3	0.65	2				~
44.6 6.46 6.48 6.40 <th< td=""><td>69.2 37.3 0.54 18.4 67.</td><td>0.54 18.4 67</td><td>18.4 67</td><td>. 67</td><td>67.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>2</td><td>0</td><td>_</td><td>0.55</td><td>22.0</td><td>58.8</td><td>6</td><td>0.56</td><td>8</td><td>2</td><td>0</td><td></td><td>10</td></th<>	69.2 37.3 0.54 18.4 67.	0.54 18.4 67	18.4 67	. 67	67.								2	0	_	0.55	22.0	58.8	6	0.56	8	2	0		10
44.6 0.04 <th< td=""><td>69.2 32.3 0.47 18.6 67.</td><td>0.47 18.6 67</td><td>18.6 67</td><td>. 67</td><td>67.</td><td></td><td></td><td></td><td></td><td>64.8</td><td></td><td></td><td></td><td>0</td><td>_</td><td></td><td>22.2</td><td>58.8</td><td>6.</td><td>0.48</td><td></td><td>2</td><td></td><td></td><td>_</td></th<>	69.2 32.3 0.47 18.6 67.	0.47 18.6 67	18.6 67	. 67	67.					64.8				0	_		22.2	58.8	6.	0.48		2			_
44.6 0.71 19.2 60.2 43.6 0.72 42.4 0.74 21.8 54.6 41.4 0.76 23.5 51.4 40.7 0.74 20.4 0.74 20.3 64.6 20.5 62.0 40.3 0.65 22.0 58.8 39.4 0.67 23.8 55.2 38.1 0.69 38.6 0.57 19.7 64.8 37.5 0.58 20.7 62.0 36.3 0.52 58.8 35.3 0.60 24.0 56.2 38.0 0.67 37.2 0.69 32.0 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 30.9 0.67 30.0 60.8 30.0 60.8 30.0 60.8 30.0 60.8 30.0 60.8 30.0 60.8 30.0 60.8 30.0 60.8 30.2 60.8 30.2 60.8 30.2 60.8 20.2 60.8 20.2 60.8 20.8 60	62.2 48.5 0.78 17.9 60.4	0.78 17.9	17.9		7.09			0.79		2	6			8			21.6	53.0	6	0.85		8	4		_
42.9 0.64 19.4 64.8 41.7 0.64 20.5 62.0 40.6 22.0 58.8 39.4 0.67 23.8 55.2 38.1 0.69 38.6 0.57 19.7 64.8 37.5 62.0 36.3 0.58 22.2 58.8 35.3 0.60 24.0 55.2 34.0 0.62 34.0 0.62 36.2 60.8 32.2 0.53 24.2 57.2 34.0 0.62 34.0 0.62 22.5 60.8 32.2 0.53 24.2 57.2 34.0 0.62 36.0 32.2 62.0 32.2 62.0 62.0 30.1 0.46 22.2 60.8 22.2 60.8 22.2 60.8 27.4 47.7 30.0 52.4 40.7 50.8 52.4 40.4 50.6 50.4 40.8 0.78 22.2 58.8 47.2 60.8 27.4 40.7 50.8 52.2 58.8 47.2 60.8 40.4 40	64.2 45.2 0.70 18.1 62.	0.70 18.1 62	18.1 62	62	62.						9			9	4		21.8	54.6		0.76	2				ω.
38.6 0.57 19.7 64.8 37.5 0.58 20.7 6.58 36.3 0.58 35.3 0.69 24.0 55.2 34.0 0.50 24.0 36.2 36.8 35.3 0.60 24.0 56.2 36.3 0.68 32.2 0.65 34.0 0.67 34.0 0.67 34.2 0.62 22.5 60.8 32.2 0.53 24.2 57.2 30.9 0.54 31.8 0.44 20.1 69.2 31.0 0.45 21.4 66.2 30.1 0.45 22.5 60.8 32.2 0.63 27.2 67.0 48.0 0.78 22.5 62.8 48.4 0.89 27.4 48.4 0.89 27.4 48.0 0.78 27.5 68.8 47.2 0.80 27.4 48.9 0.77 27.2 68.8 47.2 0.80 23.6 49.9 0.74 48.9 0.72 22.9 68.8 47.2 0.80 27.4 48.9 0.	69.2 43.5 0.63 18.4 67.3	0.63 18.4 67	18.4 67	. 67	67.					8			5	0	3	_	22.0	58.8	4	0.67	8	2	1	25	10
35.3 0.51 19.9 67.0 34.4 0.51 21.2 64.0 32.2 62.5 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 32.2 60.8 20.8 20.8 20.8 60.8 20.8 60.8 20.8 60.8 20.8 60.8 20.8 60.8 20.8 60.8 20.8 60.8 <th< td=""><td>69.2 39.2 0.57 18.6 67.2</td><td>0.57 18.6</td><td>18.6</td><td></td><td>67.</td><td></td><td></td><td>0.57</td><td></td><td>- 8</td><td>.5</td><td></td><td></td><td></td><td></td><td></td><td>22.2</td><td>58.8</td><td>3</td><td>0.60</td><td></td><td>2</td><td></td><td></td><td>0</td></th<>	69.2 39.2 0.57 18.6 67.2	0.57 18.6	18.6		67.			0.57		- 8	.5						22.2	58.8	3	0.60		2			0
31.8 0.44 20.1 69.2 31.0 0.45 22.9 62.9 62.8 62.9 <th< td=""><td>71.6 36.0 0.50 18.8 69.4</td><td>0.50 18.8</td><td>18.8</td><td></td><td>69</td><td></td><td></td><td>0.51</td><td></td><td></td><td>4</td><td></td><td>.2</td><td></td><td>2</td><td></td><td>22.5</td><td>8.09</td><td>2</td><td>0.53</td><td>7</td><td>.2</td><td></td><td></td><td>_</td></th<>	71.6 36.0 0.50 18.8 69.4	0.50 18.8	18.8		69			0.51			4		.2		2		22.5	8.09	2	0.53	7	.2			_
51.1 0.82 19.2 60.2 60.2 60.84 20.3 67.6 0.86 0.18 54.6 48.4 0.89 23.5 51.4 46.9 0.91 50.0 0.74 19.4 64.8 49.4 0.76 20.5 62.0 48.3 0.78 22.0 58.8 47.2 0.80 23.8 55.2 45.6 0.83 45.0 0.67 19.7 64.8 44.3 0.66 20.7 62.0 48.3 0.70 52.2 58.8 42.3 0.72 24.0 55.2 40.9 0.74 41.9 0.60 19.9 67.0 41.3 0.62 21.2 64.0 40.3 0.65 22.9 62.8 32.9 0.64 24.2 50.9 0.74 0.78 22.9 62.8 35.1 62.0 32.1 66.2 37.0 0.56 22.9 62.0 32.1 66.2 32.1 66.2 32.1 66.2 32.1 66.2 32.1 <td>73.8 32.5 0.44 19.0 71</td> <td>0.44 19.0</td> <td>19.0</td> <td></td> <td>7</td> <td></td> <td></td> <td></td> <td></td> <td>2</td> <td>0.</td> <td></td> <td>4.</td> <td>2</td> <td></td> <td></td> <td>22.9</td> <td></td> <td>6</td> <td>0.46</td> <td>9</td> <td>0</td> <td>4.</td> <td></td> <td>(0</td>	73.8 32.5 0.44 19.0 71	0.44 19.0	19.0		7					2	0.		4.	2			22.9		6	0.46	9	0	4.		(0
50.0 0.74 194 64.8 40.4 0.76 20.5 62.0 48.3 0.78 22.0 58.8 47.2 0.80 23.8 45.2 45.6 68.8 47.2 0.80 23.8 47.2 0.80 23.8 47.2 0.80 23.8 45.2 40.9 0.74 40.3 0.60 40.3 0.60 19.9 67.0 41.3 0.62 21.2 64.0 40.3 0.62 22.9 68.8 42.3 0.75 24.6 55.2 40.9 0.74 41.9 0.60 19.9 67.0 41.3 0.62 21.2 64.0 40.3 0.65 62.9 62.	64.2 52.0 0.81 18.1 62.4	0.81 18.1	18.1		62					2	9		3	9.	9		21.8	54.6	4	0.89	5	4.	9 0.	_	~
45.0 0.67 19.7 64.8 44.3 0.68 20.7 62.0 43.4 0.70 22.2 58.8 42.3 0.72 24.0 65.2 40.9 0.77 22.5 68.8 42.3 0.72 24.9 67.0 40.3 0.68 29.5 60.8 39.2 0.64 24.2 57.2 37.8 0.66 38.7 0.64 20.1 69.2 38.0 0.55 21.4 66.2 37.0 0.56 62.9 62.8 35.8 0.57 24.6 59.0 34.2 0.66 38.7 0.47 20.3 71.4 34.3 0.48 23.0 0.56 22.9 62.9 62.8 35.1 0.49 24.8 61.0 30.5 0.50 55.0 0.82 19.4 64.8 21.6 62.0 62.0 62.0 52.0 68.8 47.8 0.89 23.8 65.2 50.8 50.8 47.8 0.81 24.0 0.80 22.2 <td>69.2 50.8 0.73 18.4 67.</td> <td>0.73 18.4 67</td> <td>18.4 67</td> <td>67</td> <td>29</td> <td>7</td> <td></td> <td></td> <td></td> <td></td> <td>4</td> <td></td> <td>2</td> <td>0</td> <td></td> <td></td> <td>22.0</td> <td>58.8</td> <td>7</td> <td>0.80</td> <td>8</td> <td>7</td> <td></td> <td></td> <td>10</td>	69.2 50.8 0.73 18.4 67.	0.73 18.4 67	18.4 67	67	29	7					4		2	0			22.0	58.8	7	0.80	8	7			10
41.9 0.60 19.9 67.0 41.3 0.62 21.2 64.0 40.3 0.63 22.5 60.8 39.2 0.64 24.2 67.2 37.9 0.66 22.9 62.8 35.8 0.57 24.6 59.0 34.2 0.68 38.7 0.54 20.1 69.2 38.0 0.55 21.4 66.2 37.0 0.56 22.9 62.8 35.8 0.57 24.6 59.0 34.2 0.58 55.0 0.82 19.4 64.8 21.6 68.4 33.4 0.49 23.1 65.0 32.1 0.49 24.8 61.0 30.5 0.50 55.0 0.82 19.4 64.8 20.5 62.0 52.7 0.86 22.0 58.8 47.8 0.81 30.5 50.8 50.8 47.8 0.81 30.8 50.8 40.8 0.82 50.8 40.8 50.8 40.8 0.82 40.8 40.8 40.8 40.8 <td>69.2 45.6 0.66 18.6 67</td> <td>0.66 18.6</td> <td>18.6</td> <td></td> <td>6</td> <td>67.2</td> <td></td> <td>_</td> <td></td> <td></td> <td></td> <td></td> <td>_</td> <td>0</td> <td>4</td> <td>_</td> <td>22.2</td> <td>58.8</td> <td>3</td> <td>0.72</td> <td>_</td> <td>2</td> <td></td> <td>_</td> <td>6</td>	69.2 45.6 0.66 18.6 67	0.66 18.6	18.6		6	67.2		_					_	0	4	_	22.2	58.8	3	0.72	_	2		_	6
38.7 0.54 20.1 69.2 38.0 0.56 22.9 62.9 65.8 65.8 65.9 35.8 0.57 24.6 59.0 34.2 0.58 0.58 62.9 62.9 65.0 35.9 34.2 0.58 65.9 65.0 65.0 34.7 0.59 24.8 65.0 34.2 0.50 25.0 65.0 32.1 65.0 32.1 0.49 24.8 61.0 30.5 65.0 52.7 0.85 22.0 68.8 62.1 0.89 23.8 65.2 60.8 60.8 47.8 0.81 24.0 65.0 80.92 60.8 47.8 0.81 24.0 65.2 60.8 47.8 67.0 67.2 48.4 67.0 67.2 48.7 67.2 68.8 47.8 67.0 67.2 46.4 67.2 68.0 45.0 67.2 67.2 68.0 45.0 67.2 46.4 67.2 68.2 47.2 67.2 47.2 47.2 <t< td=""><td>71.6 42.7 0.60 18.8 69</td><td>0.60 18.8</td><td>18.8</td><td>_</td><td>8</td><td>69.4</td><td>_</td><td>_</td><td>_</td><td>_</td><td></td><td></td><td>7</td><td></td><td></td><td>_</td><td>22.5</td><td>8.09</td><td>2</td><td>0.64</td><td>_</td><td>5</td><td></td><td></td><td>_</td></t<>	71.6 42.7 0.60 18.8 69	0.60 18.8	18.8	_	8	69.4	_	_	_	_			7			_	22.5	8.09	2	0.64	_	5			_
34.9 0.47 20.3 71.4 34.3 0.48 21.6 65.0 23.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 32.1 65.0 47.8 67.0 62.0 48.7 0.78 22.2 58.8 47.8 0.81 24.0 55.2 46.4 0.84 46.0 67.2 48.7 67.2 62.0 47.8 67.2 62.0 67.2 62.0 47.8 67.0 47.2 46.0 67.2 22.2 68.8 47.8 0.81 24.2 67.2 46.4 67.0 46.0 67.2 22.5 60.8 45.0 67.2 47.3 67.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 47.2 <th< td=""><td>73.8 39.3 0.53 19.0 7</td><td>0.53 19.0</td><td>19.0</td><td></td><td><u>`</u></td><td>71.8</td><td></td><td></td><td></td><td>2</td><td></td><td></td><td>4.</td><td></td><td></td><td></td><td>22.9</td><td>62.8</td><td>8</td><td>0.57</td><td></td><td></td><td></td><td></td><td>(0</td></th<>	73.8 39.3 0.53 19.0 7	0.53 19.0	19.0		<u>`</u>	71.8				2			4.				22.9	62.8	8	0.57					(0
55.0 0.82 19.4 64.8 54.1 0.83 20.5 62.0 52.7 0.85 22.0 58.8 52.1 0.89 23.8 55.2 50.8 55.2 60.8 52.1 60.9 23.8 52.1 60.9 23.8 62.1 60.8 47.8 0.7 52.2 68.0 47.8 0.7 46.4 46.0 46.0 67.2 22.5 60.8 45.0 0.74 24.2 45.0 67.2 45.0 67.2 62.0 45.0 67.2 45.0 67.2 67.2 45.0 67.2 67.2 60.8 45.0 0.74 24.2 46.4 0.74 46.0 46.0 0.72 22.5 60.8 45.0 0.74 24.2 43.5 0.76 45.1 66.2 44.4 0.64 21.4 66.2 43.3 0.65 22.9 62.8 42.0 0.67 24.6 59.0 40.4 0.69 41.3 0.57 21.6 62.9 <td>76.0 35.8 0.47 19.2 7</td> <td>0.47 19.2</td> <td>19.2</td> <td></td> <td> </td> <td>73.8</td> <td></td> <td></td> <td>Н</td> <td></td> <td>3</td> <td></td> <td>9:</td> <td>4</td> <td></td> <td></td> <td>23.1</td> <td>65.0</td> <td>1</td> <td>0.49</td> <td>8</td> <td></td> <td></td> <td></td> <td></td>	76.0 35.8 0.47 19.2 7	0.47 19.2	19.2			73.8			Н		3		9:	4			23.1	65.0	1	0.49	8				
50.7 0.75 19.7 64.8 49.8 0.77 20.7 62.0 48.7 0.78 22.2 58.8 47.8 0.81 24.0 55.2 46.4 0.72 22.5 60.8 47.0 0.74 24.2 47.2 43.5 67.0 45.0 0.74 45.0 0.72 22.5 60.8 45.0 0.74 24.2 43.5 0.76 22.5 60.8 45.0 0.74 24.2 43.5 0.76 22.9 62.8 42.0 0.67 24.2 50.0 40.4 0.69 40.3 40.2 22.5 62.8 42.0 0.67 24.6 59.0 40.4 0.69 41.3 0.54 41.3 0.56 22.9 62.8 42.0 0.67 24.6 59.0 40.4 0.69	69.2 56.0 0.81 18.4 6	0.81 18.4	18.4		9	67.2					1		2	0			22.0	58.8	1	0.89	8	2		25	10
47.8 0.69 19.9 67.0 47.2 0.70 21.2 64.0 46.0 0.72 22.5 60.8 45.0 0.74 22.5 60.8 45.0 0.74 24.2 67.2 43.3 0.65 22.9 62.8 42.0 0.67 24.6 59.0 40.4 0.69 41.3 0.58 21.6 68.4 40.3 0.59 23.1 65.0 39.0 0.60 24.8 61.0 37.2 0.61	69.2 51.6 0.75 18.6 6	0.75 18.6	18.6		9						8		7	0			22.2	58.8	80	0.81		7	4		0
45.1 0.63 20.1 69.2 44.4 0.64 21.4 66.2 43.3 0.65 22.9 62.8 42.0 0.67 24.6 69.0 40.4 40.4 40.4 40.3 0.69 23.1 65.0 39.0 0.60 24.8 61.0 37.2 0.61	71.6 48.9 0.68 18.8 6	0.68 18.8	18.8		9	69.4			6		2.		2.					8.09	0	0.74	2	2	2		_
41.9 0.57 20.3 71.4 41.3 0.58 21.6 68.4 40.3 0.59 23.1 65.0 39.0 0.60 24.8 61.0 37.2 0.61	73.8 46.0 0.62 19.0	0.62		19.0		71.8				2	4		4.	2	က		22.9		0	0.67	9	0	4		6
	76.0 42.8 0.56 19.2 7	0.56 19.2	19.2	-		73.8		-	-	-	6.	28	9.	4		.59	23.1	65.0		09.0	8	-	0	-	$\overline{}$

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT

- 12 OXM00 10		CMM	160	180	200
PE-20IMIT C-EU	AIR VOLUME	S/J	2,660	3,000	3,320
	CAPACITY		0.976	1.0	1.025
COOLING	TOTAL INPUT		0.991	1.0	1.009
	CHC		596 U	10	1 044

(Use for low ambient cooling parts)

PEH-20MYA-EU

Heating Capacity (Standard Air Flow)

PEH-20MYA-EU

INDOOR -10.0 -5.0 0.0 DB.°C O.KW T/I KW O.KW T/I KW O.KW T/I KW 15 36.8 12.0 42.8 13.0 49.6 14.3 16 36.6 12.0 42.6 13.0 49.0 14.3 17 36.4 12.0 42.6 13.0 49.0 14.3 18 36.4 12.2 42.4 13.2 49.0 14.5 20 36.0 12.2 42.0 13.2 48.8 14.7 21 36.8 12.2 41.8 13.5 48.6 14.9 21 35.8 12.2 41.8 13.5 48.6 14.9 22 35.6 12.4 41.6 13.5 48.4 15.1 23 35.4 12.4 41.4 13.7 48.0 15.1 24 35.2 12.4 41.4 13.7 48.0 15.3 25 35.0					OUTDOC	OUTDOOR WB°C		
Q kW T/l kW Q kW T/l kW Q kW 36.8 12.0 42.8 13.0 49.6 36.6 12.0 42.6 13.0 49.0 36.4 12.0 42.6 13.0 49.0 36.4 12.2 42.4 13.2 49.0 36.0 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.4 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.0 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		INDOOR	-10	0.0	-5	.0	0.	0.
36.8 12.0 42.8 13.0 49.6 36.6 12.0 42.6 13.0 49.0 36.4 12.0 42.6 13.0 49.2 36.4 12.2 42.4 13.2 49.0 36.2 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.2 12.4 41.4 13.7 48.2 35.0 12.4 41.2 13.7 48.0 35.0 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.4 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		DB °C	Q KW	T/I kW	Ø K∛	T/I kW	Q KW	T/I kW
36.6 12.0 42.6 13.0 49.0 36.4 12.0 42.6 13.0 49.2 36.4 12.2 42.4 13.2 49.0 36.2 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.2 13.7 48.0 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		15	36.8	12.0	42.8	13.0	49.6	14.3
36.4 12.0 42.6 13.0 49.2 36.4 12.2 42.4 13.2 49.0 36.2 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		16	36.6	12.0	42.6	13.0	49.0	14.3
36.4 12.2 42.4 13.2 49.0 36.2 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.0 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		17	36.4	12.0	42.6	13.0	49.2	14.5
36.2 12.2 42.2 13.2 48.8 36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		18	36.4	12.2	42.4	13.2	49.0	14.5
36.0 12.2 42.0 13.5 48.6 35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		19	36.2	12.2	42.2	13.2	48.8	14.7
35.8 12.2 41.8 13.5 48.6 35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		20	36.0	12.2	42.0	13.5	48.6	14.7
35.6 12.4 41.6 13.5 48.4 35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		21	35.8	12.2	41.8	13.5	48.6	14.9
35.4 12.4 41.4 13.7 48.2 35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		22	35.6	12.4	41.6	13.5	48.4	15.1
35.2 12.4 41.2 13.7 48.0 35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		23	35.4	12.4	41.4	13.7	48.2	15.1
35.0 12.4 41.0 13.9 47.8 34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		24	35.2	12.4	41.2	13.7	48.0	15.3
34.8 12.6 40.8 13.9 47.4 34.6 12.6 40.6 14.1 47.2		25	35.0	12.4	41.0	13.9	47.8	15.5
34.6 12.6 40.6 14.1 47.2		26	34.8	12.6	40.8	13.9	47.4	15.5
		27	34.6	12.6	40.6	14.1	47.2	15.7

	17.3							
_	17.5				OUTDO	OUTDOOR WB°C		
Τ.,	17.7	INDOOR	5.	5.0	10	10.0	15	15.0
1.0	17.9	DB °C	Q KW	T/I kW	Q KW	T/I kW	Q KW	T/I kW
	18.1	15	57.2	15.9	9:59	17.8	74.6	19.9
Π.	18.4	16	57.0	15.7	65.4	17.6	74.4	19.7
Ι_	17.5	17	56.8	16.1	65.2	18.0	74.2	20.1
Ι	17.7	18	9.99	16.1	65.0	18.2	74.0	20.5
Τ.,	17.9	19	56.2	16.4	64.6	18.4	73.8	20.7
Ι_	18.1	20	56.2	16.6	64.4	18.6	73.6	20.9
T.,	18.4	21	26.0	16.8	64.2	18.8	73.2	21.1
Ι.	18.4	22	55.8	16.8	64.0	18.8	72.8	21.3
Ι_	17.7	23	55.6	17.0	63.6	19.0	72.4	21.3
Ι.	17.9	24	55.4	17.2	63.4	19.3	72.2	21.5
I	18.1	25	55.2	17.4	63.2	19.5	71.8	21.7
١	18.4	26	54.8	17.4	62.8	19.7	71.2	22.1
	18.4	27	54.4	17.6	62.2	19.9	70.8	22.4

Factor for Various Air Flow

		Little Control Control	CMM	160	180	200
	PEH-ZOMYA-EU	AIK VOLUME	S/T	2,660	3,000	3,320
<u> </u>	CAIFAIL	CAPACITY		0.989	1.0	1.008
		TOTAL INPUT	L)	1.025	1.0	0.984

	Z															l	L		Z															*
																																	_	
		T/I kW	16.8	17.1	17.1	16.8	17.1	17.1	17.3	17.5	17.1	17.1	17.3	17.5	17.7	17.9	17.3	17.5	17.7	17.9	18.1	18.4	17.5	17.7	17.9	18.1	18.4	18.4	17.7	17.9	18.1	18.4	18.4	
	0	SHF	0.70	0.63	0.55	0.80	0.73	0.65	0.58	0.51	0.84	92.0	0.68	0.61	0.54	0.47	0.77	69.0	0.62	0.56	0.50	0.44	0.80	0.72	0.65	0.59	0.53	0.47	0.80	0.74	0.68	0.62	0.56	
	15.	SHCkW	39.9	37.0	33.8	45.6	42.9	39.9	36.9	33.5	49.7	46.7	43.2	40.1	38.1	33.2	48.9	45.7	43.8	39.5	36.5	33.0	52.6	51.2	45.9	43.1	39.8	36.3	56.5	52.3	49.6	46.6	43.3	
		ķ	22.0	59.2	61.4	. 0.73	59.2	61.4	63.6	82.9	59.2	61.4	. 9.89	. 8:59	70.8	20.8	9.69	8.59	70.8	8.07	73.2	75.4	65.8	8.02	70.8	73.2	75.4	77.6	8.02	8.02	73.2	75.4	. 9.77	
-		κW	2	_	19.0 6	18.5 5	18.7 5	19.0 6	2	2	18.7 5	19.0	19.2 6	19.5 6	19.7 7	19.7	19.2 6	2	19.7	19.7	19.9	20.2	5	19.7 7	_	19.9	20.2	20.4 7	19.7	19.7	19.9	20.2	4	
		F T/I	.0 18.	18.					19.	19.								19.					.6 19.		.61					-		-	.55 20.	
	10.0	W SHF	0.70	3 0.62	.3 0.54	.4 0.80	0.72	3 0.65	.4 0.58	1 0.51	.2 0.83	.3 0.75	1 0.67	0.60	3 0.53	7 0.46	1 0.76	69.0 9.	0.62	0.56	0.50	9 0.44	9 0.79	7 0.72	9 0.65	3 0.59	3 0.53	9 0.47	3 0.79	5 0.73	1 0.67	3 0.61	0	
		SHCKW	37.1	34.	31	42	40.0	37.3	34	31.4	46	43	40.1	37.2	35.3	30.7	45.4	42	41.0	37.0	34.1	30.9	48	47.7	45	40.3	37.3	33.9	52.6	48.6	46.1	43.3	40.1	
		Q KW	53.4	55.4	57.4	53.4	55.4	57.4	59.4	61.6	55.4	57.4	59.4	61.6	66.2	66.2	59.4	61.6	66.2	66.2	68.4	7.07	61.6	66.2	66.2	68.4	70.7	72.5	66.2	66.2	68.4	70.7	72.5	
ပ္သ		T/I kW	19.2	19.4	19.7	19.2	19.4	19.7	20.0	20.2	19.4	19.7	20.0	20.2	20.2	20.5	20.0	20.2	20.2	20.5	20.7	21.0	20.2	20.2	20.5	20.7	21.0	21.3	20.2	20.5	20.7	21.0	21.3	
OUTDOOR DB		SHF	0.69	0.61	0.54	0.79	0.72	0.65	0.58	0.51	0.83	0.75	0.67	0.60	0.53	0.46	0.76	0.69	0.62	0.56	0.50	0.44	0.79	0.72	0.65	0.59	0.53	0.47	0.79	0.73	0.67	0.61	0.55	INPUT
OUTD	5.0	SHCKW	36.5	33.8	30.7	41.8	39.5	36.9	34.1	31.1	45.6	42.6	39.4	36.5	34.6	30.0	44.7	42.0	40.5	36.6	33.7	30.6	48.1	47.1	42.5	39.8	36.9	33.4	51.6	47.7	45.2	42.4	39.1	T/I:TOTAL INPUT
		Q KW	52.9	54.9	6.99	52.9	54.9	6.99	58.9	61.0	54.9	6.99	58.9	0.19	65.5	65.5	58.9	0.19	65.5	65.5	67.7	8.69	61.0	65.5	65.5	2.79	8.69	71.5	65.5	65.5	2.79	8.69	71.5	1.1/1
-		Κ	17.7	18.0	18.2	17.7	18.0	18.2	18.5	18.5	18.0	18.2	18.5	18.5	18.7	18.9	18.5	18.5	18.7	18.9	19.2	19.4	18.5	18.7	18.9	19.2	19.4	19.4	18.7	18.9	19.2	19.4	19.4	CITY
		SHF T/I	0.69	0.61	0.54 1	0.79	0.72	0.64	0.58 1	0.51	0.82	0.75	0.67	0.60	0.53 1	0.46	0.76	0.69	0.62	0.56	0.50	0.44	0.79	0.72	0.64	0.59	0.53 1	0.47	0.79	0.73	0.67	0.61	0.55	SHC:SENSIBLE HEAT CAPACITY
	0.0	_	37.8 0.	6	31.7 0.	3	40.7 0.	37.9 0.	_	2	8	6	40.7 0.	37.9 0.	35.8 0.	31.0 0.	2	43.6 0.	41.9 0.	37.8 0.	6	31.5 0.	6	2	9	41.0 0.	0	34.7 0.	53.4 0.	49.3	46.8 0.	43.7 0.	40.4 0.	HEAT
		kW SHCKW		.8	8 31	.8 43.	.8 40	.8 37	.9 35.	.3 32.	.8 46.	.8 43.	.9 40			.7 31	9 46.	3 43	.7 41		34.		.3 49.	.7 48.	.7 43.		.0 38.			-		\dashv		SIBLE
		Ø	54.8	26	58.	54	99	58	09	63	26	28	9	63.3	67.7	67	6.09	63	29	67.7	70.1	72.0	63	67	29	70.1	72	73.8	67.7	67.7	70.1	72.0	73.8	IC:SE
		T/I kW	16.3	16.5	16.7	16.3	16.5	16.7	17.0	17.0	16.5	16.7	17.0	17.0	17.2	17.4	17.0	17.0	17.2	17.4	17.6	17.6	17.0	17.2	17.4	17.6	17.6	17.8	17.2	17.4	17.6	17.6	17.8	Ϋ́
	0.	SHF	0.69	0.61	0.54	62'0	0.71	0.64	0.57	0.51	0.82	0.74	0.67	09'0	0.53	0.46	92'0	69'0	0.62	0.56	0.50	0.44	0.79	0.71	0.64	0.58	0.53	0.47	0.79	0.73	0.67	0.61	0.55	ACITY
	-5	SHCkW	38.9	36.0	32.7	44.6	41.8	38.8	35.9	33.2	48.0	45.1	41.8	39.0	36.8	31.9	47.5	44.9	43.1	38.9	35.9	32.4	51.4	49.7	44.5	42.0	39.0	35.7	55.0	50.8	48.1	44.9	41.4	G CAP
		Q KW	56.4	58.5	9.09	56.4	58.5	9.09	62.5	65.2	68.5	9.09	62.5	65.2	2.69	2.69	62.5	65.2	2.69	2.69	72.0	73.9	65.2	2.69	2.69	72.0	73.9	75.6	2.69	2.69	72.0	73.9	75.6	NITOO
 g	<u> </u>	WBC	15	16	17	15	16	17	18	19	16	17	18	19	20	21	18	19	20	21		23	19	20	21	22	23		20	21	22	23	24	Note1. * Q :COOLING CAP
a COUN	3	DB°C W		70				22					24						56						78						30			Vote1.
			_			_					_						_						_											_

Note1. * Q :COOLING CAPACITY SHC:SENSIBLE HEAT CAPACITY T/I:TOTAL INPUT


COOLING AIR VOLUME CMM 160 180 200 180 200 180 200 180 200 180 200 180 200 180 200 180 200 180 200 180 200 180 200	_	0.	32	6	4
AIR VOLUME	200	3,320	1.025	1.009	1.044
AIR VOLUME CMM L/S CAPACITY TOTAL INPUT SHC	180	3,000	1.0	1.0	1.0
AIR VOLUME CAPACITY TOTAL INPUT SHC	160	2,660	0.976	0.991	0.963
AIR VOL CAPACI TOTAL I	CMM	S/I			
PEH-20MYC-EU COOLING		AIN VOLOIME	CAPACITY	TOTAL INPUT	SHC
1 1				SOCIAG	

	100
<u>}</u>	160
Ē	Chana
Val 1043	
5	

OPERATION RANGE

The range of working temperatures is as below.

Make sure which unit you are using and confirm the range of application.



Note


As an applicable humidity outside standard for both indoors and outdoors, we recommend use within a range of 35-80% relative humidity. However, it is a condition that there is no be dewy in surfaces of electric parts.

- 🗥 Caution:


The use of your air conditioner outside the range of working temperature and humidity can result in serious failure.

FAN PERFORMANCE


PEH-5MYA-EU




PE-7MYC-EU PEH-7MYA-EU




PE-8MYC-EU PEH-8MYA-EU



PE-10MYC-EU PEH-10MYA-EU




PE-15MYC-EU PEH-15MYA-EU



			Airflow								
Total static	Model				-15MYC-E	U, PEH-15	MYA-EU				
pressure	CMM		110	120	130	140	150	160	170		
(Pa)	L/S		1830	2000	2170	2330	2500	2670	2830		
	FAN SPEED	rpm	768	768	768	768	768	-	-		
	PULLEYSIZE	mm	139.7	139.7	139.7	139.7	139.7	-	-		
	(MOTOR SIDE)	inch	5.5	5.5	5.5	5.5	5.5	-	-		
200	PULLEYSIZE	mm	254	254	254	254	254	-	-		
	(FAN SIDE)	inch	10	10	10	10	10	-	-		
	BELTSIZE	inch	B45	B45	B45	B45	B45		-		
	MOTOR	kw							_		
	FAN SPEED	rpm	898	898	898	898	898	898	898		
	PULLEYSIZE	mm	114.3	114.3	114.3	114.3	114.3	114.3	114.3		
	(MOTOR SIDE)	inch	4.5	4.5	4.5	4.5	4.5	4.5	4.5		
300	PULLEYSIZE	mm	177.8	177.8	177.8	177.8	177.8	177.8	177.8		
	(FAN SIDE)	inch	7	7	7	7	7	7	7		
	BELTSIZE	inch	B38X2	B38X2	B38X2	B38X2	B38X2	B38X2	B38X2		
	MOTOR	kw	2.2	2.2	2.2	2.2	2.2	2.2	2.2		
	FAN SPEED	rpm	942	942	942	942	971	971	971		
	PULLEYSIZE	mm	152.4	152.4	152.4	152.4	139.7	139.7	139.7		
	(MOTOR SIDE)	inch	6	6	6	6	5.5	5.5	5.5		
400	PULLEYSIZE	mm	228.6	228.6	228.6	228.6	203.2	203.2	203.2		
	(FAN SIDE)	inch	9	9	9	9	8	8	8		
	BELTSIZE	inch	B44 2.2	B44	B44	B44 2.2	B40X2	3.7	B40X2		
	MOTOR	kw					3.7	1067	3.7		
	FAN SPEED	rpm	1008	1008	1008	1008	1067		1067		
	PULLEYSIZE	mm	127 5	127 5	127 5	127 5	152.4	152.4	152.4		
500	(MOTOR SIDE)	inch	177.8	177.8	177.8	177.8	203.2	203.2	203.2		
300	(FAN SIDE)	mm	7	7	7	7	8	8	8		
	BELT SIZE	inch	B37X2	B37X2	B37X2	B37X2	B40X2	B40X2	B40X2		
	MOTOR	kw	3.7	3.7	3.7	3.7	3.7	3.7	3.7		
	FAN SPEED		1119	1119	1119	1119	1119	1119	1119		
	PULLEYSIZE	rpm mm	139.7	139.7	139.7	139.7	139.7	139.7	139.7		
		inch	5.5	5.5	5.5	5.5	5.5	5.5	5.5		
600	(MOTOR SIDE)	mm	177.8	177.8	177.8	177.8	177.8	177.8	177.8		
000	(FAN SIDE)	inch	7	7	7	7	7	7	7		
	BELT SIZE	inch	B38X2	B38X2	B38X2	B38X2	B38X2	B38X2	B38X2		
	MOTOR	kw	3.7	3.7	3.7	3.7	3.7	3.7	3.7		
	FAN SPEED	rpm	1190	1190	1190	1190		5.1			
	PULLEYSIZE	mm	127	127	127	127		-			
	(MOTOR SIDE)	inch	5	5	5	5					
700	PULLEYSIZE	mm	152.4	152.4	152.4	152.4		-	-		
	(FAN SIDE)	inch	6	6	6	6			-		
	BELT SIZE	inch	B36X2	B36X2	B36X2	B36X2			<u> </u>		
	MOTOR	kw	3.7	3.7	3.7	3.7			-		
	FAN SPEED	rpm	1258	5.7	5.7	-					
	PULLEYSIZE	mm	177.8	-	-	-		-	-		
	(MOTOR SIDE)	inch	7	-					-		
800	PULLEYSIZE	mm	203.2	-				-	-		
	(FAN SIDE)	inch	8						-		
	BELT SIZE	inch	B42	-					-		
	MOTOR	kw	3.7			-		-			
	WICTOR	n.W	5.7								

₩ Std.

PE-20MYC-EU PEH-20MYA-EU




	M1-	1	Airflow PE-20MYC-EU, PEH-20MYA-EU							
Total static	Mode		450					0.40		
pressure (Pa)	CMM		150	160	180 3000	200	220	4000		
(Pa)	L/S		2500 627	2670 627	692	3330 692	3670	4000		
	FAN SPEED PULLEYSIZE	rpm mm	127	127	127	127		-		
	(MOTOR SIDE)	inch	5	5	5	5		H		
200	PULLEYSIZE	mm	279.4	279.4	254	254	-	-		
200	(FAN SIDE)	inch	11	11	10	10	-	-		
	BELT SIZE	inch	B44X2	B44X2	B42X2	B42X2	-			
	MOTOR	kw	3.7	3.7	3.7	3.7		.		
	FAN SPEED	rpm	768	768	773	773	773	773		
	PULLEYSIZE	mm	139.7	139.7	127	127	127	127		
	(MOTOR SIDE)	inch	5.5	5.5	5	5	5	5		
300	PULLEYSIZE	mm	254	254	228.6	228.6	228.6	228.6		
300	(FAN SIDE)	inch	10	10	9	9	9	9		
	BELT SIZE	inch	B43X2	B43X2	B40X2	B40X2	B40X2	B40X2		
		kw	3.7	3.7	3.7	3.7	3.7	3.7		
	MOTOR		942	942	942	942	942	942		
	FAN SPEED	rpm								
	PULLEYSIZE	mm	152.4	152.4	152.4	152.4	152.4	152.4		
	(MOTOR SIDE)	inch	6 228.6	6 228.6	6 228.6	6 228.6	228.6	228.6		
400	PULLEYSIZE	mm	9	9	9	9	9	9		
	(FAN SIDE)		B42X2	B42X2	B42X2	B42X2	B41X2	B41X2		
	BELTSIZE	inch								
	MOTOR	kw	3.7	3.7	3.7	3.7	5.5	5.5		
	FAN SPEED	rpm	1008	1008	1008	1067	1067	1067		
	PULLEYSIZE	mm	127	127	127	152.4	152.4	152.4		
500	(MOTOR SIDE)	inch	5	5	5	6	6	6		
500	PULLEYSIZE	mm	177.8	177.8	177.8	203.2	203.2	203.2		
	(FAN SIDE)	inch	7 B37X2	7 B37X2	7 B37X2	8 B39X2	8	B39X2		
	BELTSIZE	inch					B39X2			
	MOTOR	kw	3.7	3.7	3.7	5.5	5.5	5.5		
	FAN SPEED	rpm	1119	1119	1119	1119	1119	-		
	PULLEYSIZE	mm	139.7	139.7	139.7	139.7	139.7	-		
	(MOTOR SIDE)	inch	5.5	5.5	5.5	5.5	5.5	-		
600	PULLEYSIZE	mm	177.8	177.8	177.8	177.8	177.8	-		
	(FAN SIDE)	inch	7	7	7	7	7			
	BELTSIZE	inch	B37X2	B37X2	B37X2	B37X2	B37X2	-		
	MOTOR	kw	5.5	5.5	5.5	5.5	5.5	-		
	FAN SPEED	rpm	1229	1229	1229	1229	-	-		
	PULLEYSIZE	mm	152.4	152.4	152.4	152.4	-	-		
	(MOTOR SIDE)	inch	6	6	6	6	-	<u> </u>		
700	PULLEYSIZE	mm	177.8	177.8	177.8	177.8	-	-		
	(FAN SIDE)	inch	7	7	7	7	-	-		
	BELTSIZE	inch	B38X2	B38X2	B38X2	B38X2	-	<u> </u>		
	MOTOR	kw	5.5	5.5	5.5	5.5	-	-		
	FAN SPEED	rpm	1258	1258	1258	-	-	-		
	PULLEYSIZE	mm	177.8	177.8	177.8	-	-	-		
	(MOTOR SIDE)	inch	7	7	7	-	-	-		
800	PULLEYSIZE	mm	203.2	203.2	203.2	-	-	-		
	(FAN SIDE)	inch	8	8	8	-	-	-		
	BELTSIZE	inch	B41X2	B41X2	B41X2	-	-	<u> </u>		
	MOTOR	kw	5.5	5.5	5.5	-	-	- 1		

* Std.


Pulley outside dimensions are shown below: (Unit : mm)

(1) Shape of belt groove




Shape of V-belt	Nominal Dia. øP.C	a (°)	w	Lo	К	Ko	е	f	ľ1	ľ2	ľз	V-belt thickness (Reference)
	Over 125 Under 160	34	15.86									
В	Over 160 Under 200	36	16.07	12.5	5.5	9.5	19.0	12.5	0.2~0.5	0.5~1.0	1~2	11
	Over 200	38	16.29									

Sectional plan of V-belt



(2) Shape of motor pulley boss (Unit: mm)



MOTOR CAPACITY (kW)	А	В		С
2.2, 3.7	ϕ 28 ^{+0.028} _{+ 0.007}	31 ^{+ 0.128} _{+ 0.007}	8	+0.018 -0.018
5.5	Φ38 +0.028	41 + 0.128	10	+0.018

SOUND DATA

Indoor units

Sound Levels


	PWL	PWL	PWL	PWL	SPL	OCTAVE BAND FREQ. Hz									
MODEL	dB(A)	dB(A)	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz					
PEH-5MYA-EU	63	55	60.5	57.5	57.5	52.5	50.5	43	34.5	28.5					
PE-7MYC-EU PEH-7MYA-EU	63	55	62	60	54	53	50	42.5	37	31.5					
PE-8MYC-EU PEH-8MYA-EU	64	56	63	61	55	54	51	43.5	38	32.5					
PE-10MYC-EU PEH-10MYA-EU	67	59	62	62.5	58.5	59.5	53	48	43.5	36					
PE-15MYC-EU PEH-15MYA-EU	69	61	25	40	47	52	55	57.5	52	36.5					
PE-20MYC-EU PEH-20MYA-EU	70	62	32	44	49	53.5	56.5	57.5	53	51					

Outdoor units

Sound Levels


Oddila Ecvels											
	PWL	PWL	SPL			00	CTAVE BANI	D FREQ. Hz			
MODEL	dB(A)	dB(A)	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	
PUH-5MYE-EU	68	57	68	58	57	52.5	52	47.5	49	40	
PU-7MYC1-EU PUH-7MYC1-EU	76	65	62	63.5	62	62	60	57.5	54	54	
PU-8MYC1-EU PUH-8MYC1-EU	76	65	62	63.5	62	62	60	57.5	54	54	
PUH-8MYE-EU	76	65	45.4	58	58	58.5	61	60	51.5	47	
PU-10MYC1-EU PUH-10MYC1-EU	76	65	64.5	65	64	62.5	60	57	54.5	53	
PUH-10MYE-EU	76	65	45.4	58	58	58.5	61	60	51.5	47	
PU-15MYC1-EU	78	67	68	72	70	65	60	57	53	49.5	
PU-20MYC1-EU	79	68	66	69	70.5	65	62	59	56.5	53	
PUH-15MYC1-EU	80	69	43	51	59	64	65	64	55	50.5	
PUH-20MYC1-EU	80	69	43	51	59	64.5	65	64	55.5	51.5	

Position mesurement




Outdoor unit

PU(H)




OUTLINE DIMENSIONS


PEH-5




PE(H)-7,8




PE(H)-10





PE(H)-15




PE(H)-20












PU-15






PU-20




PUH-15,20




Note: In the case of installation are shown below, it is possible to use the unit by connecting the duct. However, the pressure loss must be 30Pa (3mmAg) or less.


Duct work is local supply.



WIRING DIAGRAMS

PE-7MYC-EU (STANDARD)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49 C	Internal thermostat (compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
⟨SW1⟩	Switch (on)
⟨SW2⟩	Switch (Fan Hi-Low)
(23WA)	Thermostat (room temp.)
С	Run capacitor
C1, 3 ~ 5	Connector
CR1, 2	Surge killer


- Note:1.The dotted lines show field wiring. 2.The figure in the parentheses show field supply parts.


 - 2. The figure in the parentheses show field supply parts
 3. Color of earth wire is yellow and green twisting.
 4. Not specified color of wire is brown.
 5. Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW2> at local.
 If the Switch <SW2> is not used, the Fan motor (indoor) drives at high speed.
 6. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.


	Symbol	No.	Function	PAC-204RC (Option) terminal no.
		1	Power (Active)	24VAC(L)
		2	Cooling operation	COMP
	TB4	3	Fan operation	FAN HI
		4	Power (Neutral)	24VAC(N)

PE-8,10MYC-EU (STANDARD)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F	Internal thermostat (indoor fan)
49 C	Internal thermostat(compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
(SW1)	Switch (on)
(23WA)	Thermostat (room temp.)
C1~5	Connector
CR1, 2	Surge killer




- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.
 5.Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP
TB4	3	Fan operation	FAN HI
	4	Power (Neutral)	24VAC(N)

PE-15MYC-EU (STANDARD)




Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2	Contactor (fan O/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1, 3, 8	Connector
CR1~3	Surge killer
2	Timer

- Note:1.The dotted lines show field wiring. 2.The figure in the parentheses show field supply parts.
 - 3.Color of earth wire is yellow and green twisting.4.Not specified color of wire is brown.5.Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C1,2>, <51F1,2,3> are installed. Therefore, do not change factory set value of Over current relays.

Symbol		FULLCUOII	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
			COMP1
TB3	3	Cooling operation	COMP2
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PE-20MYC-EU (STANDARD)



Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2,3	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2	Contactor (fan O/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1,2	Over current relay(fanl/D)
51F2,3	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~3, 8	Connector
CR1~3	Surge killer
2	Timer


- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.


 - 5. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C1,2>, <51F1,2,3> are installed. Therefore, do not change factory set value of Over current relays.

Symbol		FULLCUOII	PAC-204RC (Option) terminal no.
		Power (Active)	24VAC(L)
		Cooling operation	COMP1
TB3	3	Cooling operation	COMP2
		Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PE-7MYC-EU (SPECIAL ORDER: ANTI SHORT CYCLE TIMER)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49 C	Internal thermostat (compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
⟨SW1⟩	Switch (on)
⟨SW2⟩	Switch (Fan Hi-Low)
(23WA)	Thermostat (room temp.)
С	Run capacitor
C1, 3~5	Connector
CR1, 2	Surge killer
TM	Timer (Anti short cycle)


Note:1.The dotted lines show field wiring.
2.The figure in the parentheses show field supply parts.
3.Color of earth wire is yellow and green twisting.
4.Not specified color of wire is brown.


- 5.Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW2> at local. If the Switch <SW2> is not used, the Fan motor (indoor) drives at high speed.
- 6. When PAC-204RC is used, Timer(TM) is unneccessary.
- 7. Specification subject to change without notice.

Caution,
1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.


Symbol	No.	Function	PAC-204RC (Option) terminal no.
TB4	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP
	3	Fan operation	FAN HI
	4	Power (Neutral)	24VAC(N)

PE-8,10MYC-EU (SPECIAL ORDER: ANTI SHORT CYCLE TIMER)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F	Internal thermostat (indoor fan)
49 C	Internal thermostat(compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
⟨SW1⟩	Switch (on)
(23WA)	Thermostat (room temp.)
C1~ 5	Connector
CR1, 2	Surge killer
TM	Timer (Anti short cycle)




- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.
 5.When PAC-204RC is used, Timer(TM) is unneccessary.
 - 6. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
TB4	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP
	3	Fan operation	FAN HI
	4	Power (Neutral)	24VAC(N)

PE-15MYC-EU (SPECIAL ORDER: ANTI SHORT CYCLE TIMER)



0	
Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2	Contactor (fan O/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1, 3, 8	Connector
CR1~3	Surge killer
2	Timer
TM	Timer (Anti short cycle.)

- Note:1.The dotted lines show field wiring. 2.The figure in the parentheses show field supply parts.
 - 3. Color of earth wire is yellow and green twisting.

 - 4.Not specified color of wire is brown.
 5.When PAC-204RC is used, Timer(TM)is unneccessary.
 - 6. Specification subject to change without notice.

Caution,

- Caution,


 1.To protect each Fan motor and Compressor from abnormal current,
 Over current relays<51C1,2>,<51F1,2,3>are installed. Therefore,
 do not change factory set value of Over current relays.

 2.To protect the starting Compressor<MC1,2>at the same time, Timer
 <2> is installed. Therefore, do not change factory set value of this Timer.

 3.To protect the starting Compressor<52C1,2>frequently, Timer
 <TM> is installed. Therefore, do not change factory set value of this Time

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP1
TB3	3	Cooling operation	COMP2
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PE-20MYC-EU (SPECIAL ORDER: ANTI SHORT CYCLE TIMER)



Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2,3	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2	Contactor (fan O/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2,3	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~3, 8	Connector
CR1~3	Surge killer
2	Timer
TM	Timer (Anti short cycle.)

Note:1.The dotted lines show field wiring.

2.The dotted lines show held willing.
2.The figure in the parentheses show field supply parts.
3.Color of earth wire is yellow and green twisting.
4.Not specified color of wire is brown.
5.When PAC-204RC is used, Timer(TM)

6. Specification subject to change without notice.


Caution,
1.To protect each Fan motor and Compressor from abnormal current,
Over current relays<51C1,2>,<51F1,2,3>are installed. Therefore,


do not change factory set value of Over current relays.

2.To protect the starting Compressor <MC1,2>at the same time, Timer <2> is installed. Therefore, do not change factory set value of this Tim 3.To protect the starting Compressor<52C1,2> frequently, Timer <TM> is installed. Therefore, do not change factory set value of this Tim 3.To protect the starting Compressor<52C1,2> frequently, Timer <TM> is installed. Therefore, do not change factory set value of this Timer <

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP1
TB3	3	Cooling operation	COMP2
l [4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PE-7MYC-EU (SPECIAL ORDER: LOW AMBIENT COOLING)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2~4	Contactor (fan O/D)
23C	Ambient temperature
TB1~5	Terminal block
CH	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49 C	Internal thermostat(compressor)
49F	Internal thermostat(fan O/D)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
26L	Thermostat (freeze protection)
63 H	High-pressure switch
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
(SW1)	Switch (on)
(SW2)	Switch (Fan Hi-Low)
(23WA)	Thermostat (room temp.)
С	Run capacitor
C1, 3~6	Connector
CR1, 2	Surge killer


- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.

 - 5.Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW2> at local. If the Switch <SW2> is not used, the Fan motor (indoor) drives at high speed.
 - 6. Specification subject to change without notice.


1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
TB4	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP
	3	Fan operation	FAN HI
	4	Power (Neutral)	24VAC(N)

PE-8,10MYC-EU (SPECIAL ORDER: LOW AMBIENT COOLING)



Symbol	Name
МС	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2~4	Contactor (fan O/D)
23C	Ambient temperature
TB1~5	Terminal block
CH	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F1	Internal thermostat (indoor fan)
49F2	Internal thermostat (outdoor fan)
49 C	Internal thermostat(compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
26L	Thermostat (freeze protection)
63 H	High-pressure switch
FZ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
30CZ, FZ	Auxiliary relay (check)
⟨SW1⟩	Switch (on)
(23WA)	Thermostat (room temp.)
C1~6	Connector
CR1, 2	Surge killer




- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.
 5.Specification subject to change without notice.

Caution,

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No	Function	PAC-204RC (Option)	
Syllibol	INO.	i dilololi	terminal no.	
	1	Power (Active)	24VAC(L)	
TB4	2	Cooling operation	COMP	
	3	Fan operation	FAN HI	
	4	Power (Neutral)	24VAC(N)	

PE-15MYC-EU (SPECIAL ORDER: LOW AMBIENT COOLING)



Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2	Contactor (fan O/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2,3	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~3, 8	Connector
CR1~3	Surge killer
2	Timer
26D	Thermostat (ambient temp.)


- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.


 - 5. Specification subject to change without notice.

- 1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C1,2>,<51F1,2> are installed. Therefore, do not change factory set value of Over current relays.
- 2.To protect the starting Compressor <MC1,2>at the same time,Timer <2> is installed. Therefore, do not change factory set value of this Timer.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
		Cooling operation	COMP1
TB3	3	Cooling operation	COMP2
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PE-20MYC-EU (SPECIAL ORDER: LOW AMBIENT COOLING)





Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2,3	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F1	Contactor (fan I/D)
52F2~7	Contactor (fan O/D)
TB1~6	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr1~3	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2~F5	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
FZ1	Auxiliary relay (fanl/D)
30FZ	Auxiliary relay (fanl/D)
CZ1-1,2/2-1,2	Auxiliary relay
30CZ1,2	Auxiliary relay (check)
<sw1></sw1>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~3, 8	Connector
CR1~3	Surge killer
2	Timer
26D1~4	Thermostat (ambient temp.)
FZ2~7	Auxiliary relay (fan O/D)


- Note:1.The dotted lines show field wiring. 2.The figure in the parentheses show field supply parts.
 - 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.
 5.Specification subject to change without notice.


Caution,

- 1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C1,2>,<51F1~5> are installed. Therefore, do not change factory set value of Over current relays.
- 2.To protect the starting Compressor <MC1,2>at the same time,Timer <2> is installed. Therefore, do not change factory set value of this Timer.


	Symbol	No.	Function	PAC-204RC (Option) terminal no.
ſ		1	Power (Active)	24VAC(L)
		2	Cooling operation	COMP1
	TDO	3	Cooling operation	COMP2
ı	TB3	4	Fan operation	FAN HI
ı		5	Power (Neutral)	24VAC(N)

PEH-5MYA-EU (STANDARD)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
MF2	Fan motor (outdoor)
52C	Contactor (compressor)
52F	Contactor (fan I/D)
TB1~4	Terminal block
CH	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F	Internal thermostat(indoor fan)
51C	Over current relay(compressor)
51F1,2	Over current relay(fanl/D,O/D)
63H	High-pressure switch
26D1,2	Thermostat (defrost)
21S4	4-Way valve
FZ	Auxiliary relay (fan)
CZ1,2	Auxiliary relay (compressor)
HZ1,2	Auxiliary relay (4-way valve)
30CZ,FZ	Auxiliary relay (check)
X1	Contactor (fan O/D)
X2,3	Auxiliary relay (defrost)
<sw1></sw1>	Switch (operation mode)
<sw2></sw2>	Switch (on)
<23WA>	Thermostat (room temp.)
C1,2,4,6,7	Connector
T1	Timer (defrost)
CR1,2	Surge killer



Note:1.The dotted lines show field wiring.


- 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
- 4.Not specified color of wire is brown.
- 5. Specification subject to change without notice.


Caution,

1.To protect each Fan motor and Compressor from abnormal current, Over current relays<51C>,<51F1,2>are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No	. Function	PAC-204RC (Option)
Symbol	INO.		terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling operation	COMP1
TB3	3	Revercing Valve	4WV
		for Heating operation	
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-7MYA-EU (STANDARD)





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49 C	Internal thermostat(compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
26D1,2	Thermostat (defrost)
21 S 4	4-Way valve
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
HZ1, 2	Auxiliary relay (4-way valve)
30CZ, FZ	Auxiliary relay (check)
X 1	Contactor (fan O/D)
X 2,3	Auxiliary relay (defrost)
⟨SW1⟩	Switch (operation mode)
⟨SW2⟩	Switch (on)
(SW3)	Switch (Fan Hi-Low)
(23WA)	Thermostat (room temp.)
С	Run capacitor
C1, C3~7	Connector
T1	Timer (defrost)
CR1, 2	Surge killer

- Note:1.The dotted lines show field wiring.

 2.The figure in the parentheses show field supply parts.

 3.Color of earth wire is yellow and green twisting.


 4.Not specified color of wire is brown.


 5.Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW3> at local. If the Switch <SW3> is not used, the Fan motor (indoor) drives at high speed.
 - 6. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.


Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
ТВ3	2	Cooling or Heating operation	COMP
	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-8,10MYA-EU (STANDARD)





	_
Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2.3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F	Internal thermostat (indoor fan)
49 C 51 C	Internal thermostat (compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanI/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
26D1,2	Thermostat (defrost)
21 S 4	4-Way valve
FZ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
HZ1, 2	Auxiliary relay (4-way valve)
30CZ, FZ	Auxiliary relay (check)
X 1	Contactor (fan O/D)
X 2,3	Auxiliary relay (defrost)
(SW1)	Switch (operation mode)
(SW2)	Switch (on)
(23WA)	Thermostat (room temp.)
C1~7	Connector (C5 is PUH-8,10MYC1-EU only.)
T1	Timer (defrost)
CR1, 2	Surge killer



- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.

 - 4.Not specified color of wire is brown.


 5.Specification subject to change without notice.

Caution,

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP
TB4	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-15,20MYA-EU (STANDARD)



Cumbal	Name
Symbol MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2,3	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F	Contactor (compressor)
TB1 ~ 4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2 51F1	Over current relay(compressor)
	Over current relay(fanl/D)
51F2,3	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
26D1~4	Thermostat (defrost)
21S4-1,2	4-Way valve
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	
HZ1,2	Auxiliary relay (heater)
30CZ1,2	Auxiliary relay (check)
X1,2	Contactor (fan O/D)
X3~6	Auxiliary relay (defrost)
<sw1></sw1>	Switch (operation mode)
<sw2></sw2>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~8	Connector
T1,2	Timer (defrost)
2	Timer
CR1~3	Surge killer

- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.

 - 4. Not specified color of wire is brown.


 5. Specification subject to change without notice.

Caution,
1.To protect each Fan motor and Compressor from abnormal current,
Over current relays<51C1,2>,<51F1,2,3> are installed. Therefore,
do not change factory set value of Over current relays.


Symbol		Function	PAC-204RC (Option) terminal no.
		Power (Active)	24VAC(L)
	_	Cooling or Heating operation	COMP1
	3	Cooling or Heating operation	COMP2
TB3	4	Reversing valve for Heating operation	4WV
		Fan operation	FAN HI
	6	Power (Neutral)	24VAC(N)


PEH-5MYA-EU

SPECIAL WIRING: ANTI SHORT CYCLE TIMER., PROTECT FOR COOL AIR BLOW.



PEH-7MYA-EU SPECIAL WIRING: ANTI SHORT CYCLE TIMER., PROTECT FOR COOL AIR BLOW.





Symbol	Name
МС	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 C 52 F	Contactor (fan I/D)
TB1~5	Terminal block
CH F1~3	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49 C	Internal thermostat(compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
26 D 1,2	Thermostat (defrost)
21 S 4	4-Way valve
FΖ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
HZ1, 2	Auxiliary relay (4-way valve)
30CZ, FZ	Auxiliary relay (check)
X 1	Contactor (fan O/D)
X 2,3	Auxiliary relay (defrost)
(SW1)	Switch (operation mode)
⟨SW2⟩	Switch (on)
(SW3)	Switch (Fan Hi-Low)
(23WA)	Thermostat (room temp.)
С	Run capacitor
C1, 3~7	Connector
T1	Timer (defrost)
CR1, 2	Surge killer
TM	Timer (Anti short cycle)


Note:1.The dotted lines show field wiring.
2.The figure in the parentheses show field supply parts.
3.Color of earth wire is yellow and green twisting.
4.Not specified color of wire is brown.


- 5.Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW3> at local. If the Switch <SW3> is not used, the Fan motor (indoor) drives at high speed.
- 6. When PAC-204RC is used, Timer(TM) is unneccessary. 7. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.


Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP
TB4	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-8,10MYA-EU **SPECIAL WIRING: ANTI SHORT CYCLE TIMER.,** PROTECT FOR COOL AIR BLOW.





Symbol	Name
MC	Compressor motor
MF1	Fan motor (indoor)
M F 2,3	Fan motor (outdoor)
52 C	Contactor (compressor)
52 F	Contactor (fan I/D)
TB1~5	Terminal block
СН	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49F	Internal thermostat (indoor fan)
49 C	Internal thermostat (compressor)
51 C	Over current relay (compressor)
51F1,2	Over current relay(fanl/D,O/D)
63 H	High-pressure switch
26L	Thermostat (freeze protection)
26D1,2	Thermostat (defrost)
21 S 4	4-Way valve
FZ	Auxiliary relay (fan)
CZ1, 2	Auxiliary relay (compressor)
HZ1, 2	Auxiliary relay (4-way valve)
30CZ, FZ	Auxiliary relay (check)
X 1	Contactor (fan O/D)
X 2,3	Auxiliary relay (defrost)
⟨SW1⟩	Switch (operation mode)
⟨SW2⟩	Switch (on)
(23WA)	Thermostat (room temp.)
C1~7	Connector (C5 is PUH-8,10MYC-EU only.)
T 1	Timer (defrost)
CR1, 2	Surge killer
TM	Timer (Anti short cycle)




- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.
 5.When PAC-204RC is used, Timer(TM)is unneccessary.

 - 6. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current relays.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP
TB4	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-15,20MYA-EU (SPECIAL WIRING: ANTI SHORT CYCLE TIMER)



 ϕ^3

Symbol	Name
MC1,2	Compressor motor
MF1	Fan motor (indoor)
MF2,3	Fan motor (outdoor)
52C1,2	Contactor (compressor)
52F	Contactor (fan I/D)
TB1~4	Terminal block
CH1,2	Crankcase heater
F1~3	Fuse (3.15A)
Tr	Transformer
49C1,2	Internal thermostat(compressor)
51C1,2	Over current relay(compressor)
51F1	Over current relay(fanl/D)
51F2,3	Over current relay(fanO/D)
63H1,2	High-pressure switch
26L1,2	Thermostat (freeze protection)
26D1~4	Thermostat (defrost)
21S4-1,2	4-Way valve
FZ	Auxiliary relay (fan)
30FZ	Auxiliary relay (fan)
CZ1-1,2/2-1,2	Auxiliary relay
HZ1,2	Auxiliary relay (heater)
30CZ1,2	Auxiliary relay (check)
X1,2	Contactor (fan O/D)
X3~6	Auxiliary relay (defrost)
<sw1></sw1>	Switch (operation mode)
<sw2></sw2>	Switch (on)
<23WA>	Thermostat (room temp.)
C1~8	Connector
T1,2	Timer (defrost)
2	Timer
CR1~3	Surge killer
TM	Timer (Anti short cycle)

OUT DOOF

Note:1.The dotted lines show field wiring.


- 2. The figure in the parentheses show field supply parts.

 3. Color of earth wire is yellow and green twisting.
- 4. Not specified color of wire is brown.
- 5. When PAC-204RC is used, Timer(TM)is unneccessary.
- 6. Specification subject to change without notice.

- 1.To protect each Fan motor and Compressor from abnormal current, Over current relays<51C1,2>,<51F1,2,3>are installed. Therefore, do not change factory set value of Over current relays.
- 2.To protect the starting Compressor <MC1,2>at the same time, Timer <2> is installed. Therefore, do not change factory set value of this Timer.
- 3.To protect the starting Compressor<52C1,2> frequently, Timer <TM> is installed. Therefore, do not change factory set value of this Timer.

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP1
	3	Cooling or Heating operation	COMP2
TB3		Reversing valve for Heating operation	4WV
	5	Fan operation	FAN HI
	6	Power (Neutral)	24VAC(N)

PEH-7MYA-EU (SPECIAL ORDER: LOW AMBIENT COOLING)



Symbol	Name	Symbol	Name
MC	Compressor motor	FZ	Auxiliary relay (fan)
MF1	Fan motor (indoor)	CZ1, 2	Auxiliary relay (compressor)
MF2, 3	Fan motor (outdoor)	HZ1, 2	Auxiliary relay (4-way valve)
52C	Contactor (compressor)	30CZ, FZ	Auxiliary relay (check)
52F1	Contactor (fan I/D)	X1	Contactor (fan O/D)
52F2, 3	Contactor (fan O/D)	X2, 3	Auxiliary relay (defrost)
52F4	Contactor (fan O/D)	<sw1></sw1>	Switch (operation mode)
23C	Ambient temperature	<sw2></sw2>	Switch (on)
TB1~5	Terminal block	<sw3></sw3>	Switch (Fan Hi-Low)
CH	Crankcase heater	<23WA>	Thermostat (room temp.)
F1~3	Fuse (3.15A)	С	Run capacitor
Tr	Transformer	C1, 3~8	Connector
49C	Internal thermostat (compressor)	T1	Timer (defrost)
49F	Internal thermostat (fan O/D)	CR1, 2	Surge killer
51C	Over current relay (compressor)	21S4	4-Way valve
51F1,2	Over current relay(fanl/D,O/D)	26D1, 2	Thermostat (defrost)
63H	High-pressure switch	261	Thermostat (freeze protection)


- Note:1.The dotted lines show field wiring. 2.The figure in the parentheses show field supply parts.

 - 2. The lighte in the parentheses show held supply parts
 3. Color of earth wire is yellow and green twisting.
 4. Not specified color of wire is brown.
 5. Please remove the jumper wire (*Mark) in the above diagram if you use the Switch <SW3> at local. If the Switch <SW3> is not used, the Fan motor (indoor) drives at high speed.
 - 6. Specification subject to change without notice.

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current

opilori commenci commencia			
Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP
TB4	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-8,10MYA-EU (SPECIAL ORDER: LOW AMBIENT COOLING)



Symbol	Name	Symbol	Name
MC	Compressor motor	FZ	Auxiliary relay (fan)
MF1	Fan motor (indoor)	CZ1, 2	Auxiliary relay (compressor)
MF2, 3	Fan motor (outdoor)	HZ1, 2	Auxiliary relay (4-way valve)
52C	Contactor (compressor)	30CZ, FZ	Auxiliary relay (check)
52F1	Contactor (fan I/D)	X1	Contactor (fan O/D)
52F2, 3	Contactor (fan O/D)	X2, 3	Auxiliary relay (defrost)
52F4	Contactor (fan O/D)	<sw1></sw1>	Switch (operation mode)
23C	Ambient temperature	<sw2></sw2>	Switch (on)
TB1~5	Terminal block	<sw3></sw3>	Switch (Fan Hi-Low)
CH	Crankcase heater	<23WA>	Thermostat (room temp.)
F1~3	Fuse (3.15A)	63H	High-pressure switch
Tr	Transformer	C1~8	Connector (C5 is PUH-8,10MYC1-EU only.)
49C	Internal thermostat (compressor)	T1	Timer (defrost)
49F1	Internal thermostat (fan I/D)	CR1, 2	Surge killer
49F2	Internal thermostat (fan O/D)	21S4	4-Way valve
51C	Over current relay (compressor)	26D1, 2	Thermostat (defrost)
51F1,2	Over current relay(fanl/D,O/D)	26L	Thermostat (freeze protection)

- Note:1.The dotted lines show field wiring.
 2.The figure in the parentheses show field supply parts.
 3.Color of earth wire is yellow and green twisting.
 4.Not specified color of wire is brown.


 - 5. Specification subject to change without notice.

Caution,

1.To protect each Fan motor and Compressor from abnormal current, Over current relays <51C>, <51F1,2> are installed. Therefore, do not change factory set value of Over current

Symbol	No.	Function	PAC-204RC (Option) terminal no.
	1	Power (Active)	24VAC(L)
	2	Cooling or Heating operation	COMP
TB4	3	Reversing valve for Heating operation	4WV
	4	Fan operation	FAN HI
	5	Power (Neutral)	24VAC(N)

PEH-15,20MYA-EU (SPECIAL ORDER: LOW AMBIENT COOLING)



Symbol	Name	
MC1,2	Compressor motor	
MF1	Fan motor (indoor)	
MF2,3	Fan motor (outdoor)	
52C1,2	Contactor (compressor)	
52F1	Contactor (fan I/D)	
TB1~6	Terminal block	
CH1,2	Crankcase heater	
F1~3	Fuse (3.15A)	
Tr1~3	Transformer	
49C1,2	Internal thermostat(compressor)	
51C1,2	Over current relay(compressor)	
51F1~5	Over current relay(fanI/D,O/D)	
63H1,2	High-pressure switch	
26L1,2	Thermostat (freeze protection)	
26D1~4	Thermostat (defrost)	
21S4-1,2	4-Way valve	
FZ1,30FZ	Auxiliary relay (fan I/D)	
CZ1-1,2/2-1,2	Auxiliary relay	
HZ1,2	Auxiliary relay (heater)	
30CZ1,2	Auxiliary relay (check)	
X1,2	Contactor (fan O/D)	
X3~6	Auxiliary relay (defrost)	
<sw1></sw1>	Switch (operation mode)	
<sw2></sw2>	Switch (on)	
<23WA>	Thermostat (room temp.)	
C1~8	Connector	
T1,2	Timer (defrost)	
2	Timer	
CR1~3	Surge killer	
26D5~8	Thermostat (ambient temp.)	
52F2~7	Contactor (fan O/D)	
FZ2~7	Auxiliary relay (fan O/D)	

Note:1. The dotted lines show field wiring.

- 2. The figure in the parentheses show field supply parts.
- 3.Color of earth wire is yellow and green twisting.
- 4.Not specified color of wire is brown.
- 5. Specification subject to change without notice.

Caution,


- 1.To protect each Fan motor and Compressor from abnormal current, Over current relays<51C1,2>,<51F1~5>are installed. Therefore, do not change factory set value of Over current relays.
- 2.To protect the starting Compressor <MC1,2>at the same time,Timer <2> is installed. Therefore, do not change factory set value of this Timer.


_ •			
Symbol		Function	PAC-204RC (Option) terminal no.
ТВ3		Power (Active)	24VAC(L)
	_	Cooling or Heating operation	COMP1
	3	Cooling or Heating operation	COMP2
	4	Reversing valve for Heating operation	4WV
	5	Fan operation	FAN HI
	6	Power (Neutral)	24VAC(N)

ELECTRICAL OPERATION FLOW CHARTS

PE-7,8,10MYC-EU

PEH-5MYA-EU, PEH-7,8,10MYA-EU






21S4 ON MF2, 3 OPERATE

Note.

 When the fault of outdoor unit is occurred, the fan(MF1) of indoor unit continues to work. But the unit doesn't work correctly (not cooling and heating). Then, turn off the power supply and check outdoor unit.

PE-15MYC-EU

PE-20MYC-EU




Note. When the fault of outdoor unit is occurred, the fan(MF1) of indoor unit continues to work. But the unit doesn't work correctly (not cooling).

Then, turn off the power supply and check outdoor unit.

When the fault of indoor unit is occurred, both indoor unit and outdoor unit is stop.

PEH-15,20MYA-EU




Note. When the fault of outdoor unit is occurred, the fan(MF1) of indoor unit continues to work. But the unit doesn't work correctly (not cooling).

Then, turn off the power supply and check outdoor unit.


When the fault of indoor unit is occurred, both indoor unit and outdoor unit is stop.

REFRIGERANT SCHEMATICS

PE-7,8,10,15,20MYC-EU



PEH-5,7,8,10,15,20MYA-EU



Note:PEH-15,20MYA-EU is comprised of two refrigerant cycles.

SAFETY & CONTROL DEVICES

PE-7,8,10MYC-EU PE-15,20MYC-EU

ITEM	NO.	PE-7MYC-EU PU-7MYC1-EU	PE-8MYC-EU PU-8MYC1-EU	PE-10MYC-EU PU-10MYC1-EU		
COMPRESSOR OVER CURRENT RELAY	51C	19.0A	22.0A	31.0A		
COMPRESSOR INTERNAL THERMOSTAT	49C	105 ± 5 °C OFF 83 ± 11 °C ON				
HIGH PRESSURE SWITCH	63H	2.94MPa OFF				
INDOOR FAN MOTOR OVER CURRENT RELAY	51F1	5.0A	3.5A	5.0A		
INDOOR FAN MOTOR INTERNAL THERMOSTAT	-	150 °C OFF				
OUTDOOR FAN MOTOR OVER CURRENT RELAY	51F2	2.5A				
OUTDOOR FAN MOTOR INTERNAL THERMOSTAT	-		150 °C OFF			
FUSE	F1~3		3.15A			

ITEM	NO.	PE-15MYC-EU PU-15MYC1-EU	PE-20MYC-EU PU-20MYC1-EU	
COMPRESSOR OVER CURRENT RELAY	51C1,2	22.0A	31.0A	
COMPRESSOR INTERNAL THERMOSTAT	49C	105 ± 5 °C OFF	83 ± 11 °C ON	
HIGH PRESSURE SWITCH	63	3.24MPa OFF		
INDOOR FAN MOTOR OVER CURRENT RELAY	51F1	4.6A	7.2A	
OUTDOOR FAN MOTOR OVER CURRENT RELAY	51F2,3	2.5A		
OUTDOOR FAN MOTOR INTERNAL THERMOSTAT	-	150	°C OFF	
FUSE	F1~3	3.	15A	

PEH-7,8,10MYA-EU PEH-15,20MYA-EU

ITEM	NO. PEH-5MY.		PEH-7MYA-EU PUH-7MYC1-EU	PEH-8MYA-EU PUH-8MYC1-EU PUH-8MYE-EU		
COMPRESSOR OVER CURRENT RELAY	51C	15.0A	19.0A	22.0A		
COMPRESSOR INTERNAL THERMOSTAT	49C	110 ± 5°C OFF 61 ± 9°C ON	105 ± 5°0 83 ± 11			
HIGH PRESSURE SWITCH	63H	2.94MPa OFF				
EDOOT PROTECTOR	26D1	-12 ± 2 °C ON				
FROST PROTECTOR	26D2		6 ± 2 °C OFF			
INDOOR FAN MOTOR OVER CURRENT RELAY	51F1	3.5A	5.0A	3.5A		
INDOOR FAN MOTOR INTERNAL THERMOSTAT	-	150° C OFF				
OUTDOOR FAN MOTOR OVER CURRENT RELAY	51F2	2.5A				
OUTDOOR FAN MOTOR INTERNAL THERMOSTAT	-	150°C OFF				
FUSE	F1~3		3.15A			

ITEM	NO.	PEH-10MYA-EU PUH-10MYC1-EU PUH-10MYE-EU	PEH-15MYA-EU PUH-15MYC1-EU	PEH-20MYA-EU PUH-20MYC1-EU		
COMPRESSOR OVER CURRENT RELAY	51C1,2	31.0A	31.0A			
COMPRESSOR INTERNAL THERMOSTAT	49C	10	5 ± 5 ° C OFF 83	± 11°C ON		
HIGH PRESSURE SWITCH	63H	2.94MPa OFF				
FROOT BROTEOTOR	26D1	-12 ± 2 °C ON				
FROST PROTECTOR	26D2		6 ± 2 °C OFF			
INDOOR FAN MOTOR OVER CURRENT RELAY	51F1	5.0A	4.6A	7.2A		
OUTDOOR FAN MOTOR OVER CURRENT RELAY	51F	2.5A				
OUTDOOR FAN MOTOR INTERNAL THERMOSTAT	-	150° C OFF				
FUSE	F1~3		3.15A			

SPECIAL ORDER

	Cooling only	Model	- PE-7MYC PE-8MYC PE		PE-10MYC	PE-15MYC	PE-20MYC	
Description	Cooling only	Service ref.	-	PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU
Description	Heat numer	Model	PEH-5MYA	PEH-7MYA	PEH-8MYA	PEH-10MYA	PEH-15MYA	PEH-20MYA
	Heat pump	Service ref.	PEH-5MYA-EU	PEH-7MYA-EU	PEH-8MYA-EU	PEH-10MYA-EU	PEH-15MYA-EU	PEH-20MYA-EU
* Low Ambient	Cooling		Release 2000 year	\bigcirc	\circ	\circ	\circ	
Global Remot	e Controller			\bigcirc	\bigcirc	\bigcirc	\bigcirc	\circ
Anti corrosion	ı		\bigcirc	\bigcirc	\circ	\circ	\circ	
(Service refer			(PUH-5MYE-EUS)	(PUH-7MYC-EUS)	(PUH-8MYC-EUS, PUH-8MYE-EUS)	(PUH-10MYC-EUS, PUH-10MYE-EUS)	(PUH-15MYC-EUS)	(PUH-20MYC-EUS)

^{*} Low ambient cooling

It is possible to conduct cooling operation under an outdoor temperature even down to -5 $^{\circ}\text{C}.$

PHYSICAL DATA

PE-7,8,1015,20MYC-EU

[PRODUCT]		PACKAGE AIR COOLED HEATPUMP UNITS				NITS
Product type		17101010		E SERIES	tii oivii o	11110
Product number : Indoor unit	+	PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU
Outdoor unit		PU-7MYC1-EU	PU-8MYC1-EU	PU-10MYC1-EU	PU-15MYC1-EU	PU-20MYC1-EU
Cooling capacity (AS1861)	kW	17.9	22.0	28.8	44.0	57.6
	kW	14.3	17.6	23.0	35.2	46.1
Sensible Cooling capacity (AS1861) Cooling power consumption (Input)	kW	7.2	7.8	10.1	16.9	22.7
Basic temperature condition cooling Indoor	KVV	1.2	_	°C DB/19°C	1	22.1
<u> </u>					VVB	
3				35°C DB		
[ELECTRICAL]						
<indoor unit=""></indoor>						
Design voltage	Volts	240			15	
Cycles	Hz			50		
Power supply	Volts	1PH-240V			I-415V	
Control voltage				240/24		
Voltage change Max.	Volts	240		415		
Voltage change Min.	Volts	220		380		
Fan motor output		0.28(0.21)	0.94(0.70)	1.34(1.0)	2.95(2.2)	4.96(3.7)
Fan motor current	Amps	3.2	1.2	2.0	3.5	4.8
<outdoor unit=""></outdoor>						
Design voltage	Volts			415		
Cycles	Hz			50		
Power supply	Volts			3PH-415V		
Voltage change Max.	Volts	415				
Voltage change Min.	Volts			380		
Fan motor output	HP(kW)	2X0.12(2X0.09)	2X0.2(2	2X0.15)	0.32(0.24)	2X0.32(2X0.24)
Fan motor current	Amps	0	.7	1.0	1.2	2X1.2
[COMPRESSOR]				1		
Make				MITSUBISH	I	
Model		JH519YE	JH521YE	JH527YE	JH521YE	JH527YE
Type			TIC LINE S			
Number of compressor		TILITATE	1	1711(11(1120	2	
Nominal motor	HP(kW)	6.7(5.0)	7.4(5.5)	10.1(7.5)	7.4(5.5)	10.1(7.5)
Locked rotor current	Amps	76	83	85	83	85
Normal run current (AS1861)	Amps	13.0	15.5	19.2	15.5	19.2
Swept volume	cc/rev	149	160.8	201	160.8	201
Bore	mm	140	100.0	ø44.45	100.0	201
Stroke	mm	24.0		25	: O	
Speed		24.0		2900	0.3	
Number of cylinders	rpm		4	5	1	5
Oil charge	ml		00	4500	3000	4500
Type of oil	1111		MOND MS32			
	watts		00100 101332 32	72	62	` '
Crankcase heater	walls		<i>,</i>	12	1 02	72
[REFRIGERATION SYSTEM]				Daa		
Refrigerant	la sa		F.0	R22	I	
Refrigerant charge per circuit	kg	5.7	5.0	8.7	4.8	9.7
Number of refrigerant control			1	0 11	2	<u> </u>
Refrigerant control				Capillary tub	е	
Limit of pipe's length	m			50		
Limit of pipe's height difference	mtrs		In case of inc			
	mtrs	30 (1	In case of ou	<u>ıtdoor unit a</u>	bove indoor	unit)

Product number	Indoor unit		PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU
	Outdoor unit		PU-7MYC1-EU	PU-8MYC1-EU	PU-10MYC1-EU	PU-15MYC1-EU	PU-20MYC1-EU
[INDOOR AIR CIRCUIT]					1		
Number of blowers					2		
Diameter of blowers		mm		250		3	80
Width of blowers		mm	245 275			270	374
Blower drive				Direct driv		Belt	
Fan motor output		kW	0.21	0.70	1.00	2.2	3.7
Fan motor run current		A	3.2	1.2	2.0	3.5	4.8
Air quantity		L/s	1000	1167	1500	2333	3000
External static pressure		Pa	1000	125			00
Supply air dimensions(hxw)		mm	341)	K 1102	341 X 1302	412X1000	1
Return air dimensions(hxw)		mm	5417	248 X 998	1		(1415
[EVAPORATOR]				240 X 000	<u>'</u>	0007	(1+10
Number of evaporator					1		
Face area		ca m	0	42	0.50	0.86	1.00
Rows deep		sq.m	0.	42	0.50		1.00 4
Rows high				15			1 24
Finned length		mm	11	00	1300	1415	1615
Face velocity		m/s	2.2	2.8	3.0	2.7	3.0
Fin per meter		111/3		474/2.11 513/1.95			513/1.95
Fin material thickness		mm		72.11	0.115		010/1.00
Fin material/Type				Alı	ıminium / R	ina	
Tube diameter		mm		7110	9.52	9	
Gauge of copper tube		mm			0.35		
Pipe type				Plain tube		Groov	e tube
Number of circuit				10		16	24
[OUTDOOR AIR CIRCUIT	7						
Number of fans				2		1	2
Diameter of fan		mm		600		9:	54
Blower drive					Direct driv	re	
Quantity of motor				2		1	2
Fan motor output		kW	2X0.09	2X0).15	0.24	2X0.36
Fan motor run current		Α	0.7	1	.0	1.2	2X1.2
Air quantity		L/s	3167	3000	3667	4000	8000
[CONDENSER]							
Number of condensers					2		
Face area		sq.m		2 X 2.1		1.32	1.35
Rows deep			1	1	2	2	2
Rows high			30	32	30	40	30
Finned length		mm	27		2696	1299	1775
Face velocity				1.5	3.0		
Fin per meter/Pitch			474 / 2.7	625 / 1.6	538 / 1.86	6.25	
Fin material thickness		mm			0.115	*	
Fin material/Type				Alu	minium / R	ing	
Tube diameter/Gauge		mm			9.52 / 0.35	5	
Pipe type			(Groove tub	е	Plain	tube
Number of circuit				7	11	i -	6

Product number	duct number Indoor unit			PE-7MYC-EU	PE-8MYC-EU	PE-10MYC-EU	PE-15MYC-EU	PE-20MYC-EU	
	Outo	loor unit		PU-7MYC1-EU	PU-8MYC1-EU	PU-10MYC1-EU	PU-15MYC1-EU	PU-20MYC1-EU	
[ENCLOSURE AND FRAME]									
heigh			mm		428		70	06	
Dimension	Indoor unit	width	mm	14	15	1615	1690	1993	
		depth	mm		650		86	65	
		height	mm		980		1230	961	
Dimension	Outdoor unit	width	mm		1400		998	1996	
dept		depth	mm		700 998				
External finish	(indoor unit)					alvanized			
External finish	(outdoor unit)			Acrylic resin coationg (Color: Munsell 5Y8/1)					
Panel thickness			mm			1.2			
Condense drain	size		mm			25.4			
Weight Indoor u	nit		kg	67	70	84	180	212	
Weight Outdoor	unit		kg	202	205	230	285	360	
Sound pressure level (indoor unit)			dbA	55	56	59	61	62	
Sound pressure level (outdoor unit)			dbA	65	65	65	67	68	
Sound power le	vel (indoor unit)		dbA	63	64	67	69	70	
Sound power le	vel (outdoor unit)		dbA	76	76	76	78	79	

PEH-5,7,8MYA-EU

IDDODUCT!		DACKACE	AID COOL E		
[PRODUCT] Product type		PACKAGE		D HEATPUMP UNITS	
Product type Product number: Indoor unit		PEH-5MYA-EU	PEH SE PEH-7MYA-EU	PEH-8MYA-EU	
Outdoor unit		PUH-5MYE-EU	PUH-7MYC1-EU	PUH-8MYC1-EU PUH-8MYE-EU	
Cooling capacity (AS1861)	kW	14.4	17.9	22.0	
Sensible Cooling capacity (AS1861)	kW	11.5	14.3	17.6	
Cooling power consumption (Input)	kW	6.0	7.2	7.8	
Heating capacity (AS1861)	kW	14.4	18.8	22.0	
Heating power consumption	kW	4.5	6.3	6.5	
Basic temperature condition cooling Indoor	KVV	4.5		/6.5 B/19℃ WB	
Basic temperature condition cooling Outdoor				C DB	
<u>·</u>				C DB	
Basic temperature condition heating Indoor				5/6 °CWB	
Basic temperature condition heating Outdoor	<u> </u>		7 6 0	B/O CVVB	
[ELECTRICAL]					
<indoor unit=""></indoor>					
Design voltage	Volts	415	240	415	
Cycles	Hz	0511		50	
Power supply	Volts	3PH-415V	1PH-240V	3PH-415V	
Control voltage	1/ 1/	445		0/24	
Voltage change Max.	Volts	415	240	415	
Voltage change Min.	Volts	380	220	380	
Fan motor output	HP(kW)	0.6(0.45)	0.28(0.21)	0.94(0.70)	
Fan motor current	Amps	1.1/1.0	3.2	1.2	
<outdoor unit=""></outdoor>) / It			4.5	
Design voltage	Volts	415			
Cycles	Hz			50	
Power supply	Volts			-415V	
Voltage change Max.	Volts			15	
Voltage change Min.	Volts	0.0(0.45)		80	
Fan motor output	HP(kW)	0.2(0.15)	2X0.12	(2X0.09) 0.47(0.35)	
Fan motor current	Amps	1.0		0.7	
[COMPRESSOR]					
Make		Copeland		MITSUBISHI	
Model		CRNQ-0500-TFD	JH519YE	JH521YE	
Туре		HERMETIC	LINE START	(RECIPROCATING)	
Number of compressor					
Nominal motor	HP(kW)	5.0(3.73)	6.7(5.0)	7.4(5.5)	
Locked rotor current	Amps	65	76	83	
Normal run current (AS1861)	Amps	8.6	13.0	15.5	
Swept volume	cc/rev	101.92	149	160.8	
Bore	mm	ø49.78		ø44.45	
Stroke	mm	26.19	24.0	25.9	
Speed	rpm			900	
Number of cylinders	,	2		4	
Oil charge	ml	1952	BIALLOUS	3000	
Type of oil		CALUMET RO 15 OR WITCO 3GS	DIAMOND M	IS32(N-1) OR SUNISO 3GS(D)	
Crankcase heater	watts	40		62	
[REFRIGERATION SYSTEM]					
Refrigerant			R	22	
Refrigerant charge per circuit	kg	5.0	5.7	6.6	
Number of refrigerant controls				1	
Refrigerant control				ary tube	
Reverse cycle valve				valve	
				cycle defrost	
Defrost system	m			50	
	m mtrs	20 (In c	5	-	

Product number	Indoor unit		PEH-5MYA-EU	PEH-7MYA-EU	PEH-8N	IYA-EU
	Outdoor unit		PUH-5MYE-EU	PUH-7MYC1-EU	PUH-8MYC1-EU	PUH-8MYE-EU
[INDOOR AIR CIRCUIT]						
Number of blowers			1		2	
Diameter of blowers		mm		2	50	
Width of blowers		mm	275	245	2	75
Blower drive				Direct	drive	
Fan motor output		kW	0.45	0.21	0	.70
Fan motor run current		Α	1.1/1.0	3.2	1	1.2
Nominal air quantity		L/s	700	1000	1	167
External static pressure		Pa	100		125	
Supply air dimensions(hxw)	mm	342X781	341)	X1102	342X1118
Return air dimensions(hxw	•	mm	248X498		248X998	
[EVAPORATOR]	,					
Number of evaporator					1	
Face area		sq.m	0.3		0.42	
Rows deep				4	4	
Rows high			15		15	
Finned length		mm	780	1100		100
Face velocity		m/s	2.5	2.2		2.8
Fin per meter / pitch			513/1.95	474/2.11		/2.11
Fin material thickness		mm			115	
Fin material/Type				Aluminium / Ring		
Fin coating				NA 510 D*1		
Tube diameter		mm			.52	
Gauge of copper tube		mm		0.	35	
Pipe type			Groove tube	Plai	n tube	Groove tube
Number of circuit			7		10	
[OUTDOOR AIR CIRCUI	T]					
Number of fans			1		2	1
Diameter of fan		mm		600		800
Blower drive				Direc	t drive	
Quantity of motor			1		2	1
Fan motor output		kW	0.35	2X0	0.09	0.35
Fan motor run current		Α	1.2	0	.7	1.2
Nominal air quantity		L/s	1583	27	83	3333
[CONDENSER]						
Number of condensers			1	2	2	1
Face area		sq.m	1.3	2X		1.58
Rows deep					2	
Rows high			44	3	30	44
Finned length		mm	1000		706	1400
Face velocity		m/s	1.56		.35	1.95
Fin per meter/Pitch			513/1.95		/2.11	513 /1.95
Fin material thickness		mm			115	
Fin material/Type					ım / Ring	
Tube diameter/Gauge		mm			/ 0.35	
Pipe type					ve tube	
Number of circuit			11		7	11

Specifications subject to change without noice

^{*1} Corrosion proof property: Salt spray JIS Z 2371, 500hrs Humiditiy test 50C 98% 500hrs.
*2 Corrosion proof property: Salt spray JIS Z 2371, 1000hrs Humiditiy test 50C 98% 1000hrs.

Product numbe	r Indo	or unit		PEH-5MYA-EU	PEH-7MYA-EU	PE-8MYA-EU		
	Outd	loor unit		PUH-5MYE-EU	PUH-7MYC1-EU	PUH-8MYC1-EU	PUH-8MYE-EU	
[ENCLOSURE	AND FRAME]							
		height	mm	428				
Dimension	Dimension Indoor unit		mm	1095	1095 1415			
			mm		65	50		
		height	mm	1175	98	30	1175	
Dimension	Dimension Outdoor unit	width	mm	1000	14	1400		
		depth	mm	550	700		550	
External finish	(indoor unit)			Galvanized steel				
External finish	(outdoor unit)			Acrylic resin coationg (Color: Munsell 5Y8/1)				
Panel thickness	3		mm		1.	.2		
Condense drain	n size		mm		25	.4		
Weight Indoor	unit		kg	60	67	7	0	
Weight Outdoo	r unit		kg	150	211	214	188	
Sound pressure level (indoor unit)			dbA	5	55	5	6	
Sound pressure	Sound pressure level (outdoor unit)			57		65		
Sound power le	evel (indoor unit)		dbA	6	63	6	4	
Sound power le	evel (outdoor unit)		dbA	68		76		

PEH-10,15,20MYA-EU

[PRODUCT]		PACKAGE) HEATPUMP	UNITS
Product type			PEH SE		
Product number : Indoor unit		PEH-10M		PEH-15MYA-EU	PEH-20MYA-EU
Outdoor unit		PUH-10MYC1-EU	PUH-10MYE-EU	PUH-15MYC1-EU	PUH-20MYC1-EU
Cooling capacity (AS1861)	kW	28.		44.0	57.6
Sensible Cooling capacity (AS1861)	kW	23.		35.2	46.0
Cooling power consumption (Input)	kW	10.	.1	16.8	22.7
Heating capacity (AS1861)	kW	28	.8	44.0	57.6
Heating power consumption	kW	8.	3	14.1	19.3
Basic temperature condition cooling Indoor		27°C DB/19°C WB			
Basic temperature condition cooling Outdoor		35°C DB			
Basic temperature condition heating Indoor			21°(C DB	
Basic temperature condition heating Outdoor			7 ℃ DI	B/6 °CWB	
[ELECTRICAL]					
<indoor unit=""></indoor>					
Design voltage	Volts		4	15	
Cycles	Hz		5	50	
Power supply	Volts		3PH-	-415V	
Control voltage			240	0/24	
Voltage change Max.	Volts		41	15	
Voltage change Min.	Volts			30	
Fan motor output	HP(kW)	1.34(1.0)	1.34(1.0)	2.95(2.20)	4.96(3.70)
Fan motor current	Amps	2.0	2.0	4.1	4.7
<outdoor unit=""></outdoor>					
Design voltage	Volts		4	15	
Cycles	Hz			50	
Power supply	Volts		3PH	-415V	
Voltage change Max.	Volts		4	15	
Voltage change Min.	Volts		3	80	
Fan motor output	HP(kW)	2X0.2(2X0.15)	0.47(0.35)		(2X0.35)
Fan motor current	Amps	1.0	1.2	2X	1.2
[COMPRESSOR]					
Make			MITSU	JBISHI	
Model		JH52	7YE	JH521YE	JH527YE
Type		HERMETIC	LINE START	(RECIPROCA	TING)
Number of compressor		1		2	
Nominal motor	HP(kW)	10.1	(7.5)	7.4(5.5)	10.1(7.5)
Locked rotor current	Amps	8	5	83	85
Normal run current (AS1861)	Amps	19	.2	15.5	19.2
Swept volume	cc/rev	20)1	160.8	201
Bore	mm		ø44	.45	
Stroke	mm		25		
Speed	rpm		29	00	
Number of cylinders		Ę		4	5
Oil charge	ml	450	00	3000	4500
Type of oil) OR SUNISO 30	
Crankcase heater	watts	72)	62	72
[REFRIGERATION SYSTEM]					
Refrigerant			R	22	
Refrigerant charge per circuit	kg	9.		6.6	9.7
Number of refrigerant controls		1			2
Refrigerant control				ary tube	
Reverse cycle valve				valve	
Detrost system		Reverse cycle defrost			
Defrost system Limit of pipe's length	m	50			
Limit of pipe's length Limit of pipe's height difference	m mtrs	20 (In c		50 init above outdo	oor unit)

Product number	Indoor unit		PEH-10M	IVA ELI	PEH-15MYA-EU	PEH-20MYA-EU
Floduct Humber	Outdoor unit		PUH-10MYC1-EU	PUH-10MYE-EU	PUH-15MYC1-EU	PUH-20MYC1-EU
[INDOOR AIR CIRCUIT]	Outdoor unit		PUN-10WITCI-EU	PUN-TUNITE-EU	1 OTT-13WTOT-LO	1 011-20W1101-L0
Number of blowers				2)	
Diameter of blowers		mm	21	<u></u>	28	20
Width of blowers		mm	27		245	275
Blower drive		111111	Direct			drive
		kW	1.00	1.00	2.20	3.70
Fan motor output		A	2.0	1.8	4.5	4.7
Fan motor run current		L/s	1500	1500	2333	3000
Nominal air quantity		Pa	1500		2333	
External static pressure						
Supply air dimensions(hxw)		mm	341X1302	342X1318	412X1000	412X1209
Return air dimensions(hxw) [EVAPORATOR]		mm	248>	(998) 590 <i>X</i>	(1415
Number of evaporator			1		2	2
Face area		sq.m	0.	50	0.86	0.98
Rows deep				۷	1	
Rows high			1:	5	2	4
Finned length		mm	13	00	1415	1615
Face velocity		m/s	3	.0	2.7	3.0
Fin per meter / pitch			513/	1.95	513/1.95	592/1.69
Fin material thickness		mm	0.115			
Fin material/Type	Fin material/Type		Aluminium / Ring			
Fin coating			NA 510 D*1 (NA 549*2)			
Tube diameter		mm			52	,
Gauge of copper tube		mm		0.3		
Pipe type			Plain tube		Groove tube	
Number of circuit			10		16 24	
[OUTDOOR AIR CIRCUIT]						
Number of fans			2	1	2	2
Diameter of fan		mm	600		800	
Blower drive					drive	
Quantity of motor			2	1	2	
Fan motor output		kW	2X0.15	0.35		0.35
Fan motor run current		Α	1.0	1.2		.3
Nominal air quantity		L/s	3167	3333	2X3	3083
[CONDENSER]						
Number of condensers			2	1		2
Face area		sq.m	2X2.1	1.58	2X1.07	2X1.32
Rows deep				3	3	
Rows high			30 44 37		37	
Finned length		mm	2706	1400		00
Face velocity		m/s	1.35	1.95	2.89	2.34
Fin per meter/Pitch			474/2.11	513/1.95		/2.11
Fin material thickness		mm			115	
Fin material/Type				Aluminiu	ım / Ring	
Tube diameter/Gauge		mm	9.52 / 0.35			
Pipe type				Groov	e tube	
Number of circuit			11	16	11	14

Specifications subject to change without noice

^{*1} Corrosion proof property: Salt spray JIS Z 2371, 500hrs Humiditiy test 50°C 98% 500hrs. *2 Corrosion proof property: Salt spray JIS Z 2371, 1000hrs Humiditiy test 50°C 98% 1000hrs. (anti corrosion as special order)


Product number	Product number Indoor unit			PEH-10MYA-EU		PEH-15MYA-EU	PEH-20MYA-EU	
	Outd	loor unit		PUH-10MYC1-EU	PUH-10MYE-EU	PUH-15MYC1-EU	PUH-20MYC1-EU	
[ENCLOSURE	AND FRAME]							
		height	mm	42	28	70	06	
Dimension	Indoor unit	width	mm	16	15	1690	1993	
		depth	mm	6	50	86	35	
		height	mm	980	1175	12	00	
Dimension	Outdoor unit	width	mm	1400	1250	19	51	
		depth	mm	700	550	10	80	
External finish	(indoor unit)			Galvanized steel				
External finish	(outdoor unit)			Acrylic resin coationg (Color: Munsell 5Y8/1)				
Panel thickness	i		mm	1.2				
Condense drain	size		mm	25.4				
Weight Indoor u	nit		kg	8	4	180	212	
Weight Outdoor	Weight Outdoor unit			240	221	431	472	
Sound pressure level (indoor unit)			dbA	59		61	62	
Sound pressure level (outdoor unit)			dbA	65		69		
Sound power level (indoor unit)			dbA	67		69	70	
Sound power le	vel (outdoor unit)		dbA	7	6	8	0	


INSTALLATION


1. Space required around unit.

Indoor unit

Dimension of the unit and space necessary for sevicing.









	Α	В
PEH - 5	1560	1000
PE(H) - 7, 8	1880	1320
PE(H) - 10	2080	1520

PE(H)-15,20






	Α	В
PE(H) - 15	2187	1587
PE(H) - 20	2490	1890

Outdoor unit


Secure enough space necessary for servicing, installing, and for proper function of the unit. To prevent short-cycling, remove obstacles as much as possible.

PUH-5, 8, 10 (Side blow)

(1) At a single installation




With the inlet surface facing a wall.



With the outlet surface facing a wall.

(2) Relation of unit when many set up unit.



Please set the unit that the inlet air and the outlet air are not influenced.


PU(H)-7,8, 10 (Upper blow)

(1) At a single installation


The obstacle is on the outlet side. (Fig 1)

The obstacle is in three directions. (Fig 2,3)


The obstacle is in four directions. (Fig 4)



The right and left side and the back and forth side must be opened.




However, the outlet side must be opened.



panel, you need 500 over. If this side is inlet, you need 300 over.


However, if the service panel is an interior side, the right or left side need 500 over.



All "A" is 500 over. However, outlet side must be opened. And the obstacle in two directions must be lower than the unit.

Fig 4

(2) Relation of unit when many set up unit. (Fig 5,6,7)







Fig 7 All "A" is 500 over in any case.

PU-15

(1) At a single installation

The obstacle is on the outlet side. (Fig 1)

The obstacle is in four directions. (Fig 2) 111








Fig 2

(2) Relation of unit when many set up unit. (Fig 3,4)







All "A" is 500 over. Fig 4

PU-20

(1) At a single installation

The obstacle is on the outlet side. (Fig 1) The obstacle is in four directions. (Fig 2)





(2) Relation of unit when many set up unit. (Fig 3,4,5) 300 over




Fig 3

If this side is service panel, you need 500 over. If this side is inlet. you need 300 over




Fig 4

All "A" is 500 over.

If this side is service panel, you need 500 over. If this side is inlet, you need 300 over.

If this side is service panel, you need 500 over. If this side is inlet, you need 300 over. 300 over 30<u>0 over</u>

All "A" is 500 over in any case. Fig 5


PUH-15, 20


(1) At a single installation

The obstacle is on the outlet side. (Fig 1)

The obstacle is in four directions. (Fig 2)

The obstacle is in three directions. (Fig 3,4)





However, outlet side must be opened. And the obstacle in two directions must be lower than the unit.

However, the outlet side must be opened.




Fig 3





Fig 4

(2) Relation of unit when many set up unit. (Fig 5,6,7)




2. Preparation before installing

Indoor unit

Please use the specified hanging bolt in any case. Hanging bolt is local supply.


Please use the method below or use the angle and the rectangular lumber, etc. and install the hanging bolt.




3. Installation of the unit.

Indoor unit

Please carry the packed until parallelly to installed place. Please install the unit before construction of the ceiling -lined.




PE(H)- 15, 20



Outdoor unit

Fix unit tightly with bolts as shown below so that unit will be securely fixed in place use concrete or angle foundation of unit.

At the time of bottom piping of refrigerant pipe, build a 100mm or higher foundation so that piping will go through bottom of unit.




Duct construction.

Provide canvas flexible ducting between unit when connect to the duct-work.

The duct unit must use a nonflammable material.

Provide sufficient insulation for prevent dewdrop.




Lifting method.

When the unit is to be lifted and moved, attach ropes to the suspension plates(3 p.c.s) provided on the top of the unit.


When the unit is lifted, it 's center of gravity tends to shift the unit one side and so balance, such as that in the figure below, should be attained.

The angles at which the ropes suspend the unit should be at least 60° at the compressor end and at least 45° at the condenser end. Care should be taken to avoid contact with the main unit while carrying.

It is necessary to protect the unit with the blanket so that the ropes should not injure the unit.



Example PUH-15, 20




Piping connection


★ Warning.
Please follow the following procedures, during the piping connection work is carried out. If the procedures are not followed properly, the refrigerant and valve sheet might gush out from the ball valve. It might cause the injury.

In case of Brazing type


1. Open the ball valve cap before removing the by-pass tube. Then, turn the knob of the ball valve from 'close' to 'open' position.




2. Please repeat to close and open the ball valve of gas and liquid side at the same time (3 times or more). And finally make sure the ball valve is at close position.



3. Cut part A (two places) of the by-pass tube as shown in figure below.




4. Make sure that the ball valve is wrapped with enough wet cloth, during the brazing of the by-pass tube (for cooling purpose). Make sure the temperature of ball valve is below 100 degree centigrade. (If the temperature of the ball valve is over 100 degree centigrade, the refrigerant and valve sheet might gush out from the ball valve. It might cause the injury.)



- 5. Please make sure the ball valve is cool enough when removing the by-pass tube. Wait for a while for further cooling of the ball valve, before the piping connection work begins.
- 6. When the piping connection begins. Again, make sure that the ball valve is wrapped with enough wet cloth, during the brazing for cooling the ball valve. Make sure the temperature of ball valve is below 100 degree centigrade. (If the temperature of the ball valve is over 100 degree centigrade, the refrigerant and valve sheet might gush out from the ball valve. It might cause the injury.)
- 7. Before charging the refrigerant, vacuum the pipes to clear all the air and water.
- 8. Charge the additional amount of refrigerant according to the table.
- 9. Turn the knob of the ball valve to 'open' position after leak check.
- 10. Finally, put the cap back to the ball valve.

In case of Flare, Flange type

- 1. PROCEDURE TO CONNECT THE EXTENSION PIPE. Proceed with the connection as follows:
 - (1) Open the ball valve cap before cutting the by-pass tube. (Fig.1)
 - (2) Check the ball valve section is completely closed.(Fig.2)
 - (3) Cut two parts of the by-pass tube.(Fig.4)



- (4) Remove the connection pipe assy.(Fig.5) Throw away the packing. Do not brazing the pipe while the flange assy connect the ball valve. (Except the PUH-5)
- (5) Remove the by-pass tube.(Fig.6)
 Braze the extension pipe with the flange assy. (Except the PUH-5)
- (6) Connect the extension pipes with the packing between the ball valve and the flange.(Fig.7) Use the attached new packing certainly.




Fig. 1

Close Fig. 2

Pipe assy

Valve knob

Valve knob


Open Fig. 3

Unit side


Fig. 5

2. HANDLING PRECAUTIONS.

- (1) The extension pipes should be connected with the valve knob completely closed. (Fig.2) Check leak test the part of flange and flare.
- (2) Before charging the refrigerant, vacuum the pipes to clear all the air and water.
- (3) Charge the additional amount of refrigerant according to the table.
- (4) Turn the ball valve knob to "Open" position after leak check again. (Fig.3)
- (5) Finally, put the cap back to the ball valve.



throw away



4. Refrigerant piping.

Extension piping and installation parts are field supply. Perform the work only after carefully reading the appropriate instructions.


Install the unit where the refrigerant piping is shortest, the difference between the indoor unit and outdoor unit is smallest.

As pipes purchased in the market may contain dust, below them off with dry inlet gas.


Take care not to allow dust and water content to enter the piping during pipe processing or installing.

Minimize the number of bends, and make the bending radius as long as possible.

Always observe the restriction(allowable length, height difference, pipe diameter) on the refrigerant piping. For soldering & brazing, use high-quality materials.



When the outdoor unit is lower.



When the outdoor unit is higher.

Never purge air with a refrigerant. Always use a vacuum pump for purging.

Provide proper insulation to the piping. Insufficient insulation cause poor cooling/heating performance or condensation drip, leading to unexpected trouble.


Do not insulate gas or low pressure pipe and liquid or high pressure pipe together.

For the connection of the refrigerant piping, leave the valve of the outdoor unit fully closed (as set before shipment), and no operate it until the connection between the indoor/outdoor units and refrigerant piping, refrigerant leak test and evacuation work have been completed. The maximum permissible values are shown below.

Remove the cover (grommet) attached sheet metal at exit of heat exchanger pipe of indoor unit before connecting the local piping.

(This cover is protect the pipe from sheet metal edge at unit transportation.)

Please insulate liquid pipe & gas pipe (two places for each) with an insulated pipe of the attachment after connecting piping.



		PEH-5	PE(H)-7	PE(H)-8	PE(H)-10	PE(H)-15	PE(H)-20
Dimension A (m)		20	20	20	20	20	20
Dimension B (m)		30	30	30	30	30	30
Number of bends		15	15	15	15	15	15
Total piping length (m)		50	50	50	50	50	50
Piping	Liquid pipe (mm)	12.7	15.88	15.88	15.88	2x15.88	2x15.88
size	Gas pipe (mm)	19.05	25.4	25.4	28.6	2x25.4	2x28.6


Airtight test

Airtight test should be made by pressurizing nitrogen gas to 3Mpa.

For the test method, refer to the following figure.

(Make a test with the valve closed. Be also sure to pressurize both liquid and gas pipe.) The test result can be judged good if the pressure has not been reduced after leaving for about one day after completion of nitrogen pressurization.

a.	Nitrogen gas
b.	To indoor unit
C.	System analyzer
d.	Low knob
e.	High knob
f.	Valve
g.	Liquid gas
h.	Gas pipe
i.	Outdoor unit
j.	Service port




Evacuation

Evacuation should be made from the service port provided on the outdoor unit's valve to the vacuum pump commonly used for both liquid pipe and gas pipe. (Make evacuation from both liquid pipe and gas pipe with valve closed.)

Remember : Never carry out air purge by refrigerant.

a.	System analyzer
b.	To indoor unit
C.	Low knob
d.	High knob
e.	Valve
f.	Liquid gas
g.	Gas pipe
h.	Outdoor unit
i.	Service port
j.	Vacuum pump



Additional refrigerant charge

The mount of refrigerant charged in this unit is a appropriate for 5-meter long refrigerant pipes. Refer to the table below and add the corresponding amount of refrigerant if the pipes are extended.

(The refrigerant is charged in the outdoor unit.)

	Refrigerant piping length										
	unit	5m	10m	15m	20m	25m	30m	35m	40m	45m	50m
	PU-7										
	PU-8	0	0.8	1.6	2.4	3.2	4.0	4.8	5.6	6.4	7.2
l	PU-10										
charge	PU-15	0	240.0	0.4.0	2x2.4	2x3.2	2x4.0	2x4.8	2x5.6	2x6.4	2x7.2
mount R-22	PU-20		2XU.8	2X1.0							
(kg)	PUH-5	0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5
	PUH-7	0	0.8	1.6	2.4	3.2	4.0	4.8	5.6	6.4	7.2
	PUH-8	0	0.8		2.5	3.3	4.0		5.8	6.7	7.
	PUH-10	0	0.6	1.7	2.5	ა.ა	4.2	5.0	5.0	0.7	7.5
	PUH-15	0	240.0	0.4.7	2,42.5	242.2	244.2	245.0	2vE 0	2,40.7	07.5
	PUH-20	U	ZXU.8	ZX1.7	/ ZX2.5	2x3.3	3 ZX4.Z	∠x5.0	∠x5.8	2x6.7	2x7.5


The outdoor unit of PE-5,8,10 have side blow type and upper blow type. Factory charge refer to the table below.

	Factory charge							
	Outdoor unit							
	Side	blow	Upp	er blow				
	_	_	PU-7	5.7				
	_	_	PU-8	5.0				
	_	_	PU-10	8.7				
charge	_	_	PU-15	2x4.8				
mount	_	_	PU-20	2x9.7				
R-22 (kg)	PUH-5	5.0	_	_				
(Ng)	_	_	PUH-7	5.7				
	PUH-8	6.6	PUH-8	6.6				
	PUH-10	9.9	PUH-10	9.9				
	_	_	PUH-15	2x6.6				
	_		PUH-20	2x9.7				


5. Drain piping

- •Incline the drain piping to the outside (drain side) as shown in the figure below.
- •The outlet of the indoor unit drain pipe is Rc1.
- •After completion of piping, confirm that drainage is good and that there are no leaks.

Indoor unit drain piping



The drain piping should have a drain trap.



6. Electric wiring

Construct the earth connection.

All electrical work must be carried out by a suitable qualified electrical trades-person and in accordance with local supply authority requirements and associated regulators.

The outdoor unit is to be wired directly from an electrical distribution board either by a circuit

The outdoor unit is to be wired directly from an electrical distribution board either by a circuit breaker (preferred) or HRC fuse.


Fix power source wiring to control box by using buffer bushing for tensible force (PG connection or the like). Connect control wiring to control terminal block through the knockout hole of control box using ordinary bushing.

NOTE: Earth wiring must be connected.


Arrangement such as terminal block in control box

Control module of indoor unit PEH-5, PE(H)-7, 8,10

Control module of indoor unit PE(H)-15, 20




Control module of outdoor unit (PUH-5, 8, 10)




Control module of outdoor unit PU(H)-7, 8, 10

Control module of outdoor unit PU-15



Control module of outdoor unit PU-20


Control module of outdoor unit PUH-15,20



Method for connecting electric wire


Please do the wiring after consulting the electric power company of jurisdiction beforehand in the instruction.

(1) The entire wiring diagram of unit.




a.	Power supply
b.	Main switch/fuse (field supply)
c.	Power supply wiring for outdoor unit
d.	Power supply wiring for indoor unit
e.	Outdoor unit
f.	Indoor unit
g.	Connection wiring for indoor / outdoor units (polarity)
h.	Remote controller (field supply)
i.	Connection wiring for indoor / remote controller (no polarity)
j.	Earth


(2) Power supply construction and electric wiring connection of indoor and outdoor unit.



A.	Indoor unit
B.	Power cable wiring
C.	Control cable wiring (Fixing wire Do not remove)
D.	Outdoor unit
E.	Breaker
F.	Fuse
G.	Power supply terminal bed
Н.	Control cable terminal bed

(3) Indoor unit and remote controller.(OPTION:PAC-204RC) Connect the wires on the basis of the following wiring diagram.





(4) Wiring example (For metal piping)

	Power cable	Breaker capacity	Over current protection switch	Earth cable	Control wiring
PEH - 5	2.0mm ²	15A	15A	2.0mm ² over	
PE(H) - 7	2.0mm ²	15A	15A	2.0mm ² over	
PE(H) - 8	2.0mm ²	15A	15A	2.0mm ² over	Cable or wire of
PE(H) -10	2.0mm ²	15A	15A	2.0mm ² over	0.75mm ²
PE(H) -15	2.0mm ²	30A	30A	2.0mm ² over	(24VDC)
PE(H) -20	2.0mm ²	30A	30A	2.0mm ² over	
PUH - 5	8mm ²	50A	50A	8mm ² over	
PU(H) - 7	8mm ²	50A	50A	8mm ² over	Cable or
PU(H) - 8	8mm ²	50A	50A	8mm ² over	wire of 2
PU(H) -10	14mm ²	60A	60A	14mm ² over	0.75mm ² (24VDC)
PU(H) -15	14mm ²	100A	100A	14mm ² over	(21100)
PU(H) -20	22mm ²	125A	125A	22mm ² over	

The grounding wire must be of the same diameter as the power cable wires. Table above is an example.

The selection of other capacities should be determined in accordance with the relevant standards.

(5) Selecting earth leakage breaker (NV)

To select NF or NV instead of a combination of Class B fuse switch use the following. In the case of Class B fuse rated 15A.

	Fuse (class B)	Earth leakage breaker (with over-load protection)		
PEH - 5	15A	NV30-CA	15A	30mA 0.1s or less
PE(H) - 7	15A	NV30-CA	15A	30mA 0.1s or less
PE(H) - 8	15A	NV30-CA	15A	30mA 0.1s or less
PE(H) - 10	15A	NV30-CA	15A	30mA 0.1s or less
PE(H) -15	30A	NV50-CP	30A	30mA 0.1s or less
PE(H) -20	30A	NV50-CP	30A	30mA 0.1s or less
PUH - 5	50A	NV50-CA	50A	100mA 0.1s or less
PU(H) - 7	50A	NV50-CA	50A	100mA 0.1s or less
PU(H) - 8	50A	NV50-CA	50A	100mA 0.1s or less
PU(H) - 10	60A	NV60-CA	60A	100mA 0.1s or less
PU(H) - 15	100A	NV100-CP	100A	100mA 0.1s or less
PU(H) - 20	125A	NV225-CP	125A	100mA 0.1s or less

NV is a product of MITSUBISHI ELECTRIC. Table above is an example. The selection of other capacities should be determined in accordance with the relevant standards.

Note.

All electrical wiring must be comply with local electrical authority regulations.

7. The putting condition of the belt.

(PE(H)-15,20 only)


- 1. Set the parallel angle of the fan and the motor pulley as shown in the table and figure 1 below.
- 2.Set the tension of the per one belt when the flexion load is within the range as shown in the figure 1 below at the proper flexion. (A=4.5mm)
- 3.Adjust the suitable tension after the belt sit properly across the pulley (after more 24-28 hours working). When the new belt is used, adjust the suitable tension about the 1.3 times of the maximum value of the flexion load.
- 4. Readjust the belt every 2,000 hours after the first adjustment.

Exchange the belt when the belt's surroundings length has expanded by 2% including the first expansion of the belt. (about 1%)

(about 8,000 hours converted working time)

table

pulley parallel angle	K (")	note
pulley	10 or less	gap of 3mm every 1m








Figure 2 Belt tension

8. Before starting the Trial run.

Check items

- (1) Check to see wheter there are refrigerant leakage, and slack power or transmission cable.
- (2) Conform that 500V megohmmeter shows 1.0M ohm or more between power supply terminal and ground.
- (3) Do not operate in the case of 1.0M ohm or less.

Note: Never carry out megger-ohm check over terminal control board.

Otherwise the control board would be broken.

(4) Check to see wheter both gas and liquid valves are fully opened.

Note: Be sure to tighten caps.

- (5) Turn universal power supply at least 6 hours before gettig test run in order to current to crank heater. If current-carrying hours are too short, it may result in a malfunction of compressor.
- (6) Confirm operation of high-pressure switch.
 - If the two lead wires of the outdoor unit fan motor are disconnected from the connector and cooling is performed, the high-pressure switch should operate and stop the unit after 5 to 10 minutes.
- (7) Confirm that the fans of the indoor and outdoor unit rotate in the correct direction. Change the power supply phase connections if it is rotating in the reverse direction.

Perform trial operation after completion of the above items.


INSTRUCTIONS FOR USE

1. Check points for operation.


Check the following points before you operate your air conditioner.

(1) Check that there is nothing blocking the flow of air from the air outlet into the air inlet.

Indoor unit




Outdoor unit



Obstacle blocking air inlet.

(2)Make sure the air conditioner is properly grounded by checking the ground terminal.




2. Caution for use.

Keep the following points in mind to safeguard against failures and breakdowns.


(1) This air conditioner does not restart within 3min. after shut down.

(These models have a crankcase heater in the compressor. If the air conditioner is shut down for a short time, please do not turn the power switch to OFF, but turn the operation switch to OFF.)



(3) Do not stick rods or other objects through the air outlet during operation since this may result in equipment damage or personal injury.





3.Maintenance.

For superior performance and lasting durability, please do not forget to conduct proper and regular maintenance.

\Lambda Warning

1.Do not wash the unit with water.

If washed with water, electrical shock may be caused.

2. Ahead of the maintenance.

For safety, turn the power source off before service work.

3.1 Cleaning the Air Filter

Clean the air filter about once a week with a neutral cleanser and leave it to dry in a shady location. Clean more regularly if the air filter gets very dirty.

If the filter gets blocked, air will not be sucked in properly, and the cooling effect will deteriorate. Failure to clean the air filter may result in equipment breakdown or malfunctions.

3.2 Cleaning panels


Clean dirt off front panel as follows.

Use a household neutral cleanser such as for dishes or vegetables. Moisten a soft cloth with the cleanser, then wipe lightly. Next,wipe three or four times with another soft cloth moisten with water. Finally, wipe off all the remaining cleanser with a soft cloth.

Moisten a soft cloth with the alcohol, then wipe off lightly. Isopropyl alcohol is sold at stores as reagents in small quantities.


Note:

Alcohol is highly combustible. Take extreme care when handling. Also, do not use paint or adhesive thinner.



3.3 Cleaning the Outdoor Unit Heat Exchanger

If you use your air conditioner for prolonged periods, the outdoor heat exchanger will become dirty, impairing its function and reducing air conditioners performance. Consult your equipment supplier or air conditioning contractor on how to clean the heat exchanger.



4. When beginning to use air conditioner again.

Please turn on the power supply after confirming an following check is done and abnormality is not found.

- (1) It is confirmed that air inlet and outlet are not blocked.
- (2) It is confirmed that the earth connection line does not come off.
 The earth connection line is occasionally installed in the outdoor unit.
- (3) It is confirmed that there are neither lifting, blocking, nor bending about the drain-hose.

Keep the power switch ON for more than 6hours before starting operation, to operate the crankcase heater to drive refrigerant out of oil.

Do not turn the power supply OFF during seasons of heavy use. Doing so can result in failure.

5. When the air conditioner is not to be used for a long time.

- (1) If the air conditioner is not to be used for a long time due to a seasonal change etc.,run it for 4-5hours with the air blowing until the inside is completely dry.
 - Failing to do so can result the growth of unhygienic, unhealthy mold in scattered areas throughout the room.
- (2) When it is not to be used for an extended time, keep the < power supply >turned OFF. If the power supply is kept on, several watts or several tens of watts will be wasted. Also, the accumulation of dust, etc., can result in fire.

5-1 In case of failure.

- (1) Never remodel the air conditioner.

 Consult your dealer for any repair service.
 - Improper repair work can result in water leakage, electric shock, fire, etc.
- (2) If the poser breaker is frequently activated, get in touch with your dealer. Leaving the unit as it is under such conditions can result in fire or failure.
- (3) If the refrigeration gas blows out or leaks, stop the operation of the air conditioner.
- (4) Thoroughly ventilate the room, and contact your dealer.

 Leaving the unit as it is can result in accidents due to oxygen deficiency.

6.Transferring work, and construction

6-1 Transfer of installation.

- (1) When removing and reinstalling the air conditioner when you enlarge your home, remodel, or move, consult with your dealer in advance to ascertain the cost of the professional engineering work required for transferring the installation.
- (2) Please do not mix the one other than a specified refrigerant when you add the refrigerant (R-22) at the installation and the transferring.
- (3) When moving or reinstalling the air conditioner, consult with your dealer. Defective installation can result in electric shock, fire, etc.

6-2 Place for installation.

Please do not use the unit in the following places.

- (1) Place where a lot of oil (The machine oil is contained), moistures, and dust exist.
- (2) Place where a lot of salinities such as beach districts exists.
- (3) Place where sulfur gas, volatile gas, and corroded gas are filled.
- (4) Place where acid solution is frequently used.
- (5) Place where special spray is frequently used.
- (6) Hot spring zone.
- (7) Never machine (high cycle welding machine etc.) generating highcycle.
- (8) Place where ventilation entrance of outdoor units is closed by snowfall.
- (9) The unit must be installed on stable, level surface.

The main body might corrode when the unit is used in such a place, the refrigerant leak, the performance of the unit decrease remarkably, and it cause the damage of parts of the unit.

6-3 Regarding electric work.

- (1) The electrical work must be undertaken by a person who is qualified as an electric engineer according to the (technical standard respecting electrical installation), (internal wiring rules), and the installation instruction manual with the absolute use of exclusive circuits.
- (2) Please install a special power supply in the power supply.
- (3) Please install the earth connection for the electric shock prevention.
- (4) Never connect the grounding wire to a gas pipe, water pipe, arrester, or telephone grounding wires. For details, consult with your dealer.
- (5) In some types of installation sites, the installation of an earth leakage breaker is mandatory. For details, consult with your dealer.
- (6) The breaker and the fuse must use the one of correct capacity.

6-4 Conseration of the noise.

- (1) Take sufficient measures against noise when installing the air conditioners at hospitals or communication-related businesses.
- (2) If the air conditioner is used in any of the above-mentioned environments, frequent operational failure can be excepted.
 - It is advisable to avoid these type of installation sites.
 - For further details, consult with your dealer.
- (3) Choose a place where cool or warm air and noise from the outdoor air outlet of the air conditioner do not inconvenience the neighbours.
- (4) If any alien object is placed near the air outlet of the unit, decreased performance and increased noise can result.
 - Avoid placing any obstacles adjacent to the air outlet.
- (5) If the air conditioner produces any abnormal sound, consult with your dealer.

6-5 Disposing of the unit.

When you need to dispose of the unit, consult your dealer.

If pipes are removed incorrectly, refrigerant (fluorocarbon gas) may blow out and come into contact with your skin, causing injury.

Releasing refrigerant into the atmosphere also damages the environments.

6-6 Maintenance and inspection.

- (1) If the air conditioner is used throughout several seasons, the insides can get dirty, reducing the performance.
- (2) Depending upon the conditions of usage, foul odours can be generated and drainage can deteriorate due to dust and dirt. etc.


7. Trouble shooting

Before you ask for repair service, check the following points:

State of Machine	Cause	Troubleshooting
	Power failure.	Press the [ON/OFF] button after power restoration.
It does not run.	The power supply is turned OFF.	Turn the power supply ON.
	The fuse in the power supply is gone.	Replace fuse.
	The earth leakage breaker is gone.	Put in the earth leakage breaker.
Air flows out but it does not cool or heat enough.	Improper temperature adjustment.	After checking the set temperature.
	The filter is filled with dust and dirt.	Clean up the filter.
	There are some obstacles at the air inlet and outlet of the units.	Remove.
	Windows and doors are open.	Close.
	Insufficient refrigerant charge.	Contact with your installing contractor.
Cool or warm air does not come out.	The restart-preventing circuit is in operation for 3 minutes.	Wait for a while. (To protect the compressor, a 3-minute restart-preventing circuit is built into the unit. Therefore, there are occasions sometimes when the compressor does not start running immediately. There are cases when it does not run for as long as 3 minutes.)
	Indoor unit operation was started anew during the heating and defrosting operation. (5 ~10 HP only)	Wait for a while. (Heating operation starts after ending defrosting operation.)
Fan runs but compressor do not run.	The set temperature of thermostat is excessively high for cooling. excessively low for heating. (PEH only)	For temperature control, decrease the set temperature at cooling. increase the set temperature at heating. (PEH only)
	The room temperature is excessively low for cooling. excessively high for heating. (PEH only)	Can not be operated as it is out of temperature control range.
Fan runs but stops immediately.	Air outlet and inlet are blocked.	Remove blocking matter.
Fogged white steam is discharged from the indoor unit.	When the indoor temperature and humidity are high, such a phenomenon is occasionally had at the beginning of system operation.	It is not a breakdown. Please use as it is.
Water or steam is discharged from the outdoor unit.	At cooling, water which places to cooling piping and piping connection part drops. When heating, water which places to the heat exchanger drops. (PEH only)	It is not a breakdown. Please use as it is.
On heating, the air flow stops although a set temperature is not reached. (PEH only)	Frost adheres to the outdoor coil when the temperature on the outside is low and humidity is high. This frost is melted.	It is not a breakdown. Please use as it is.

HOW TO OPERATE (OPTION PAC-204RC)

Display section



- (A) [Current/start/ending time] Display
- Operation mode
 Displays the status of operation.
- © [Checking] Display
 This displays indication when some abnormality occurs in the unit.
- (D) [Set temperature] Display Displays the set temperature.
- (E) [Operation] Lamp Lights up during operation, goes off during stop.
- (F) [Room temperature] Display Displays the temperature of the air sucked in during operation.
- © [Fan speed] Display
 This displays indication High-speed or Low-speed.
- (H) [Key lock] Display This display indication during key lock function active.

For purposes of explanation, all the displays on this page are shown in their lit condition. This configuration does not occur in the actual unit


Before starting operation

* Make sure that the power supply is turned ON before use. (Keep the power supply turned ON at all times when the air conditioner is in use. Use of the unit without power can result in compressor failure.)

Warning:

Check and confirm the power circuit before use. For the contents, refer to the previously described chapter [Crucial points to be observedfor safety].

1-1 ON / OFF



(A) Operation lamp

Start an operation

① Press the [ON/OFF] button
Operation lamp lights up and operation starts.


Stop an operation

- Press the [ON/OFF] button again
 Operation lamp goes off and operation stops.
- * Once the buttons have been set, pressing of the [ON/OFF] button only can repeat the same operation thereafter.
- * During operation, the operation lamp above the [ON/OFF] button lights up.

Caution:

Even if the operation button is pressed immediately after the operation is once stopped, operation is not restarted for about 3 minutes. This function protects the machine. It automatically starts operation after the lapse of approximately 3 minutes.

1-2 Selecting operation



When selecting operation

① Press the [MODE] button
 Consecutive press of the [MODE] button switches the operation
 over to "FAN", "COOL", "HEAT" and ※ "AUTO". For the contents
 of operation, check the display.

For fan

Press the [MODE] button and bring up the "FAN" display.

- * The fan operation functions to circulate the air in the room.
- * The temperature of the room cannot be set by fan operation.

Caution:

Never expose your body directly to cool air for a long time. Excessive exposure to cool air is bad for your health, and should therefore be avoided.

For cooling

Press the [MODE] button and bring up the "COOL" display.

For heating

Press the [MODE] button and bring up the "HEAT" display.

Caution:

- * When the air conditioner is used together with burners, thoroughly ventilate the area. Insufficient ventilation can result in accidents due to oxygen deficiency.
- * Never place a burner at a place where it is exposed to the airflow from the air conditioner. Doing so can result in imperfect combustion of the burner.

For Auto change over *

Press the [MODE]button and bring up the "AUTO" display


** This function is special order. Please consult your local Mitsubishi Electric Sales office for application advice on this function.

Because this function need low ambient cooling parts as option.

Indoor temperature can be set within the following range.

Indoor temperature setting range:17~30°C

1-3 Room temperature adjustment



A Set temperature display and room temperature display

To change room temperature

① Press the room temperature button and set the room temperature of your choice.

Press \triangle or ∇ once changes the setting by 1°C. If the pressing is continued, the setting continues to change by 1°C.


* Indoor temperature can be set within the following range.

Cooling 19 ~ 30℃

Heating 17 ~ 28℃

- * It is impossible to set the room temperature by the air-blow operation

1-4 Time setting



- A Current time display
- (B) Timer Hold/Resume display

Clock key

- ①Press the key one time will activate set clock mode. Press the key again will disable set clock mode.
- 2~4 Under set clock mode, the real time clock and present day setting can be changed by pressing Day key, Hour key or Minute key.

7-Days timer key

- 1) There are two keys for timer. One is ON Timer, another is Off Timer.
 - Press the key one time will activate set timer mode. Press the key again will disable set timer mode.
- 2~4 Under set timer mode, the 7-days timer setting can be changed by pressing Day key, Hour key or Minute key.

Day key

②During set clock mode or set timer mode, press the key will change the day setting.

Hour key

③During set clock mode or set timer mode, press the key will change the hour setting.

Minute key


4 During set clock mode or set timer mode, press the key will change the minute setting.

Timer Hold/Resume key

If 7-days timer is set, then the word "Timer Active" is displayed.

⑤To clear all the timers setting, Press and hold the hold key until the word "Timer Active" is not displayed. To resume the timer setting after timers have been held, press and hold the key until the word "Timer Active" is displayed.

1-5 Other function



Key lock

①Press the "MINUTE" key three times consecutively,
"KEY LOCK" symbol will appear on LCD screen.
At this time, only "ON-OFF" key is valid.
This function purpose is protect from mischief of child etc.

To cancel the key lock function, Please press "MINUTE" key three times consecutively again.

Test run

②Press the "TEST" key two times consecutively.

The unit will run and finished automatically after two hours.

1-6.Trouble shooting

Before you ask for repair service, check the following points:

State of Machine	Remote Controller	Cause	Troubleshooting
It does not run	"ON-OFF "display is not lit up No display appears even when the [ON/ OFF] button is pressed.	Power failure	Press the [ON/OFF] button after power restoration.
		The power supply is turned OFF.	Turn the power supply ON.
		The fuse in the power supply is gone.	Replace fuse.
		The earth leakage breaker is gone.	Put in the earth leakage breaker.
Air flows out but it does not cool enough or heat enough.	The liquid crystal display shows that it is in the state of operation.	Improper temperature adjustment.	After checking the set temperature and inlet temperature on the liquid crystal display, refer to [To change room temperature] on page 107, and operate the adjustment button.
	орегацоп.	The filter is filled with dust and dirt.	Clean up the filter.
		There are some obstacles at the air inlet and outlet of the indoor and outdoor units.	Remove.
		Windows and doors are open.	Close.
Cool air or warm air does not come out.	The liquid crystal display shows that it is in operation.	The restart-preventing circuit is in operation for 3 minutes.	Wait for a while. (To protect the compressor, a 3-minute restart-preventing circuit is built into the indoor unit. Therefore, there are occasions sometimes when the compressor does not start running immediately. There are cases when it does not run for as long as 3 minutes.)
		Indoor unit operation was started anew during the heating and defrosting operation. (5 \sim 10 HP only)	Wait for a while. (Heating operation starts after ending defrosting operation.)
Can not change to Heat mode	Can not change to Heat mode when press the "MODE" key.	DIP switch1 is not correct	Change the DIP switch off to on. (Refer to Instruction manual for Installation.)

Error Display

Indicate	Cause	Troubleshooting
E01	Room temperature sensor open.	Automatically reset to restoration error.
E02	Room temperature sensor short.	Automatically reset to restoration error.
E03	Error input from Indoor unit or Outdoor unit.	Push the On-Off switch.(OFF to ON)

SPECIFICATION GUIDELINES

Air to air reverse cycle split air conditioning system.

The systems shall operate at out door ambient temperatures as high as °C.

The eventure shall have a total engling connective of LAM or greater with an indeer air quantity of

The system shall have a total cooling capacity of __kW or greater with an indoor air quantity of __L/s at __°C DB and __°C WB entering indoor coil temperature with a __°C temperature entering the outdoor coil.

The system shall have a sensible heat capacity of __kW or greater with a room DB temperature of __°C.

The total heating capacity (without electric element heaters) shall be __kW or greater at __°CDB, __°C WB outdoor air conditions, with __°C of indoor air entering indoor coil at __°CDB.

The compressors shall be a welded high efficiency hermetic type with internal vibration isolation and be equipped with a crankcase heater.

Coils shall be of non-ferrous construction with mechanically bonded aluminum plate fins Outdoor coils shall be made, of 9.52mm OD, 0.35mm thick formless copper tubes mechanically bonded to 0.12mm thick aluminum plate fins.

Face area of the coil shall not be less than __m² The coil shall be factory pressure and leak tested at 3.3 MPa pressure. The indoor coil face area shall be not less than __m².

Multi-wing propeller type fans shall be fitted at the condenser and shall be dynamically balanced, to ensure smooth airflow and shall discharge vertically and be direct driven by a weatherproof three phase squirrel cage __ kW induction motor.

The system shall be factory wired and all electrical wiring must comply with the Local wiring code (Controls and control wiring shall be supplied by the contractor). Compressors and fan motors shall have both internal and current sensitive overload devices.

An automatic defrost control shall be included to accomplish defrosting (only if required) every __ minutes for a period of __ minutes.

High pressure switch (pre-set) shall be factory installed.

The enclosure is weatherproof casing constructed of phosphatized, zinc coated steel with powder coating.

(OUTDOOR UNIT)

The unit shall be provided with hoisting plates for rigging and hoisting the unit. The hoisting plates shall be located in the pillars. (OUTDOOR UNIT)

The unit shall have a drain connection provided (25mm BSP:male thread).

The enclosure shall have openings provided for power connections.

Access for both service and installation shall be provided to compressors, control wiring, and fans.

Side panels and top panels shall be removable for easy service access.

The unit maximum dimensions shall be : height: __mm, width: __mm and depth: __mm (INDOOR UNIT) : height: __mm, width: __mm and depth: __mm (OUTDOOR UNIT)

Due to continuous product development, these guidelines are subject to change.

DATA BOOK PE,PEH



HEAD OFFICE DENKI BLDG., MARUNOUCHI,TOKYO 100-0005,TELEX J24532 CABLE MELCO TOKYO